

**SECTION 01 00 00
GENERAL REQUIREMENTS**

TABLE OF CONTENTS

1.1 GENERAL INTENTION	1
1.2 STATEMENT OF BID ITEM(S)	2
1.3 CONTRACTOR UNIT PRICING BREAKDOWN.....	8
1.4 SPECIFICATIONS AND DRAWINGS FOR CONTRACTOR	17
1.5 CONSTRUCTION SECURITY REQUIREMENTS.....	17
1.6 FIRE SAFETY.....	19
1.7 OPERATIONS AND STORAGE AREAS.....	21
1.8 ALTERATIONS.....	25
1.9 INFECTION PREVENTION MEASURES.....	26
1.10 DISPOSAL AND RETENTION.....	29
1.11 PROTECTION OF EXISTING VEGETATION, STRUCTURES, EQUIPMENT, UTILITIES, AND IMPROVEMENTS.....	29
1.12 RESTORATION	31
1.13 PHYSICAL DATA	31
1.14 PROFESSIONAL SURVEYING SERVICES	32
1.15 LAYOUT OF WORK.....	32
1.16 AS-BUILT DRAWINGS.....	34
1.17 USE OF ROADWAYS.....	34
1.18 COR'S FIELD OFFICE	34
1.19 TEMPORARY USE OF MECHANICAL AND ELECTRICAL EQUIPMENT.....	35
1.20 TEMPORARY USE OF EXISTING ELEVATORS.....	36
1.21 TEMPORARY USE OF NEW ELEVATORS.....	36
1.22 TEMPORARY TOILETS.....	36

Renovate Information
Technology Closets
VA Project 660-11-113

1.23 AVAILABILITY AND USE OF UTILITY SERVICES.....	36
1.24 NEW TELEPHONE EQUIPMENT	37
1.25 TESTS.....	37
1.26 INSTRUCTIONS.....	38
1.27 GOVERNMENT-FURNISHED PROPERTY.....	39
1.28 RELOCATED EQUIPMENT ITEMS.....	40
1.29 SAFETY SIGN.....	41
1.30 PHOTOGRAPHIC DOCUMENTATION - NOT REQUIRED.	41
1.31 FINAL ELEVATION DIGITAL IMAGES - NOT REQUIRED.	41
1.32 HISTORIC PRESERVATION.....	41

SECTION 01 00 00
GENERAL REQUIREMENTS

1.1 GENERAL INTENTION

- A. Contractor shall completely prepare site for building operations, including demolition and removal of existing structures, and furnish labor and materials and perform work for the Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein.
- B. The Overall Scope of Work includes modifications to all the active Information Technology Closets on the entire campus as identified in the Construction Documents for Buildings B.01, B.14, B.38, B.03, B.05, B.45, B.02, B.04, B.08, B.06, B.07, B.18, T-1, B.09, B.13, B.37, and B.16. This Scope of work includes, but is not necessarily limited to upgrading all IT Closet security access and control with upgrades to doors, door hardware, electronic card readers, associated door control and power wiring with upgrades to the existing campus door control access system infrastructure, new dedicated power circuits and emergency power upgrades with UPS backup, new lighting, new Variable Refrigerant Flow HVAC Systems and automated controls interfaced with the existing campus energy management system, securing the envelope of the Closets with modifications to the ceilings and walls, painting of the closets, and other miscellaneous repairs as illustrated on the construction documents. Work shall be priced per the Bid Items listed in Section 1.2 of this specification.
- B. Visits to the site by Bidders may be made only by appointment with the Medical Center Contracting Officer Representative (COR).
- C. Offices of Spectrum Engineers, 324 South State Street, Suite 400, Salt Lake City, UT 84111, as Architect-Engineers, will render certain technical services during construction. Such services shall be considered as advisory to the Government and shall not be construed as expressing or implying a contractual act of the Government without affirmations by Contracting Officer or his duly authorized representative.
- D. Before placement and installation of work subject to tests by testing laboratory retained by Department of Veterans Affairs, the Contractor shall notify the COR in sufficient time to enable testing laboratory personnel to be present at the site in time for proper taking and testing of specimens and field inspection. Such prior notice shall be not less than three work days unless otherwise designated by the COR.

- E. All employees of general contractor and subcontractors shall comply with VA security management program and obtain permission of the VA police, be identified by project and employer, and restricted from unauthorized access.
- F. Prior to commencing work, general contractor shall provide proof that a OSHA certified "competent person" (CP) (29 CFR 1926.20(b)(2)) will maintain a presence at the work site whenever the general or subcontractors are present.
- G. Training:
 - 1. All employees of general contractor or subcontractors shall have the 10-hour OSHA certified Construction Safety course and/or other relevant competency training, as determined by VA CP with input from the ICRA team. Managers and Supervisors shall have 30-hour OSHA certified Construction Safety course and/or other relevant competency training, as determined by VA CP with input from the ICRA team.
 - 2. Submit training records of all such employees for approval before the start of work.

1.2 STATEMENT OF BID ITEM(S)

A. GENERAL CONSTRUCTION:

- 1. **BID ITEM 1:** All IT Closets All Buildings Card Reader Upgrade with Emergency UPS Power Upgrade. Work includes ALL general construction, alterations, and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein to upgrade ALL the IT closet doors, door hardware, door closers, card readers, associated power and control wiring with upgrades to the existing door control access system to provide electronic card reader access to ALL IT Closet Doors in ALL Buildings. Bid Item 1 shall also provide new power wiring to All IT Closets and provide new UPS systems in each IT Closet as illustrated on the contract drawings.
- 2. **BID ITEM 2:** IT Closets Building B.01. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not

included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.01, and includes all work illustrated on the contract drawings not included in Bid Item 1.

3. **BID ITEM 3:** IT Closets Building B.14. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.14, and includes all work illustrated on the contract drawings not included in Bid Item 1.
4. **BID ITEM 4:** IT Closets Building B.38. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.38, and includes all work illustrated on the contract drawings not included in Bid Item 1.
5. **BID ITEM 5:** IT Closets Building B.03. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.03, and includes all work illustrated on the contract drawings not included in Bid Item 1.
6. **BID ITEM 6:** IT Closets Building B.05. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as

illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.05, and includes all work illustrated on the contract drawings not included in Bid Item 1.

7. **BID ITEM 7:** IT Closets Building B.45. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.45, and includes all work illustrated on the contract drawings not included in Bid Item 1.
8. **BID ITEM 8:** IT Closets Building B.02. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.02, and includes all work illustrated on the contract drawings not included in Bid Item 1.
9. **BID ITEM 9:** IT Closets Building B.04. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.04, and includes all work illustrated on the contract drawings not included in Bid Item 1.
10. **BID ITEM 10:** IT Closets Building B.08. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings

entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.08, and includes all work illustrated on the contract drawings not included in Bid Item 1.

11. **BID ITEM 11:** IT Closets Building B.06. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.06, and includes all work illustrated on the contract drawings not included in Bid Item 1.
12. **BID ITEM 12:** IT Closets Building B.07. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.07, and includes all work illustrated on the contract drawings not included in Bid Item 1.
13. **BID ITEM 13:** IT Closets Building B.18. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.18, and includes all work illustrated on the contract drawings not included in Bid Item 1.
14. **BID ITEM 14:** IT Closets Building T1. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and

construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building T1, and includes all work illustrated on the contract drawings not included in Bid Item 1.

15. **BID ITEM 15:** IT Closets Building B.09. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.09, and includes all work illustrated on the contract drawings not included in Bid Item 1.

16. **BID ITEM 16:** IT Closets Building B.13. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.13, and includes all work illustrated on the contract drawings not included in Bid Item 1.

17. **BID ITEM 17:** IT Closets Building B.37. Work includes ALL general construction, alterations, mechanical and electrical work, utility systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.37, and includes all work illustrated on the contract drawings not included in Bid Item 1.

18. **BID ITEM 18:** IT Closets Building B.16. Work includes ALL general construction, alterations, mechanical and electrical work, utility

systems, and necessary removal of existing structures and construction of certain other items as detailed on the drawings entitled Renovations to the Information Technology Closets as illustrated on the Construction Documents and specified herein not included in Bid Item 1. This Bid Item shall cover all Information Technology Closets in Building B.16, and includes all work illustrated on the contract drawings not included in Bid Item 1.

19. **BID ITEM 19:** IT Closets Mechanical/Electrical/Access Control Systems Commissioning. Work includes ALL Mechanical, Electrical and Access Control Systems Commissioning by an independent third party Commissioning Agent as detailed in this Specification and on the Contract Documents. Bid Item 19 shall be individually priced per building as follows:

BID ITEM 19-1: Commissioning Building 1

BID ITEM 19-2: Commissioning Building 14

BID ITEM 19-3: Commissioning Building 38

BID ITEM 19-4: Commissioning Building 3

BID ITEM 19-5: Commissioning Building 5

BID ITEM 19-6: Commissioning Building 45

BID ITEM 19-7: Commissioning Building 2

BID ITEM 19-8: Commissioning Building 4

BID ITEM 19-9: Commissioning Building 8

BID ITEM 19-10: Commissioning Building 6

BID ITEM 19-11: Commissioning Building 7

BID ITEM 19-12: Commissioning Building 18

BID ITEM 19-13: Commissioning Building T1

BID ITEM 19-14: Commissioning Building 9

BID ITEM 19-15: Commissioning Building 13

BID ITEM 19-16: Commissioning Building 37

BID ITEM 19-17: Commissioning Building 16

1.3 CONTRACTOR UNIT PRICING BREAKDOWN

- A. Insert Contractor Unit Pricing per the spreadsheet Pricing Bid Form Below. Bid item 1 covers ALL Buildings as described, with separate pricing for the Bond.
- B. Balance of Bid items (2 thru 18) will have a summary line item for the total cost of all work in that building as described, and a cost for the bond for all work described in that building.
- C. Bid Item 19 will Cost the Commissioning of all installed systems for each building, with a total cost for all Buildings and the All Building Bond Cost.

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
1	All IT Closets - All Buildings - Card Reader Upgrade with Emergency UPS Power Upgrade(s)			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
2	IT Closets Building B.01			
2-1	IT Closets Building B.01, Closet GA02			
2-2	IT Closets Building B.01, Closet GA16			
2-3	IT Closets Building B.01, Closet GB02			
2-4	IT Closets Building B.01, Closet GB05			
2-5	IT Closets Building B.01, Closet GB08			
2-6	IT Closets Building B.01, Closet GC10B			
2-7	IT Closets Building B.01, Closet GD03C			
2-8	IT Closets Building B.01, Closet GD13			
2-9	IT Closets Building B.01, Closet 1A19A			
2-10	IT Closets Building B.01, Closet 1B05			
2-11	IT Closets Building B.01, Closet 1B29			
2-12	IT Closets Building B.01, Closet 1C12			
2-13	IT Closets Building B.01, Closet 1D15F			
2-14	IT Closets Building B.01, Closet 1D18			
2-15	IT Closets Building B.01, Closet 1D49			
2-16	IT Closets Building B.01, Closet 1EAC			
2-17	IT Closets Building B.01, Closet 1F02			
2-18	IT Closets Building B.01, Closet 1G14			
2-19	IT Closets Building B.01, Closet 2A15C			
2-20	IT Closets Building B.01, Closet 2B09			
2-21	IT Closets Building B.01, Closet 2C20B			
2-22	IT Closets Building B.01, Closet 2D07			
2-23	IT Closets Building B.01, Closet 2EAC			
2-24	IT Closets Building B.01, Closet 3A15A			
2-25	IT Closets Building B.01, Closet 3B09			
2-26	IT Closets Building B.01, Closet 3C20B			
2-27	IT Closets Building B.01, Closet 3D07			
2-28	IT Closets Building B.01, Closet 4A15D			
2-29	IT Closets Building B.01, Closet 4B13			
2-30	IT Closets Building B.01, Closet 4C22B			
2-31	IT Closets Building B.01, Closet 4D05			
2-32	IT Closets Building B.01, Closet 5B13B			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
3	IT Closets Building B.14			
3-1	IT Closets Building B.14, Closet BA05			
3-2	IT Closets Building B.14, Closet BC07			
3-3	IT Closets Building B.14, Closet GB34			
3-4	IT Closets Building B.14, Closet GB51A			
3-5	IT Closets Building B.14, Closet GB64			
3-6	IT Closets Building B.14, Closet 1B01			
3-7	IT Closets Building B.14, Closet 1B25			
3-8	IT Closets Building B.14, Closet 2B02			
3-9	IT Closets Building B.14, Closet 2B43			
3-10	IT Closets Building B.14, Closet 3B03			
3-11	IT Closets Building B.14, Closet 3B01C			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
4	IT Closets Building B.38, Room 1A08			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
5	IT Closets Building B.03			
5-1	IT Closets Building B.03, Closet GA02			
5-2	IT Closets Building B.03, Closet GA08C			
5-3	IT Closets Building B.03, Closet GB01A			
5-4	IT Closets Building B.03, Closet GC14B			
5-5	IT Closets Building B.03, Closet 1A13C			
5-6	IT Closets Building B.03, Closet 1B01A			
5-7	IT Closets Building B.03, Closet 1C18A			
5-8	IT Closets Building B.03, Closet 1D01			
5-9	IT Closets Building B.03, Closet 2A13C			
5-10	IT Closets Building B.03, Closet 2B01A			
5-11	IT Closets Building B.03, Closet 2C14B			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
6	IT Closets Building B.05			
6-1	IT Closets Building B.05, Closet G100C			
6-2	IT Closets Building B.05, Closet 1A14			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
7	IT Closets Building B.45, Closet GA04			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
8	IT Closets Building B.02			
8-1	IT Closets Building B.02, Closet G008B			
8-2	IT Closets Building B.02, Closet GA28			
8-3	IT Closets Building B.02, Closet GB03			
8-4	IT Closets Building B.02, Closet GC13			
8-5	IT Closets Building B.02, Closet GD05			
8-6	IT Closets Building B.02, Closet 1A36			
8-7	IT Closets Building B.02, Closet 1B09			
8-8	IT Closets Building B.02, Closet 1C14			
8-9	IT Closets Building B.02, Closet 1D09			
8-10	IT Closets Building B.02, Closet 1D35			
8-11	IT Closets Building B.02, Closet 2A24			
8-12	IT Closets Building B.02, Closet 2B07			
8-13	IT Closets Building B.02, Closet 2C16			
8-14	IT Closets Building B.02, Closet 2D11			
8-15	IT Closets Building B.02, Closet 2D27			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
9	IT Closets Building B.04			
9-1	IT Closets Building B.04, Closet BB03A			
9-2	IT Closets Building B.04, Closet 1A30A			
9-3	IT Closets Building B.04, Closet 1C40A			
9-4	IT Closets Building B.04, Closet 1B14			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
10	IT Closets Building B.08, Closet 2A02A			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
11	IT Closets Building B.06, Closet B103			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
12	IT Closets Building B.07			
12-1	IT Closets Building B.07, Closet 1A38			
12-2	IT Closets Building B.07, Closet 1B05			
12-3	IT Closets Building B.07, Closet 1C10			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
13	IT Closets Building B.18, Closet 1A06			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
14	IT Closets Building T1, Closet 1A25			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
15	IT Closets Building B.09, Closet 1A21			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
16	IT Closets Building B.13, Closet 1A02			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
17	IT Closets Building B.37			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
18	IT Closets Building B.16			
18-1	IT Closets Building B.16, Closet GA50			
18-2	IT Closets Building B.16, Closet 1A46			
18-3	IT Closets Building B.16, Closet 2A48			

Bid Item	Work Description by Building Number	Bid Item Cost with overhead & profit (NO Bond) per Closet:	Total Bid Item with overhead & profit (NO Bond) by Building:	Total Cost of Bond per Total Building Bid Item:
19	IT Closets Mechanical/Electrical/Access Control Systems Commissioning			
19-1	Commissioning Building 1			
19-2	Commissioning Building 14			
19-3	Commissioning Building 38			
19-4	Commissioning Building 3			
19-5	Commissioning Building 5			
19-6	Commissioning Building 45			
19-7	Commissioning Building 2			
19-8	Commissioning Building 4			
19-9	Commissioning Building 8			
19-10	Commissioning Building 6			
19-11	Commissioning Building 7			
19-12	Commissioning Building 18			
19-13	Commissioning Building T1			
19-14	Commissioning Building 9			
19-15	Commissioning Building 13			
19-16	Commissioning Building 37			
19-17	Commissioning Building 16			

1.4 SPECIFICATIONS AND DRAWINGS FOR CONTRACTOR

- A. AFTER AWARD OF CONTRACT, Two (2) sets of specifications and drawings will be furnished. A CD will also be provided the successful bidder containing all specifications and contract drawings in PDF format.
- B. Additional sets of drawings may be made by the Contractor, at Contractor's expense, from the CD furnished by Issuing Office.

1.5 CONSTRUCTION SECURITY REQUIREMENTS

- A. Security Plan:
 - 1. The security plan defines both physical and administrative security procedures that will remain effective for the entire duration of the project.
 - 2. The General Contractor is responsible for assuring that all sub-contractors working on the project and their employees also comply with these regulations.
- B. Security Procedures:
 - 1. General Contractor's employees shall not enter the project site without appropriate badge. They may also be subject to inspection of their personal effects when entering or leaving the project site.
 - 2. For working outside the "regular hours" as defined in the contract, The General Contractor shall give 3 days notice to the Contracting Officer so that security arrangements can be provided for the employees. This notice is separate from any notices required for utility shutdown described later in this section.
 - 3. No photography of VA premises is allowed without written permission of the Contracting Officer.
 - 4. VA reserves the right to close down or shut down the project site and order General Contractor's employees off the premises in the event of a national emergency. The General Contractor may return to the site only with the written approval of the Contracting Officer.
- C. Guards:
 - 1. No Guards will be required on this project.
- D. Key Control:
 - 1. The General Contractor shall provide duplicate keys and lock combinations to the COR for the purpose of security inspections of every area of project including tool boxes and parked machines and take any emergency action.

2. The General Contractor shall turn over all permanent lock cylinders to the VA locksmith for permanent installation. See Section 08 71 00, DOOR HARDWARE and coordinate.

E. Document Control:

1. Before starting any work, the General Contractor/Sub Contractors shall submit an electronic security memorandum describing the approach to following goals and maintaining confidentiality of "sensitive information".
2. The General Contractor is responsible for safekeeping of all drawings, project manual and other project information. This information shall be shared only with those with a specific need to accomplish the project.
3. Certain documents, sketches, videos or photographs and drawings may be marked "Law Enforcement Sensitive" or "Sensitive Unclassified". Secure such information in separate containers and limit the access to only those who will need it for the project. Return the information to the Contracting Officer upon request.
4. These security documents shall not be removed or transmitted from the project site without the written approval of Contracting Officer.
5. All paper waste or electronic media such as CD's and diskettes shall be shredded and destroyed in a manner acceptable to the VA.
6. Notify Contracting Officer and Site Security Officer immediately when there is a loss or compromise of "sensitive information".
7. All electronic information shall be stored in specified location following VA standards and procedures using an Engineering Document Management Software (EDMS).
 - a. Security, access and maintenance of all project drawings, both scanned and electronic shall be performed and tracked through the EDMS system.
 - b. "Sensitive information" including drawings and other documents may be attached to e-mail provided all VA encryption procedures are followed.

F. Motor Vehicle Restrictions

1. Vehicle authorization request shall be required for any vehicle entering the site and such request shall be submitted 24 hours before the date and time of access. Access shall be restricted to picking up and dropping off materials and supplies.
2. Separate permits shall be issued for General Contractor and its employees for parking in designated areas only.

1.6 FIRE SAFETY

- A. Applicable Publications: Publications listed below form part of this Article to extent referenced. Publications are referenced in text by basic designations only.
1. American Society for Testing and Materials (ASTM):
 - E84-2009.....Surface Burning Characteristics of Building Materials
 2. National Fire Protection Association (NFPA):
 - 10-2010.....Standard for Portable Fire Extinguishers
 - 30-2008.....Flammable and Combustible Liquids Code
 - 51B-2009.....Standard for Fire Prevention During Welding, Cutting and Other Hot Work
 - 70-2011.....National Electrical Code
 - 241-2009.....Standard for Safeguarding Construction, Alteration, and Demolition Operations
 3. Occupational Safety and Health Administration (OSHA):
 - 29 CFR 1926.....Safety and Health Regulations for Construction
- B. Fire Safety Plan: Establish and maintain a fire protection program in accordance with 29 CFR 1926. Prior to start of work, prepare a plan detailing project-specific fire safety measures, including periodic status reports, and submit to COR for review for compliance with contract requirements in accordance with Section 01 33 23, SHOP DRAWINGS, PRODUCT DATA AND SAMPLES Prior to any worker for the Contractor or subcontractors beginning work, they shall undergo a safety briefing provided by the general contractor's competent person per OSHA requirements. This briefing shall include information on the construction limits, VAMC safety guidelines, means of egress, break areas, work hours, locations of restrooms, use of VAMC equipment, etc. Documentation shall be provided to the COR that individuals have undergone contractor's safety briefing.
- C. Site and Building Access: Maintain free and unobstructed access to facility emergency services and for fire, police and other emergency response forces in accordance with NFPA 241.
- D. Separate temporary facilities, such as trailers, storage sheds, and dumpsters, from existing buildings and new construction by distances in accordance with NFPA 241. For small facilities with less than 6 m (20 feet) exposing overall length, separate by 3m (10 feet).
- E. Temporary Construction Partitions:

1. Install and maintain temporary construction partitions to provide smoke-tight separations between construction areas and adjoining areas. Construct partitions of gypsum board or treated plywood (flame spread rating of 25 or less in accordance with ASTM E84) on both sides of fire retardant treated wood or metal steel studs. Extend the partitions through suspended ceilings to floor slab deck or roof. Seal joints and penetrations. At door openings, install Class C, ¾ hour fire/smoke rated doors with self-closing devices.
 2. Install temporary construction partitions as required to maintain integrity of existing exit stair enclosures, exit passageways, fire-rated enclosures of hazardous areas, horizontal exits, smoke barriers, vertical shafts and openings enclosures.
 3. Close openings in smoke barriers and fire-rated construction to maintain fire ratings. Seal penetrations with listed through-penetration firestop materials in accordance with Section 07 84 00, FIRESTOPPING.
- F. Temporary Heating and Electrical: Install, use and maintain installations in accordance with 29 CFR 1926, NFPA 241 and NFPA 70.
- G. Means of Egress: Do not block exiting for occupied buildings, including paths from exits to roads. Minimize disruptions and coordinate with COR.
- H. Egress Routes for Construction Workers: Maintain free and unobstructed egress. Inspect daily. Report findings and corrective actions weekly to COR.
- I. Fire Extinguishers: Provide and maintain extinguishers in construction areas and temporary storage areas in accordance with 29 CFR 1926, NFPA 241 and NFPA 10.
- J. Flammable and Combustible Liquids: Store, dispense and use liquids in accordance with 29 CFR 1926, NFPA 241 and NFPA 30.
- K. Standpipes: Install and extend standpipes up with each floor in accordance with 29 CFR 1926 and NFPA 241. Do not charge wet standpipes subject to freezing until weather protected.
- L. Sprinklers: Install, test and activate new automatic sprinklers prior to removing existing sprinklers.
- M. Existing Fire Protection: Do not impair automatic sprinklers, smoke and heat detection, and fire alarm systems, except for portions immediately under construction, and temporarily for connections. Provide fire watch for impairments more than 4 hours in a 24-hour period. Request interruptions in accordance with Article, OPERATIONS AND STORAGE AREAS, and coordinate with COR. All existing or temporary fire protection

systems (fire alarms, sprinklers) located in construction areas shall be tested as coordinated with the medical center. Parameters for the testing and results of any tests performed shall be recorded by the medical center and copies provided to the COR.

- N. Smoke Detectors: Prevent accidental operation. Remove temporary covers at end of work operations each day. Coordinate with COR.
- O. Hot Work: Perform and safeguard hot work operations in accordance with NFPA 241 and NFPA 51B. Coordinate with COR. Obtain permits from COR at least 48 hours in advance. Designate contractor's responsible project-site fire prevention program manager to permit hot work.
- P. Fire Hazard Prevention and Safety Inspections: Inspect entire construction areas weekly. Coordinate with, and report findings and corrective actions weekly to COR.
- Q. Smoking: Smoking is prohibited in and adjacent to construction areas inside existing buildings and additions under construction. In separate and detached buildings under construction, smoking is prohibited except in designated smoking rest areas.
- R. Dispose of waste and debris in accordance with NFPA 241. Remove from buildings daily.
- S. Perform other construction, alteration and demolition operations in accordance with 29 CFR 1926.
- T. If required, submit documentation to the COR that personnel have been trained in the fire safety aspects of working in areas with impaired structural or compartmentalization features.

1.7 OPERATIONS AND STORAGE AREAS

- A. The Contractor shall confine all operations (including storage of materials) on Government premises to areas authorized or approved by the Contracting Officer. The Contractor shall hold and save the Government, its officers and agents, free and harmless from liability of any nature occasioned by the Contractor's performance.
- B. Temporary buildings (e.g., storage sheds, shops, offices) and utilities may be erected by the Contractor only with the approval of the Contracting Officer and shall be built with labor and materials furnished by the Contractor without expense to the Government. The temporary buildings and utilities shall remain the property of the Contractor and shall be removed by the Contractor at its expense upon completion of the work. With the written consent of the Contracting Officer, the buildings and utilities may be abandoned and need not be removed.

- C. The Contractor shall, under regulations prescribed by the Contracting Officer, use only established roadways, or use temporary roadways constructed by the Contractor when and as authorized by the Contracting Officer. When materials are transported in prosecuting the work, vehicles shall not be loaded beyond the loading capacity recommended by the manufacturer of the vehicle or prescribed by any Federal, State, or local law or regulation. When it is necessary to cross curbs or sidewalks, the Contractor shall protect them from damage. The Contractor shall repair or pay for the repair of any damaged curbs, sidewalks, or roads.
- D. Working space and space available for storing materials shall be as determined by the COR.
- E. Workmen are subject to rules of Medical Center applicable to their conduct.
- F. Execute work so as to interfere as little as possible with normal functioning of Medical Center as a whole, including operations of utility services, fire protection systems and any existing equipment, and with work being done by others. Use of equipment and tools that transmit vibrations and noises through the building structure, are not permitted in buildings that are occupied, during construction, jointly by patients or medical personnel, and Contractor's personnel, except as permitted by COR where required by limited working space.
 - 1. Do not store materials and equipment in other than assigned areas.
 - 2. Schedule delivery of materials and equipment to immediate construction working areas within buildings in use by Department of Veterans Affairs in quantities sufficient for not more than two work days. Provide unobstructed access to Medical Center areas required to remain in operation.
 - 3. Where access by Medical Center personnel to vacated portions of buildings is not required, storage of Contractor's materials and equipment will be permitted subject to fire and safety requirements.
- G. Phasing: To insure such executions, Contractor shall furnish the COR with a schedule of approximate phasing dates on which the Contractor intends to accomplish work in each specific area of site, building or portion thereof. In addition, Contractor shall notify the COR two weeks in advance of the proposed date of starting work in each specific area of site, building or portion thereof. Arrange such phasing dates to insure accomplishment of this work in successive phases mutually agreeable to Medical Center Director and COR.

- H. All Buildings will be occupied during performance of work, and the existing hospital and all its Information Technology Systems shall be in full operation during the entire construction period.
- I. Construction Fence, as applicable to materials storage areas on site:
Before construction operations begin, Contractor shall provide a chain link construction fence, 2.1m (seven feet) minimum height, around the construction area indicated on the drawings. Provide gates as required for access with necessary hardware, including hasps and padlocks. Fasten fence fabric to terminal posts with tension bands and to line posts and top and bottom rails with tie wires spaced at maximum 375mm (15 inches). Bottom of fences shall extend to 25mm (one inch) above grade. Remove the fence when directed by COR.
- J. When building work areas are turned over to Contractor, Contractor shall accept entire responsibility therefore.
 - 1. Contractor shall maintain a minimum temperature of 4 degrees C (40 degrees F) at all times, except as otherwise specified.
 - 2. Contractor shall maintain in operating condition existing fire protection and alarm equipment. In connection with fire alarm equipment, Contractor shall make arrangements for pre-inspection of site with Fire Department or Company (Department of Veterans Affairs or municipal) whichever will be required to respond to an alarm from Contractor's employee or watchman.
- K. Utilities Services: Maintain existing utility services for Medical Center at all times. Provide temporary facilities, labor, materials, equipment, connections, and utilities to assure uninterrupted services. Where necessary to cut existing water, steam, gases, sewer or air pipes, or conduits, wires, cables, etc. of utility services or of fire protection systems and communications systems (including telephone), they shall be cut and capped at suitable places where shown; or, in absence of such indication, where directed by COR.
 - 1. No utility service such as water, gas, steam, sewers or electricity, or fire protection systems and communications systems may be interrupted without prior approval of COR. Electrical work shall be accomplished with all affected circuits or equipment de-energized. When an electrical outage cannot be accomplished, work on any energized circuits or equipment shall not commence without the Medical Center Director's prior knowledge and written approval.
 - 2. Contractor shall submit a request to interrupt any such services to COR, in writing, 48 hours in advance of proposed interruption.

- Request shall state reason, date, exact time of, and approximate duration of such interruption.
3. Contractor will be advised (in writing) of approval of request, or of which other date and/or time such interruption will cause least inconvenience to operations of Medical Center. Interruption time approved by Medical Center may occur at other than Contractor's normal working hours.
 4. Major interruptions of any system must be requested, in writing, at least 15 calendar days prior to the desired time and shall be performed as directed by the COR.
 5. In case of a contract construction emergency, service will be interrupted on approval of COR. Such approval will be confirmed in writing as soon as practical.
 6. Whenever it is required that a connection fee be paid to a public utility provider for new permanent service to the construction project, for such items as water, sewer, electricity, gas or steam, payment of such fee shall be the responsibility of the Government and not the Contractor.
- L. Abandoned Lines: All service lines such as wires, cables, conduits, ducts, pipes and the like, and their hangers or supports, which are to be abandoned but are not required to be entirely removed, shall be sealed, capped or plugged. The lines shall not be capped in finished areas, but shall be removed and sealed, capped or plugged in ceilings, within furred spaces, in unfinished areas, or within walls or partitions; so that they are completely behind the finished surfaces.
- M. To minimize interference of construction activities with flow of Medical Center traffic, comply with the following:
1. Keep roads, walks and entrances to grounds, to parking and to occupied areas of buildings clear of construction materials, debris and standing construction equipment and vehicles. Wherever excavation for new utility lines cross existing roads, at least one lane must be open to traffic at all times.
 2. Method and scheduling of required cutting, altering and removal of existing roads, walks and entrances must be approved by the COR.
- N. Coordinate the work for this contract with other construction operations as directed by COR. This includes the scheduling of traffic and the use of roadways, as specified in Article, USE OF ROADWAYS.
- O. Coordination of Construction with Cemetery Director: The burial activities at a National Cemetery shall take precedence over

construction activities. The Contractor must cooperate and coordinate with the Cemetery Director, through the COR, in arranging construction schedule to cause the least possible interference with cemetery activities in actual burial areas. Construction noise during the interment services shall not disturb the service. Trucks and workmen shall not pass through the service area during this period:

1. The Contractor is required to discontinue his work sufficiently in advance of Easter Sunday, Mother's Day, Father's Day, Memorial Day, Veteran's Day and/or Federal holidays, to permit him to clean up all areas of operation adjacent to existing burial plots before these dates.
2. Cleaning up shall include the removal of all equipment, tools, materials and debris and leaving the areas in a clean, neat condition.

1.8 ALTERATIONS

- A. Survey: Before any work is started, the Contractor shall make a thorough survey with the COR and a representative of VA Supply Service, of areas of buildings in which alterations occur and areas which are anticipated routes of access, and furnish a report, signed by both, to the Contracting Officer. This report shall list by rooms and spaces:
 1. Existing condition and types of resilient flooring, doors, windows, walls and other surfaces not required to be altered throughout affected areas of building.
 2. Existence and conditions of items such as plumbing fixtures and accessories, electrical fixtures, equipment, venetian blinds, shades, etc., required by drawings to be either reused or relocated, or both.
 3. Shall note any discrepancies between drawings and existing conditions at site.
 4. Shall designate areas for working space, materials storage and routes of access to areas within buildings where alterations occur and which have been agreed upon by Contractor and COR.
- B. Any items required by drawings to be either reused or relocated or both, found during this survey to be nonexistent, or in opinion of COR, to be in such condition that their use is impossible or impractical, shall be furnished and/or replaced by Contractor with new items in accordance with specifications which will be furnished by Government. Provided the contract work is changed by reason of this subparagraph B, the contract will be modified accordingly, under provisions of clause entitled

"DIFFERING SITE CONDITIONS" (FAR 52.236-2) and "CHANGES" (FAR 52.243-4 and VAAR 852.236-88).

- C. Re-Survey: Thirty days before expected partial or final inspection date, the Contractor and COR together shall make a thorough re-survey of the areas of buildings involved. They shall furnish a report on conditions then existing, of resilient flooring, doors, windows, walls and other surfaces as compared with conditions of same as noted in first condition survey report:
 - 1. Re-survey report shall also list any damage caused by Contractor to such flooring and other surfaces, despite protection measures; and, will form basis for determining extent of repair work required of Contractor to restore damage caused by Contractor's workmen in executing work of this contract.
- D. Protection: Provide the following protective measures:
 - 1. Wherever existing roof surfaces are disturbed they shall be protected against water infiltration. In case of leaks, they shall be repaired immediately upon discovery.
 - 2. Temporary protection against damage for portions of existing structures and grounds where work is to be done, materials handled and equipment moved and/or relocated.
 - 3. Protection of interior of existing structures at all times, from damage, dust and weather inclemency. Wherever work is performed, floor surfaces that are to remain in place shall be adequately protected prior to starting work, and this protection shall be maintained intact until all work in the area is completed.

1.9 INFECTION PREVENTION MEASURES

- A. Implement the requirements of VAMC's Infection Control Risk Assessment (ICRA) team. ICRA Group may monitor dust in the vicinity of the construction work and require the Contractor to take corrective action immediately if the safe levels are exceeded.
- B. Establish and maintain a dust control program as part of the contractor's infection preventive measures in accordance with the guidelines provided by ICRA Group as specified herein. Prior to start of work, prepare a plan detailing project-specific dust protection measures, including periodic status reports, and submit to COR for review for compliance with contract requirements in accordance with Section 01 33 23, SHOP DRAWINGS, PRODUCT DATA AND SAMPLES.

1. All personnel involved in the construction or renovation activity shall be educated and trained in infection prevention measures established by the medical center.
- C. Medical center Infection Control personnel shall monitor for airborne disease (e.g. aspergillosis) as appropriate during construction. A baseline of conditions may be established by the medical center prior to the start of work and periodically during the construction stage to determine impact of construction activities on indoor air quality. In addition:
1. The COR and VAMC Infection Control personnel shall review pressure differential monitoring documentation to verify that pressure differentials in the construction zone and in the patient-care rooms are appropriate for their settings. The requirement for negative air pressure in the construction zone shall depend on the location and type of activity. Upon notification, the contractor shall implement corrective measures to restore proper pressure differentials as needed.
 2. In case of any problem, the medical center, along with assistance from the contractor, shall conduct an environmental assessment to find and eliminate the source.
- D. In general, following preventive measures shall be adopted during construction to keep down dust and prevent mold.
1. Dampen debris to keep down dust and provide temporary construction partitions in existing structures where directed by COR. Blank off ducts and diffusers to prevent circulation of dust into occupied areas during construction.
 2. Do not perform dust producing tasks within occupied areas without the approval of the COR. For construction in any areas that will remain jointly occupied by the medical Center and Contractor's workers, the Contractor shall:
 - a. Provide dust proof fire-rated temporary drywall construction barriers to completely separate construction from the operational areas of the hospital in order to contain dirt debris and dust. Barriers shall be sealed and made presentable on hospital occupied side. Install a self-closing rated door in a metal frame, commensurate with the partition, to allow worker access. Maintain negative air at all times. A fire retardant polystyrene, 6-mil thick or greater plastic barrier meeting local fire codes may be

used where dust control is the only hazard, and an agreement is reached with the COR and Medical Center.

- b. HEPA filtration is required where the exhaust dust may reenter the breathing zone. Contractor shall verify that construction exhaust to exterior is not reintroduced to the medical center through intake vents, or building openings. Install HEPA (High Efficiency Particulate Accumulator) filter vacuum system rated at 95% capture of 0.3 microns including pollen, mold spores and dust particles. Insure continuous negative air pressures occurring within the work area. HEPA filters should have ASHRAE 85 or other prefilter to extend the useful life of the HEPA. Provide both primary and secondary filtrations units. Exhaust hoses shall be heavy duty, flexible steel reinforced and exhausted so that dust is not reintroduced to the medical center.
- c. Adhesive Walk-off/Carpet Walk-off Mats, minimum 600mm x 900mm (24" x 36"), shall be used at all interior transitions from the construction area to occupied medical center area. These mats shall be changed as often as required to maintain clean work areas directly outside construction area at all times.
- d. Vacuum and wet mop all transition areas from construction to the occupied medical center at the end of each workday. Vacuum shall utilize HEPA filtration. Maintain surrounding area frequently. Remove debris as they are created. Transport these outside the construction area in containers with tightly fitting lids.
- e. The contractor shall not haul debris through patient-care areas without prior approval of the COR and the Medical Center. When, approved, debris shall be hauled in enclosed dust proof containers or wrapped in plastic and sealed with duct tape. No sharp objects should be allowed to cut through the plastic. Wipe down the exterior of the containers with a damp rag to remove dust. All equipment, tools, material, etc. transported through occupied areas shall be made free from dust and moisture by vacuuming and wipe down.
- f. Using a HEPA vacuum, clean inside the barrier and vacuum ceiling tile prior to replacement. Any ceiling access panels opened for investigation beyond sealed areas shall be sealed immediately when unattended.
- g. There shall be no standing water during construction. This includes water in equipment drip pans and open containers within

the construction areas. All accidental spills must be cleaned up and dried within 12 hours. Remove and dispose of porous materials that remain damp for more than 72 hours.

h. At completion, remove construction barriers and ceiling protection carefully, outside of normal work hours. Vacuum and clean all surfaces free of dust after the removal.

E. Final Cleanup:

1. Upon completion of project, or as work progresses, remove all construction debris from above ceiling, vertical shafts and utility chases that have been part of the construction.
2. Perform HEPA vacuum cleaning of all surfaces in the construction area. This includes walls, ceilings, cabinets, furniture (built-in or free standing), partitions, flooring, etc.
3. All new air ducts shall be cleaned prior to final inspection.

1.10 DISPOSAL AND RETENTION

A. Materials and equipment accruing from work removed and from demolition of buildings or structures, or parts thereof, shall be disposed of as follows:

1. Reserved items which are to remain property of the Government are noted on drawings or in specifications as items to be stored. Items that remain property of the Government shall be removed or dislodged from present locations in such a manner as to prevent damage which would be detrimental to re-installation and reuse. Store such items where directed by COR.
2. Items not reserved shall become property of the Contractor and be removed by Contractor from Medical Center.
3. Items of portable equipment and furnishings located in rooms and spaces in which work is to be done under this contract shall remain the property of the Government. When rooms and spaces are vacated by the Department of Veterans Affairs during the alteration period, such items which are NOT required by drawings and specifications to be either relocated or reused will be removed by the Government in advance of work to avoid interfering with Contractor's operation.

1.11 PROTECTION OF EXISTING VEGETATION, STRUCTURES, EQUIPMENT, UTILITIES, AND IMPROVEMENTS

A. The Contractor shall preserve and protect all structures, equipment, and vegetation (such as trees, shrubs, and grass) on or adjacent to the work site, which are not to be removed and which do not unreasonably interfere with the work required under this contract. The Contractor

shall only remove trees when specifically authorized to do so, and shall avoid damaging vegetation that will remain in place. If any limbs or branches of trees are broken during contract performance, or by the careless operation of equipment, or by workmen, the Contractor shall trim those limbs or branches with a clean cut and paint the cut with a tree-pruning compound as directed by the Contracting Officer.

- B. The Contractor shall protect from damage all existing improvements and utilities at or near the work site and on adjacent property of a third party, the locations of which are made known to or should be known by the Contractor. The Contractor shall repair any damage to those facilities, including those that are the property of a third party, resulting from failure to comply with the requirements of this contract or failure to exercise reasonable care in performing the work. If the Contractor fails or refuses to repair the damage promptly, the Contracting Officer may have the necessary work performed and charge the cost to the Contractor.

(FAR 52.236-9)

- C. Refer to Section 01 57 19, TEMPORARY ENVIRONMENTAL CONTROLS, for additional requirements on protecting vegetation, soils and the environment. Refer to Articles, "Alterations", "Restoration", and "Operations and Storage Areas" for additional instructions concerning repair of damage to structures and site improvements.
- D. Refer to FAR clause 52.236-7, "Permits and Responsibilities," which is included in General Conditions. A National Pollutant Discharge Elimination System (NPDES) permit is required for this project. The Contractor is considered an "operator" under the permit and has extensive responsibility for compliance with permit requirements. VA will make the permit application available at the (appropriate medical center) office. The apparent low bidder, contractor and affected subcontractors shall furnish all information and certifications that are required to comply with the permit process and permit requirements. Many of the permit requirements will be satisfied by completing construction as shown and specified. Some requirements involve the Contractor's method of operations and operations planning and the Contractor is responsible for employing best management practices. The affected activities often include, but are not limited to the following:
- Designating areas for equipment maintenance and repair;
 - Providing waste receptacles at convenient locations and provide regular collection of wastes;

- Locating equipment wash-down areas on site, and provide appropriate control of wash-waters;
- Providing protected storage areas for chemicals, paints, solvents, fertilizers, and other potentially toxic materials; and
- Providing adequately maintained sanitary facilities.

1.12 RESTORATION

- A. Remove, cut, alter, replace, patch and repair existing work as necessary to install new work. Except as otherwise shown or specified, do not cut, alter or remove any structural work, and do not disturb any ducts, plumbing, steam, gas, or electric work without approval of the COR. Existing work to be altered or extended and that is found to be defective in any way, shall be reported to the COR before it is disturbed. Materials and workmanship used in restoring work, shall conform in type and quality to that of original existing construction, except as otherwise shown or specified.
- B. Upon completion of contract, deliver work complete and undamaged. Existing work (walls, ceilings, partitions, floors, mechanical and electrical work, lawns, paving, roads, walks, etc.) disturbed or removed as a result of performing required new work, shall be patched, repaired, reinstalled, or replaced with new work, and refinished and left in as good condition as existed before commencing work.
- C. At Contractor's own expense, Contractor shall immediately restore to service and repair any damage caused by Contractor's workmen to existing piping and conduits, wires, cables, etc., of utility services or of fire protection systems and communications systems (including telephone) which are indicated on drawings and which are not scheduled for discontinuance or abandonment.
- D. Expense of repairs to such utilities and systems not shown on drawings or locations of which are unknown will be covered by adjustment to contract time and price in accordance with clause entitled "CHANGES" (FAR 52.243-4 and VAAR 852.236-88) and "DIFFERING SITE CONDITIONS" (FAR 52.236-2).

1.13 PHYSICAL DATA

- A. Data and information furnished or referred to below is for the Contractor's information. The Government shall not be responsible for any interpretation of or conclusion drawn from the data or information by the Contractor.
 1. The indications of physical conditions on the drawings and in the specifications are the result of site investigations by the A/E of

Record.

- B. Subsurface conditions have been developed by core borings and test pits. Logs of subsurface exploration are shown diagrammatically on drawings.
- C. A copy of the soil report will be made available for inspection by bidders upon request to the Engineering Officer at the VA Medical Center, and shall be considered part of the contract documents.
- D. Government does not guarantee that other materials will not be encountered nor that proportions, conditions or character of several materials will not vary from those indicated by explorations. Bidders are expected to examine site of work and logs of borings; and, after investigation, decide for themselves character of materials and make their bids accordingly. Upon proper application to Department of Veterans Affairs, bidders will be permitted to make subsurface explorations of their own at site.

1.14 PROFESSIONAL SURVEYING SERVICES

- A. A registered professional land surveyor or registered civil engineer whose services are retained and paid for by the Contractor shall perform services specified herein and in other specification sections. The Contractor shall certify that the land surveyor or civil engineer is not one who is a regular employee of the Contractor, and that the land surveyor or civil engineer has no financial interest in this contract.

1.15 LAYOUT OF WORK

- A. The Contractor shall lay out the work from Government established base lines and bench marks, indicated on the drawings, and shall be responsible for all measurements in connection with the layout. The Contractor shall furnish, at Contractor's own expense, all stakes, templates, platforms, equipment, tools, materials, and labor required to lay out any part of the work. The Contractor shall be responsible for executing the work to the lines and grades that may be established or indicated by the Contracting Officer. The Contractor shall also be responsible for maintaining and preserving all stakes and other marks established by the Contracting Officer until authorized to remove them. If such marks are destroyed by the Contractor or through Contractor's negligence before their removal is authorized, the Contracting Officer may replace them and deduct the expense of the replacement from any amounts due or to become due to the Contractor.

(FAR 52.236-17)

- B. Establish and plainly mark center lines for each building and/or addition to each existing building, and such other lines and grades that are reasonably necessary to properly assure that location, orientation, and elevations established for each such structure and/or addition, are in accordance with lines and elevations shown on contract drawings.
- C. Following completion of general mass excavation and before any other permanent work is performed, establish and plainly mark (through use of appropriate batter boards or other means) sufficient additional survey control points or system of points as may be necessary to assure proper alignment, orientation, and grade of all major features of work. Survey shall include, but not be limited to, location of lines and grades of footings, exterior walls, center lines of columns in both directions, major utilities and elevations of floor slabs:
 - 1. Such additional survey control points or system of points thus established shall be checked and certified by a registered land surveyor or registered civil engineer. Furnish such certification to the COR before any work (such as footings, floor slabs, columns, walls, utilities and other major controlling features) is placed.
- D. During progress of work, and particularly as work progresses from floor to floor, Contractor shall have line grades and plumbness of all major form work checked and certified by a registered land surveyor or registered civil engineer as meeting requirements of contract drawings. Furnish such certification to the COR before any major items of concrete work are placed. In addition, Contractor shall also furnish to the COR certificates from a registered land surveyor or registered civil engineer that the following work is complete in every respect as required by contract drawings.
 - 1. Lines of each building and/or addition.
 - 2. Elevations of bottoms of footings and tops of floors of each building and/or addition.
 - 3. Lines and elevations of sewers and of all outside distribution systems.
- E. Whenever changes from contract drawings are made in line or grading requiring certificates, record such changes on a reproducible drawing bearing the registered land surveyor or registered civil engineer seal, and forward these drawings upon completion of work to COR.
- F. Upon completion of the work, the Contractor shall furnish the COR, reproducible drawings at the scale of the contract drawings, showing the

finished grade on the grid developed for constructing the work, including burial monuments and fifty foot stationing along new road centerlines. These drawings shall bear the seal of the registered land surveyor or registered civil engineer.

- G. The Contractor shall perform the surveying and layout work of this and other articles and specifications in accordance with the provisions of Article "Professional Surveying Services".

1.16 AS-BUILT DRAWINGS

- A. The contractor shall maintain two full size sets of as-built drawings which will be kept current during construction of the project, to include all contract changes, modifications and clarifications.
- B. All variations shall be shown in the same general detail as used in the contract drawings. To insure compliance, as-built drawings shall be made available for the COR's review, as often as requested.
- C. Contractor shall deliver two approved completed sets of as-built drawings to the COR within 15 calendar days after each completed phase and after the acceptance of the project by the COR.
- D. Paragraphs A, B, & C shall also apply to all shop drawings.

1.17 USE OF ROADWAYS

- A. For hauling, use only established public roads and roads on Medical Center property and, when authorized by the COR, such temporary roads which are necessary in the performance of contract work. Temporary roads shall be constructed by the Contractor at Contractor's expense. When necessary to cross curbing, sidewalks, or similar construction, they must be protected by well-constructed bridges.
- B. When new permanent roads are to be a part of this contract, Contractor may construct them immediately for use to facilitate building operations. These roads may be used by all who have business thereon within zone of building operations.
- C. When certain buildings (or parts of certain buildings) are required to be completed in advance of general date of completion, all roads leading thereto must be completed and available for use at time set for completion of such buildings or parts thereof.

1.18 COR'S FIELD OFFICE

- A. This project DOES NOT require a COR Field Office.

1.19 TEMPORARY USE OF MECHANICAL AND ELECTRICAL EQUIPMENT

- A. Use of new installed mechanical and electrical equipment to provide heat, ventilation, plumbing, light and power will be permitted subject to compliance with the following provisions:
1. Permission to use each unit or system must be given by COR. If the equipment is not installed and maintained in accordance with the following provisions, the COR will withdraw permission for use of the equipment.
 2. Electrical installations used by the equipment shall be completed in accordance with the drawings and specifications to prevent damage to the equipment and the electrical systems, i.e. transformers, relays, circuit breakers, fuses, conductors, motor controllers and their overload elements shall be properly sized, coordinated and adjusted. Voltage supplied to each item of equipment shall be verified to be correct and it shall be determined that motors are not overloaded. The electrical equipment shall be thoroughly cleaned before using it and again immediately before final inspection including vacuum cleaning and wiping clean interior and exterior surfaces.
 3. Units shall be properly lubricated, balanced, and aligned. Vibrations must be eliminated.
 4. Automatic temperature control systems for preheat coils shall function properly and all safety controls shall function to prevent coil freeze-up damage.
 5. The air filtering system utilized shall be that which is designed for the system when complete, and all filter elements shall be replaced at completion of construction and prior to testing and balancing of system.
 6. All components of heat production and distribution system, metering equipment, condensate returns, and other auxiliary facilities used in temporary service shall be cleaned prior to use; maintained to prevent corrosion internally and externally during use; and cleaned, maintained and inspected prior to acceptance by the Government.
- B. Prior to final inspection, the equipment or parts used which show wear and tear beyond normal, shall be replaced with identical replacements, at no additional cost to the Government.
- C. This paragraph shall not reduce the requirements of the mechanical and electrical specifications sections.

1.20 TEMPORARY USE OF EXISTING ELEVATORS

- A. Contractor will not be allowed the use of existing elevators. Outside type hoist shall be used by Contractor for transporting materials and equipment.

1.21 TEMPORARY USE OF NEW ELEVATORS

- A. The project DOES NOT have NEW Elevators.

1.22 TEMPORARY TOILETS

- A. Provide where directed, (for use of all Contractor's workmen) ample temporary sanitary toilet accommodations with suitable sewer and water connections; or, when approved by COR, provide suitable dry closets where directed. Keep such places clean and free from flies, and all connections and appliances connected therewith are to be removed prior to completion of contract, and premises left perfectly clean.

1.23 AVAILABILITY AND USE OF UTILITY SERVICES

- A. The Government shall make all reasonably required amounts of utilities available to the Contractor from existing outlets and supplies, as specified in the contract. The amount to be paid by the Contractor for chargeable electrical services shall be the prevailing rates charged to the Government. The Contractor shall carefully conserve any utilities furnished without charge.
- B. The Contractor, at Contractor's expense and in a workmanlike manner satisfactory to the Contracting Officer, shall install and maintain all necessary temporary connections and distribution lines, and all meters required to measure the amount of electricity used for the purpose of determining charges. Before final acceptance of the work by the Government, the Contractor shall remove all the temporary connections, distribution lines, meters, and associated paraphernalia.
- C. Contractor shall install meters at Contractor's expense and furnish the Medical Center a monthly record of the Contractor's usage of electricity as hereinafter specified.
- D. Heat: Furnish temporary heat necessary to prevent injury to work and materials through dampness and cold. Use of open salamanders or any temporary heating devices which may be fire hazards or may smoke and damage finished work, will not be permitted. Maintain minimum temperatures as specified for various materials.
- E. Electricity (for Construction and Testing): Furnish all temporary electric services.

1. Obtain electricity by connecting to the Medical Center electrical distribution system. The Contractor shall meter and pay for electricity required for electric cranes and hoisting devices, electrical welding devices and any electrical heating devices providing temporary heat. Electricity for all other uses is available at no cost to the Contractor.

F. Water (for Construction and Testing): Furnish temporary water service.

1. Obtain water by connecting to the Medical Center water distribution system. Provide reduced pressure backflow preventer at each connection. Water is available at no cost to the Contractor.
2. Maintain connections, pipe, fittings and fixtures and conserve water-use so none is wasted. Failure to stop leakage or other wastes will be cause for revocation (at COR's discretion) of use of water from Medical Center's system.

G. Steam: Furnish steam system for testing required in various sections of specifications.

1. Obtain steam for testing by connecting to the Medical steam distribution system. Steam is available at no cost to the Contractor.
2. Maintain connections, pipe, fittings and fixtures and conserve steam-use so none is wasted. Failure to stop leakage or other waste will be cause for revocation (at COR's discretion), of use of steam from the Medical Center's system.

H. Fuel: Natural and LP gas and burner fuel oil required for boiler cleaning, normal initial boiler-burner setup and adjusting, and for performing the specified boiler tests will be furnished by the Government. Fuel required for prolonged boiler-burner setup, adjustments, or modifications due to improper design or operation of boiler, burner, or control devices shall be furnished by the Contractor at Contractor's expense.

1.24 NEW TELEPHONE EQUIPMENT

- A. The contractor shall coordinate with the work of installation of telephone equipment by others. This work shall be completed before the building is turned over to VA.

1.25 TESTS

- A. Pre-test mechanical and electrical equipment and systems and make corrections required for proper operation of such systems before requesting final tests. Final test will not be conducted unless pre-tested.

- B. Conduct final tests required in various sections of specifications in presence of an authorized representative of the Contracting Officer. Contractor shall furnish all labor, materials, equipment, instruments, and forms, to conduct and record such tests.
- C. Mechanical and electrical systems shall be balanced, controlled and coordinated. A system is defined as the entire complex which must be coordinated to work together during normal operation to produce results for which the system is designed. For example, air conditioning supply air is only one part of entire system which provides comfort conditions for a building. Other related components are return air, exhaust air, steam, chilled water, refrigerant, hot water, controls and electricity, etc. Another example of a complex which involves several components of different disciplines is a boiler installation. Efficient and acceptable boiler operation depends upon the coordination and proper operation of fuel, combustion air, controls, steam, feedwater, condensate and other related components.
- D. All related components as defined above shall be functioning when any system component is tested. Tests shall be completed within a reasonably short period of time during which operating and environmental conditions remain reasonably constant.
- E. Individual test result of any component, where required, will only be accepted when submitted with the test results of related components and of the entire system.

1.26 INSTRUCTIONS

- A. Contractor shall furnish Maintenance and Operating manuals and verbal instructions when required by the various sections of the specifications and as hereinafter specified.
- B. Manuals: Maintenance and operating manuals (four copies each) for each separate piece of equipment shall be delivered to the COR coincidental with the delivery of the equipment to the job site. Manuals shall be complete, detailed guides for the maintenance and operation of equipment. They shall include complete information necessary for starting, adjusting, maintaining in continuous operation for long periods of time and dismantling and reassembling of the complete units and sub-assembly components. Manuals shall include an index covering all component parts clearly cross-referenced to diagrams and illustrations. Illustrations shall include "exploded" views showing and identifying each separate item. Emphasis shall be placed on the use of special tools and instruments. The function of each piece of equipment, component,

accessory and control shall be clearly and thoroughly explained. All necessary precautions for the operation of the equipment and the reason for each precaution shall be clearly set forth. Manuals must reference the exact model, style and size of the piece of equipment and system being furnished. Manuals referencing equipment similar to but of a different model, style, and size than that furnished will not be accepted.

- C. Instructions: Contractor shall provide qualified, factory-trained manufacturers' representatives to give detailed instructions to assigned Department of Veterans Affairs personnel in the operation and complete maintenance for each piece of equipment. All such training will be at the job site. These requirements are more specifically detailed in the various technical sections. Instructions for different items of equipment that are component parts of a complete system, shall be given in an integrated, progressive manner. All instructors for every piece of component equipment in a system shall be available until instructions for all items included in the system have been completed. This is to assure proper instruction in the operation of inter-related systems. All instruction periods shall be at such times as scheduled by the COR and shall be considered concluded only when the COR is satisfied in regard to complete and thorough coverage. The Department of Veterans Affairs reserves the right to request the removal of, and substitution for, any instructor who, in the opinion of the COR, does not demonstrate sufficient qualifications in accordance with requirements for instructors above.

1.27 GOVERNMENT-FURNISHED PROPERTY

- A. The Government shall deliver to the Contractor, the Government-furnished property shown on the drawings.
- B. Equipment furnished by Government to be installed by Contractor will be furnished to Contractor at the Medical Center.
- C. Contractor shall be prepared to receive this equipment from Government and store or place such equipment not less than 90 days before Completion Date of project.
- D. Notify Contracting Officer in writing, 60 days in advance, of date on which Contractor will be prepared to receive equipment furnished by Government. Arrangements will then be made by the Government for delivery of equipment.
 - 1. Immediately upon delivery of equipment, Contractor shall arrange for a joint inspection thereof with a representative of the Government.

At such time the Contractor shall acknowledge receipt of equipment described, make notations, and immediately furnish the Government representative with a written statement as to its condition or shortages.

2. Contractor thereafter is responsible for such equipment until such time as acceptance of contract work is made by the Government.
- E. Equipment furnished by the Government will be delivered in a partially assembled (knock down) condition in accordance with existing standard commercial practices, complete with all fittings, fastenings, and appliances necessary for connections to respective services installed under contract. All fittings and appliances (i.e., couplings, ells, tees, nipples, piping, conduits, cables, and the like) necessary to make the connection between the Government furnished equipment item and the utility stub-up shall be furnished and installed by the contractor at no additional cost to the Government.
- F. Completely assemble and install the Government furnished equipment in place ready for proper operation in accordance with specifications and drawings.
- G. Furnish supervision of installation of equipment at construction site by qualified factory trained technicians regularly employed by the equipment manufacturer.

1.28 RELOCATED EQUIPMENT ITEMS

- A. Contractor shall disconnect, dismantle as necessary, remove and reinstall in new location, all existing equipment and items indicated by symbol "R" or otherwise shown to be relocated by the Contractor.
- B. Perform relocation of such equipment or items at such times and in such a manner as directed by the COR.
- C. Suitably cap existing service lines, such as steam, condensate return, water, drain, gas, air, vacuum and/or electrical, whenever such lines are disconnected from equipment to be relocated. Remove abandoned lines in finished areas and cap as specified herein before under paragraph "Abandoned Lines".
- D. Provide all mechanical and electrical service connections, fittings, fastenings and any other materials necessary for assembly and installation of relocated equipment; and leave such equipment in proper operating condition.
- E. Contractor shall employ services of an installation engineer, who is an authorized representative of the manufacturer of this equipment to

supervise assembly and installation of existing equipment, required to be relocated.

- F. All service lines such as noted above for relocated equipment shall be in place at point of relocation ready for use before any existing equipment is disconnected. Make relocated existing equipment ready for operation or use immediately after reinstallation.

1.29 SAFETY SIGN

- A. Provide a Safety Sign where directed by COR. Face of sign shall be 19 mm (3/4 inch) thick exterior grade plywood. Provide two 100 mm by 100 mm (four by four inch) posts extending full height of sign and 900 mm (three feet) into ground. Set bottom of sign level at 1200 mm (four feet) above ground.
- B. Paint all surfaces of Safety Sign and posts with one prime coat and two coats of white gloss paint. Letters and design shall be painted with gloss paint of colors noted.
- C. Maintain sign and remove it when directed by COR.
- D. Standard Detail Drawing Number SD10000-02(Found on VA TIL) of safety sign showing required legend and other characteristics of sign is attached hereto and is made a part of this specification.
- E. Post the number of accident free days on a daily basis.

1.30 PHOTOGRAPHIC DOCUMENTATION - NOT REQUIRED.

1.31 FINAL ELEVATION DIGITAL IMAGES - NOT REQUIRED.

1.32 HISTORIC PRESERVATION

- A. Where the Contractor or any of the Contractor's employees, prior to, or during the construction work, are advised of or discover any possible archeological, historical and/or cultural resources, the Contractor shall immediately notify the COR verbally, and then with a written follow up.

- - - E N D - - -