

EXISTING DUCT TO REMAIN



TERMINAL UNIT WITH REHEAT COIL



FLOW SWITCH

SENSOR WITH AVERAGING ELEMENT TO TRANSMIT  
TEMPERATURE TO EMCS

1. ALL PIPING AND DUCTS IN FINISHED ROOMS OR SPACES SHALL BE CONCEALED IN A FURRED CHASE OR ABOVE THE HARD SUSPENDED CEILING.
2. THE FIRST FIGURE OF DUCT SIZE INDICATES DIMENSION OF FACE SHOWN OR INDICATED. DUCT SIZES ARE NET INSIDE DIMENSIONS.
3. ACCESS PANELS IN HARD SUSPENDED CEILINGS ARE REQUIRED FOR ALL VALVES, TRAPS, DAMPERS, CLEANOUTS, CONTROLS, ETC. ACCESS PANELS SHALL BE FURNISHED AND INSTALLED UNDER THE ARCHITECTURAL SPECIFICATIONS.
4. TOTAL STATIC PRESSURE NOTED IN THE SCHEDULES INCLUDES DUCT SYSTEM, TERMINAL UNITS, FILTERS, COILS, ETC.
5. FOR TYPICAL STEAM AND WATER PIPING CONNECTIONS TO EQUIPMENT, SEE STANDARD EQUIPMENT DETAILS.
6. DIFFUSER, REGISTER AND GRILLE SIZES SHOWN ON FLOOR PLANS ARE NECK SIZES.
7. WATER PIPE CONNECTIONS TO AIR HEATING AND COOLING COILS SHALL BE MADE TO PROVIDE COUNTER FLOW BETWEEN WATER AND AIR.
8. WALL TYPE EXHAUST REGISTERS NOTED AS "BR" ON DRAWINGS ARE TO BE INSTALLED WITH BOTTOM ELEVATION OF REGISTER AT 7" [175mm] ABOVE FINISHED FLOOR.
9. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF CEILING DIFFUSERS, REGISTERS, AND GRILLES.
10. SEISMIC PROVISIONS REQUIRED – SEE SPECIFICATIONS.

ALL PRESSURES LISTED ARE GAGE PRESSURE UNLESS OTHERWISE NOTED

The diagram shows a label with the text "26-TU-1-1" inside a hexagonal border. Four lines point from the label to descriptive text on the right:

- Line 1 points to "BUILDING NO. WHERE EQUIPMENT IS LOCATED"
- Line 2 points to "ITEM (TERMINAL UNIT SHOWN)"
- Line 3 points to "ITEM NUMBER (TERMINAL UNIT NO. 1)"
- Line 4 points to "SERVED BY AIR HANDLER UNIT NO. 1"

[illegible]

**Hernandez Consulting**  
ALBERT ARCHITECTURE



**JBHM**  
ARCHITECTS, P.A.

**Allen & Hoshall**  
engineering since 1915

[illegible]

|                  |  |
|------------------|--|
| Drawing<br>Title | MECHANICAL – LEGEND<br>AND GENERAL NOTES |
|------------------|--|

|                           |
|---------------------------|
| Approved Service Engineer |
| Approved Service Director |

|               |  |
|---------------|--|
| Project Title | Southeast VA Health Care<br>System<br>(SLVHCS)<br>A&E Design Urgent Care |
|---------------|--|

|   |             |           |
|---|-------------|-----------|
| Building Number                                     | Checked WLP | Drawn WLP |
| Location<br>1601 Perdido Street, New Orleans,<br>LA |             |           |

|             |                  |
|-------------|------------------|
| Date        | January 18, 2013 |
| Project No. | VA256-C-0231     |
| DRAWING NO. | M001             |
|             | Dep. 1 Of 1      |



Department of  
Veterans Affairs