

DEMO EXIST 2-1/2" HWS&R AS SHOWN INCLUDING RISE THRU ROOF.

EXIST 4" CHWS&R PIPING INSULATION IS SATURATED IN BREEZEWAY FROM REPORTED ROOF LEAK. DEMO EXIST INSULATION ONLY IN BREEZEWAY AND VERIFY PIPING INTEGRITY. IF LEAKS ARE PRESENT IN PIPING NOTIFY OWNER/ARCHITECT PRIOR TO PROCEEDING.

NOTIFY OWNER/ARCHITECT IF SATURATED INSULATION CONTINUES INTO UNOCCUPIED AREA.

DEMO EXIST 30x18 SA & RA DUCTWORK AS SHOWN INCLUDING RISE TO UNIT ON ROOF ABOVE.

1 FIRST FLOOR DEMOLITION PLAN - MECHANICAL  
1/8"=1'-0"

**Hernandez Consulting**  
ALBERT ARCHITECTURE



**Allen&Hoshall**  
engineering since 1915

Approved:	Signature
Title	

Drawing Title	MECHANICAL - FIRST FLOOR DEMO PLAN
Approved Service Engineer	
Approved Service Director	

Project Title	Southeast VA Health Care System (SLVHCS) A&E Design Urgent Care
Building Number	
Location	1601 Perdido Street, New Orleans, LA

Date	January 18, 2013
Project No.	VA256-C-0231
PROVING NO.	MD101
Dep.	1 OF 1



Department of Veterans Affairs

