GENERAL NOTES:

1. CONTRACTOR SHALL PROPERLY DISPOSE OF DEMOLISHED ITEMS OFF SITE.

KEYED NOTES:

1. EXISTING ELEVATOR FUSED DISCONNECT SWITCH TO REMAIN (TYPICAL FOR 2).
2. REMOVE EXISTING SUMP PUMP IN ELEVATOR PIT. PUMP PLUGGED INTO RECEPTACLE.
3. REMOVE EXISTING PIT RECEPTACLE. OUTLET BOX AND "L2B" BRANCH CIRCUIT TO REMAIN.
4. DISCONNECT FAN COIL UNITS. REMOVE ASSOCIATED DISCONNECT SWITCH AND BRANCH CIRCUIT CONDUIT AND CONDUCTORS BACK TO SOURCE PANEL. REVISE PANELBOARD DIRECTORY TO INDICATE "SPARE" CIRCUIT. FAN COIL UNITS ARE LOCATED OVER ELEVATOR CONTROLLER AND TRANSFORMER. SEE MD101 FOR EXACT LOCATION.
5. DISCONNECT AND REMOVE EXISTING ISOLATION TRANSFORMER AND FILTER.
6. DISCONNECT AND REMOVE EXISTING ELEVATOR MOTOR.
7. EXISTING FIRE ALARM CONTROL RELAYS TO REMAIN. (TYP. 4)
8. REMOVE BRANCH CIRCUIT CONDUIT AND CONDUCTORS BACK TO SOURCE PANELBOARD. REVISE PANELBOARD DIRECTORY TO INDICATE "SPARE" CIRCUIT.
9. DISCONNECT AND REMOVE EXISTING ELEVATOR CONTROLLER.
10. RELOCATE EXISTING FIRE ALARM SMOKE DETECTOR TO BELOW NEW SUSPENDED CEILING. REWORK CONDUIT AND CONDUCTORS AS REQUIRED.
11. REMOVE ELEVATOR MACHINE ROOM LIGHT FIXTURES AND LIGHT SWITCH.
12. EXISTING TELEPHONE CABINET TO REMAIN. REMOVE TELEPHONE LINE CABLE CONNECTION BETWEEN CABINET AND EACH ELEVATOR CONTROLLER.



1 / ED101 GROUND FLOOR DEMOLITION PLAN
SCALE: 1/4" = 1'-0"



READY TO ADVERTISE SUBMITTAL

Revisions:	Date

CONSULTANTS:

ARCHITECT/ENGINEERS:

POND
Architects • Engineers • Planners
3500 Parkway Lane
Suite 600
Norcross, Ga. 30092
Phone 678-336-7740
Fax 678-336-7744
Web www.pondco.com

Copyright © 2011 by Pond & Company. All rights reserved. No copying or duplication of these documents is allowed without the express written agreement of Pond & Company

Drawing Title: GROUND FLOOR DEMOLITION PLAN

Approved: Project Director

Project Title: Birmingham VA Replacement of Elevators Eight and Nine

Location: 700 South 19th St. Birmingham, AL

Date: FEBRUARY 2, 2011 | Checked: KJZ | Drawn: LMG

Project Number: 521-10-114

Building Number: 1A

Drawing Number: ED101

Dwg. 16 of 18

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231