



CONCRETE WALL & FOOTING SCHEDULE (FW-#)										
(SEE DETAIL 2/S201)										
MARK	CONCRETE FOUNDATION WALL			CONCRETE FOOTING				REMARKS	LOCATION	
	SIZE	REINFORCING REQTS		SIZE	REINFORCING REQTS					
	THICKNESS (T) (IN.)	VERTICAL REINFORCING	HORIZONTAL REINFORCING	L (IN.)	D (IN.)	VERTICAL REINFORCING	HORIZONTAL REINFORCING			
FW-1	9	#4's @ 9 o.c.	#4's @ 12 o.c.	-	69	12	SEE DETAIL	(5) #4's - LONG WAY (TOP) (7) #4's - LONG WAY (BOTTOM) #4's @ 12 O.C. - SHORT WAY (BOTTOM)	(1), (2)	NEW - CONCRETE STAIR WALLS
CONCRETE PIER & FOOTING SCHEDULE REMARKS:										
1.) ALL BENT TIES AND STIRRUPS SHALL BE BENT WITH A MINIMUM INSIDE DIAMETER OF 2"										
2.) TIES BETWEEN FOOTING PADS TO PIERS OR WALLS SHALL EXTEND A MINIMUM OF 30" INTO THE PIER OR WALL, AND SHALL CONTAIN A 90 DEGREE BEND WITHIN THE FOOTING										

