


three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot



- CONSTRUCTION KEYNOTE LEGEND**
- (C1) LAY-IN CEILING PANELS IN EXPOSED GRID SYSTEM SUSPENDED FROM STRUCTURE ABOVE.
 - (C2) 1/2" GYPSUM BOARD CEILING ON METAL SUSPENSION SYSTEM SUSPENDED FROM STRUCTURE ABOVE.
 - (C3) 1 HR RATED SHAFT WALL CEILING: KHI DESIGN 488 PSH 054/067, ONE LAYER 1/2" TYPE 'X' GYPSUM BOARD ON 2x4" STEEL SHAFTWALL STUDS @ 24" OC W/ 1" TYPE 'X' GYPSUM BOARD LINER PANEL @ CONCEALED FACE.
 - (C4) 2 HR RATED SHAFT WALL CEILING: KHI DESIGN 488 PSH 054/067, TWO LAYERS 1/2" TYPE 'X' GYPSUM BOARD ON 2x4" STEEL SHAFTWALL STUDS @ 24" OC W/ 1" TYPE 'X' GYPSUM BOARD LINER PANEL @ CONCEALED FACE.
 - (E1) ALUMINUM WINDOW SYSTEM WITH INSULATING GLASS.
 - (E2) ALUMINUM STOREFRONT SYSTEM WITH INSULATING GLASS.
 - (E3) ALUMINUM ENTRANCE SYSTEM WITH TEMPERED INSULATING GLASS (EDIT FOR SCHOOLS: 1/4" TEMPERED GLASS IN DOORS).
 - (E4) THERMALLY INSULATED METAL DOOR.
 - (E5) METAL FASCIA SYSTEM: METAL GRAVEL STOP ON TREATED 2x WOOD BLOCKING.
 - (E6) METAL COPING SYSTEM: METAL COPING ON TREATED 2x WOOD BLOCKING.
 - (E7) METAL GUTTER AND DOWNSPOUT. (EDIT FOR SIZE & STYLE).
 - (E8) SCUPPER. (EDIT FOR SIZE & STYLE).
 - (E9) METAL COUNTERFLASHING: ONE PIECE SURFACE MOUNTED METAL COUNTERFLASHING WITH MECHANICAL FASTENERS @ 12" OC W/ NEOPRENE WASHERS @ EXPOSED FASTENER HEADS.
 - (E10) METAL COUNTERFLASHING: ONE PIECE WEDGED-IN-PLACE METAL COUNTERFLASHING IN OPEN MORTAR JOINT, SAW CUT JOINT (3/8" HIGH X 1/2" DEEP). SECURE 1/4" LONG MOUNTING FLANGE W/ METAL WEDGES & SEAL W/ BACKER ROD & SEALANT.
 - (R1) BUILT-UP ROOFING (BUR) SYSTEM: SURFACING ON BUILT-UP ROOFING ON INSULATION ON THERMAL BARRIER.
 - (R2) ASPHALT SHINGLE ROOFING SYSTEM: SHINGLES ON UNDERLAYMENT. SEE ROOF PLAN FOR LOCATION(S) OF ICE & WATER BARRIER.
 - (S1) 4" REINFORCED CONCRETE SLAB ON VAPOR RETARDER ON 6" DRAINAGE FILL.

FINAL BID DOCUMENTS 95% CONSTRUCTION DOCUMENT SUBMISSION 12-14-12 50% REVISED DOCUMENTS FOR REVIEW 11-26-12 90% CONSTRUCTION DOCUMENTS SUBMISSION 05-17-12 50% CONSTRUCTION DOCUMENTS SUBMISSION 04-06-12 35% DOCUMENTS SUBMISSION 02-22-12 SCHEMATIC DESIGN SUBMISSION 11-21-11 Revisions: Date	Federal Health Care Center U.S. Department of Veterans Affairs U.S. Department of Defense Captain James A. Lovell Federal Health Care Center 3001 Green Bay Road North Chicago, IL, 60064	CAPTAIN JAMES A. LOVELL FEDERAL HEALTH CARE CENTER 2010	CONSULTANTS: ARNOLD & O'SHERIDAN Consulting Engineers CHEQUAMEGON BAY ENGINEERING, INC. MACKESY AND ASSOCIATES, LLC	PROJECT LEADER: Plunkett Rysch Architects 11000 West Park Place • Milwaukee WI 53224 • Tel 414 359-3060 • Fax 414 359-3070 Intelligent Designs Inspired Results www.prarch.com PRA Job No. 110172-01	Drawing Title Exterior Details Approved: Project Director	Project Title AE SCIP for Building 6 FHCC Location North Chicago, IL Date December 14, 2012	Project Number 556-11-119 Building Number 6 Drawing Number AS-600	Office of Facilities Management Department of Veterans Affairs
--	--	--	---	--	---	--	--	--