



- GENERAL DRAWING NOTES:
1. CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND RE-INSTALLATION OF CEILING GRID AND/OR CEILING TILES TO ACCOMMODATE PIPING INSTALLATION. REPLACE ANY DAMAGED CEILING MATERIALS TO MATCH EXISTING.
  2. REFER TO GENERAL NOTE #9 ON SHEET GI-001 FOR ALL WORK IN PARTIALLY EXCAVATED SUB-BASEMENT AREAS.
  3. ONLY NEW PIPING HAS BEEN SHOWN. SUB-BASEMENT CONTAINS MANY OTHER PIPING SYSTEMS THAT REMAIN. ROUTE NEW PIPING TO AVOID CONFLICT WITH EXISTING SYSTEMS AND MAXIMIZE CLEARANCE FOR

- KEYED NOTES:**
- 1 INCLUDE ISOLATION VALVES AND BLIND FLANGES FOR FUTURE CONNECTION TO D-WING.


[illegible]

**IPD: Engineering**  
INTEGRATED PROJECT DELIVERY

ONE WEBSTER'S LANDING  
SYRACUSE, NEW YORK 13202  
315.423.0185

IPD PROJECT # 11-7061-

Drawing Title SUB-BASEMENT BOILER PIPING PLAN	Project Title ADD HEATING HOT WATER TO SHAFTS #3 & #4			Date 11-16-12
				Project No. 528A7-11-711
	Building Number 1	Checked SBG	Drawn NCB	DRAWING NO. <b>MP-102</b>
	Location SYRACUSE			Dwg. 3 Of 8



Department of  
Veterans Affairs