

1. AFTER CRIMPING, ALL FLASHES, BURRS, OR SHARP EDGES RESULTING FROM THE CRIMPING PROCESS MUST BE REMOVED.



B3 NOT TO SCALE



B6 NOT TO SCALE




C8 NOT TO SCALE



D1 NOT TO SCALE



D4 NOT TO SCALE



E6 NOT TO SCALE



D8 NOT TO SCALE

4. ALL GROUNDING CONDUCTORS SHALL BE RUN EXPOSED WITHIN THE BUILDING WHENEVER PRACTICAL. CONDUCTORS SHALL NOT BE RUN CONCEALED IN SLABS, COLUMNS, OR WALLS. USE CONDUIT SLEEVES WHERE GROUND CONDUCTORS PENETRATE WALLS OR FLOOR SLABS.
5. PLASTIC OR METALLIC STRAPS SHALL BE USED TO SECURE GROUND CONDUCTORS EVERY 18" HORIZONTALLY AND EVERY 9" VERTICALLY TO THE BUILDING COLUMNS OR WALLS. IF METALLIC STRAPS ARE USED, THEY MUST BE OF THE TYPE WHICH DO NOT COMPLETELY ENCIRCLE THE CONDUCTOR. DO NOT USE CONDUIT, CABLE TRAY, MECHANICAL DUCT, OR PLASTIC TIE WRAPS TO SECURE GROUND CONDUCTORS.
6. PACK OPENING AROUND GROUND CONDUCTOR PENETRATIONS OF FLOOR SLABS OR WALLS WITH FIRE RETARDANT MATERIAL.

**100 LBS. STEEL RIVETED BUILDING
BID DOCUMENTS**

Revisions:	Date			300 Mount Lebanon Blvd #201A, Pittsburgh, PA 15234 - PH: 502.339.8511 ~ www.paradigmusa.com				E-DESIGN		INT'L		PARADIGM AMERICA
-------------------	------	--	--	---	--	--	--	----------	--	-------	--	------------------