



GENERAL NOTES

- ELECTRICAL ENTITIES DRAWN WITH THIS LINETYPE () INDICATES EXISTING TO REMAIN, UNLESS OTHERWISE NOTED.
- ELECTRICAL ENTITIES DRAWN WITH DARK LINETYPE () INDICATES DEMOLITION.

KEYED NOTES

- CONTRACTOR SHALL DISCONNECT ALL MECHANICAL EQUIPMENT AND POWER RECEPTACLES AND REMOVE ALL RELATED DISCONNECT SWITCHES, COMBINATION STARTERS, DEVICE BOXES, INCLUDING CONDUIT AND WIRE BACK TO THE POWER SOURCE PANELS 2-B-16 AND 2-B-17 INCLUDING (4) #410 WIRE AND 2½" CONDUIT BACK TO PANEL 2-B-11.
- CONTRACTOR SHALL REMOVE ALL LIGHTING FIXTURES, 2 x 4 FLUORESCENT, EXIT LIGHTS, CEILING LIGHTS, LIGHTING CONTROL SENSORS, LIGHTING SWITCHES, INCLUDING CONDUIT AND WIRE BACK TO THE POWER SOURCE PANELS 2-1-5 AND 2-1-1E IDENTIFIED ON THE PLAN. RECONNECT EMERGENCY LIGHTING CIRCUIT TO NEW EM LIGHTS IDENTIFIED ON PLAN EL101.
- CONTRACTOR SHALL REMOVE ALL TELECOM CABLING FROM EACH TELECOM OUTLET IDENTIFIED TO BE DEMOLISHED BACK TO RJ45 AND 110 BLOCKS LOCATED IN THIS ROOM.
- CONTRACTOR SHALL REMOVE EXISTING BUS TAP FEEDING PANELS 2-B-16 AND 2-B-17. COORDINATE 12:00 AM - 2:00 AM WEEKEND POWER OUTAGE WITH OWNER. SCHEDULE DEMOLITION OF 2½" CONDUIT THROUGH ROOM 004 AFTER 9:00 PM ON WEEKDAY.

ELECTRICAL
PARTIAL BASEMENT FLOOR PLAN
ROOM 002R
1/8" = 1'-0"

TELECOM
PARTIAL SECOND FLOOR PLAN
TELEPHONE/DATA ROOM
1/8" = 1'-0"

ELECTRICAL RM. 002R ELEVATION
SCALE: NONE

CONSULTANTS:

BUILDING IS
FULLY
SPRINKLED

ARCHITECT/ENGINEERS:

BROOKS BORG SKILES
ARCHITECTURE ENGINEERING LLP

317 6th Avenue, Suite 400
Des Moines, IA 50309-4136
515 244 7167

AE PROJECT NO.
10031

Drawing Title
**ELECTRICAL DEMOLITION
PARTIAL FIRST FLOOR PLAN**
Scale: NONE

Approved: Project Director

Project Title
CANTEEN RETAIL STORE

Project Number
636A6-10-712

Building Number
2

Location
DES MOINES, IOWA

Date
11/01/2011

Checked
BC

Drawn
VC

Drawing Number
ED101

Dwg. 13 of 16

Department of
Veterans Affairs