MECH/ ELEC LEGEND AND NOTES

LEGEND AND NOTES APPLY TO ALL SHEETS

EXISTING TO REMAIN

- RADIANT HEAT PANEL
- SURFACE MOUNTED 1X4 LIGHT
- RECESSED CAN LIGHT
- FIRE ALARM PULL STATION/ STROBE/ HORN
- ELEC. PANEL
- EXHAUST FAN THROUGH ROOF

NOTE: FOR ALL ITEMS TO REMAIN, DURING CONSTRUCTION PROTECT AND COVER.

GENERAL ELECTRICAL NOTE: CONTRACTOR SHALL VERIFY EXISTING CONDITIONS FOR ELECTRICAL, INCLUDING BUT NOT LIMITED TO CIRCUITS, WIRING AND AVAILABLE VOLTAGES. CONTRACTOR SHALL VERIFY COMPATIBILITY OF SPECIFIED FIXTURES AND DEVICES WITH EXISTING CONDITIONS.

DEMOLITION WORK

- RADIANT HEAT PANEL
- SURFACE MOUNTED 1X4 LIGHT
- WALL MOUNTED EXIT LIGHT
- JUNCTION AND PUSH BUTTON FOR DOOR OPERATORS
- SURFACE RECEPTACLE AND RACEWAY
- OCCUPANCY SENSOR
- THERMOSTAT AND SURFACE RACEWAY
- ELEC PULL BOX
- 1" CONDUIT TO ROOF TOP EQUIPMENT

NOTE: FOR ALL ITEMS TO BE REMOVED, REMOVE EXISTING WIRING TO PANEL IN ENTIRETY, UNLESS OTHERWISE NOTED TO REMAIN FOR NEW WORK. PATCH AND REPAIR WALL OR CEILING SURFACE TO MATCH ADJACENT.

- 1" GAS LINE TO ROOF TOP EQUIPMENT.

NOTE: REMOVE EXISTING PIPING IN ENTIRETY TO JUNCTION POINT. PATCH AND REPAIR WALL OR CEILING SURFACE TO MATCH ADJACENT.

NEW WORK

- SURFACE MOUNTED CEILING — PHOTON LIGHTING- OUTDOOR LIGHT FLUSH MOUNT MEN-HDS7M, OIL RUB BRONZE/ GLASS LENS CONNECT TO EXISTING WIRING/ CIRCUIT AT REMOVED LIGHTS.
- CONNECT TO BOTH NORMAL AND EMERGENCY POWER CIRCUITS WITH A BODINE GTD20A GENERATOR TRANSFER DEVICE.
- WALL MOUNTED SCONCE — PATRIOT LIGHTING- MISSION OUTDOOR WALL LANTERN (MEDIUM) MND0012G, BRONZE PATINA/ OPAQUE LINEN GLASS CONNECT TO WIRING/ CIRCUIT OF SURFACE MOUNTED CEILING LIGHTS.
- FREESTANDING LAMPPOST AND FOOTING — PATRIOT LIGHTING- MISSION OUTDOOR POST LANTERN MND0012G, BRONZE PATINA/ OPAQUE LINEN GLASS
- PERGOLA LAMPPOST MOUNTED TO PRECAST CAP — OUTDOOR POST 502039 (CUT TO LENGTH SHOWN IN ELEVATIONS) BLACK BASE 502484 SEE ELECTRICAL DRAWINGS FOR NEW WIRING/ CIRCUIT.
- WALL MOUNTED EXIT LIGHT — DUAL-LIGHT LX SERIES WALL MOUNT. REROUTE EXISTING WIRING FROM EXISTING TO NEW LIGHT.
- JUNCTION AND PUSH BUTTON FOR DOOR OPERATORS — REROUTE EXISTING WIRING FROM EXISTING JUNCTION BOX AND BUTTONS TO NEW LOCATIONS FOR NEW DOOR AND BUTTONS.
- SURFACE RECEPTACLE AND RACEWAY — EXISTING WIRING TO REMAIN. PROVIDE NEW GFCI DEVICES, NEW RACEWAY AND NEW WATERPROOF COVERPLATES.
- OCCUPANCY SENSOR — EXISTING WIRING TO REMAIN. PROVIDE NEW GFCI DEVICES, NEW RACEWAY AND NEW WATERPROOF COVERPLATES.

2 / 2.1 DEMOLITION PLAN
SCALE: 1/4" = 1'-0"



1 / 2.1 DEMOLITION PLAN
SCALE: 1/4" = 1'-0"

TRUE NORTH · PLAN NORTH

© 2000 Calvin L. Hinz Architects P.C.

These plans are specifically designed for construction by Calvin L. Hinz Architects and are intended for no other purposes. Permission for use of this document in part or whole without written consent of Calvin L. Hinz Architects is prohibited.

IMPORTANT CONTRACTOR'S NOTE

1. ALL CONTRACTORS ARE RESPONSIBLE FOR REVIEWING ENTIRE SET OF DOCUMENTS TO DETERMINE THEIR FULL SCOPE OF WORK. CONTRACTOR SHALL NOT BE ALLOWED EXTRA COSTS DUE TO FAILURE TO REVIEW ENTIRE SET OF DOCUMENTS.
2. ANY USE OF THESE ELECTRONIC DRAWINGS OR SCALING OF THE PRINTED DOCUMENTS ARE DONE SO AT THE CONTRACTORS RISK.

ARCHITECT CALVIN L. HINZ A-1793 STATE OF NEBRASKA

ARCHITECT/ENGINEERS:

CLH Calvin L. Hinz Architects, P.C.
Calvin L. HINZ Architects, P.C.
3705 North 200th Street
Elkhorn, Nebraska 68022
Phone:402.291.6941 Fax: 402.291.9193

Shaffer and Stevens Structural Engineering
9910 North 48th Street
Omaha, Nebraska 68152
Phone:402.455.7698 Fax: 402.455.7597

E&A Consulting Group, Inc
330 North 117th Street
Omaha, Nebraska 68154
Phone:402.895.4700 Fax: 402.895.3599

KRS Engineering, LLC
11620 Arbor Street, Suite 100
Omaha, Nebraska 68144
Phone:402.932.0100 Fax: 402.932.1001

Drawing Title
-DEMOLITION PLANS
-MECH/ ELEC LEGEND AND NOTES

Project Title
SMOKING SHELTER SITTING AREA
NWIHCS GRAND ISLAND

Location
VAMC Grand Island, NE

Approved Project Director: KEVIN HUTSELL

CONSTRUCTION DOCUMENTS (CD-3) SUBMITTAL 100%
JANUARY 9, 2013

Date	Checked	Drawn
JANUARY 9, 2013	CH	RB

Project Number: 636-12-817
Building Number: ONE
Drawing Number: A2.1
Dwg. 7 of 11

Office of Construction and Facilities Management
Department of Veterans Affairs

Revisions | Date

VA FORM 08-6231

P:\Projects - Active\2012-07 VA GI Exterior Sitting Area\100% to VA 010913\CAD drawings\VA GI Exterior Sitting Area 636-12-817 A01 A21-4.dwg 1-04-13 10:18:49 AM rblock