PLUMBING FIXTURE SCHEDULE

TAG	DESCRIPTION	S OR W	V	CW	HW	SPECIFICATIONS
P-103	WALL MOUNTED WATER CLOSET (A.D.A.)	4"	2"	1¼"	–	KOHLER "KINGSTON" MODEL MODEL K-4330-0 (OR APPROVED EQUAL), 1.6 GPF, ELONGATED WATER CLOSET; SLOAN "ROYAL" MODEL III ES-S EXPOSED SENSOR OPERATED 1.6 GPF FLUSH VALVE, OPTIMA EL-1500-L SELF ADAPTIVE INFRARED SENSOR WITH INDICATOR LIGHT, COURTESY FLUSH OVER-RIDE BUTTON AND MODEL EL-154 TRANSFORMER; CHURCH MODEL 9500C OPEN FRONT SEAT LESS COVER, J.R. SMITH FLOOR MOUNTED CARRIER (INSTALL AT A.D.A. HEIGHT WHERE SHOWN).
P-202	WALL HUNG URINAL (A.D.A.)	2"	1½"	¾"	–	KOHLER "DEXTER" MODEL K-5016-ET (OR APPROVED EQUAL) 1.0 GPF, SIPHON JET URINAL; SLOAN "ROYAL" MODEL 186-1 ES-S EXPOSED SENSOR OPERATED 1.0 GPF FLUSH VALVE, OPTIMA EL-1500 SELF ADAPTIVE INFRARED SENSOR WITH INDICATOR LIGHT, AND MODEL EL-154 TRANSFORMER; J.R. SMITH MODEL 0636 FLOOR MOUNTED CARRIER
P-418	WALL HUNG LAVATORY (A.D.A.)	1½"	1½"	1/2"	1/2"	KOHLER "KINGSTON" MODEL K-2007-0 (OR APPROVED EQUAL) 21" X 18" LAVATORY WITH BACK-SPLASH; CHICAGO FAUCETS MODEL 116.112.AB.1 INFRARED SENSOR FAUCET WITH 0.5 GPM VANDEL PROOF NON-AERATING SPRAY, MODEL 131-CABNF THERMOSTATIC MIXING VALVE, HARDWIRED TRANSFORMER; McGUIRE PRODUCTS MODEL 155A GRID STRAINER, MODEL PW2125 PREWRAPPED 17 GA. P-TRAP AND SUPPLY COVERS, MODEL LF2165LK STOPS; J.R. SMITH MODEL 0710 "LABOR SAVER" FLOOR MOUNTED CARRIER.
P-419	WALL HUNG EXAM SINK	2"	1½"	1/2"	1/2"	KOHLER "KINGSTON" MODEL K-2007-0 (OR APPROVED EQUAL) 21" X 18" LAVATORY WITH SINGLE HOLE FOR FAUCET; CHICAGO FAUCETS MODEL 834-EPSLOCP COMBINATION PEDAL BOX WITH EXTENDED PEDALS AND SLOW CLOSING CARTRIDGE AND MODEL 626-E29ABCP GOOSENECK SPOUT; McGUIRE PRODUCTS MODEL 155A GRID STRAINER, MODEL PW2125 PREWRAPPED 17 GA. P-TRAP AND SUPPLY COVERS, MODEL LF2165LK STOPS; J.R. SMITH MODEL 0710 "LABOR SAVER" FLOOR MOUNTED CARRIER.
P-502	JANITORS SERVICE SINK	3"	2"	3/4"	3/4"	FLORESTONE (OR APPROVED EQUAL) MODEL 97 28" X 28" X 12" DEEP HALF ROUND TERRAZZO MOP SINK; CHICAGO FAUCETS MODEL 897-CP FAUCET WITH VACUUM BREAKER SPOUT WITH PAIL HOOK AND WALL BRACE, LEVER HANDLES AND ¾" HOSE THREAD OUTLET; FLORESTONE MODEL MR-370 5' LONG HOSE WITH CLAMP AND MODEL MR-372 MOP HANGER WITH 3 CLAMPS.
P-528	SINGLE COMPARTMENT COUNTER MOUNTED SINK	2"	1½"	1/2"	1/2"	JUST MFG. CO (OR APPROVED EQUAL) MODEL SL-1921-A-GR 19" X 21" X 7½" DEEP SINGLE COMPARTMENT SINK WITH MODEL J-35-GS-STP BASKET STRAINER AND MODEL JT-200 17 GA P-TRAP AND McGUIRE LF2165LK STOPS. DELTA MODEL 100 FAUCET
P-709	DECK MOUNTED EMERGENCY EYEWASH	–	–	1/2"	1/2"	HAWS (OR APPROVED EQUAL) MODEL 7612LH SWING-AWAY EYEWASH DESIGNED TO BE MOUNTED ON LEFT SIDE OF SINK; MODEL TWBS.EWE TEMPERING STATION, SET AT 80°F
P-802	TRAP PRIMER	–	–	1/2"	–	PRECISION PLUMBING PRODUCTS (OR APPROVED EQUAL) MODEL PR-500 AUTOMATIC FLOOR DRAIN TRAP PRIMER, PROVIDE MIN. 12"X12" ACCESS PANEL IN WALL.
P-804	HOSE BIBB	–	–	3/4"	–	WOODFORD MANUFACTURING CO. (OR APPROVED EQUAL) MODEL 24-P HOSE BIBB WITH LOOSE KEY HANDLE AND NIDEL MODEL 34HF VACUUM BREAKER WITH HOSE THREAD END.
P-901	FLOOR DRAIN	2"	1½"	1/2"		J. R. SMITH MODEL 02005-A (OR APPROVED EQUAL) FLOOR DRAIN WITH 6" DIAMETER ROUND POLISHED NICKEL BRONZE STRAINER; P-802 TRAP PRIMER.
S-1	SINGLE COMPARTMENT SINK WALL MOUNTED	2"	1½"	1/2"	1/2"	JUST MFG. CO. (OR APPROVED EQUAL) MODEL A-18665-S 23" X 18½" X 12" DEEP SS SINK (LESS JUST MFG. FAUCET); CHICAGO FAUCETS COMPANY MODEL 626-E29ABCP GOOSENECK FAUCET AND MODEL 834-EPSLOABCP EXTENDED FOOT PEDAL CONTROLS; MCGUIRE MODEL 8902 17 GA. P-TRAP AND LF2165 STOPS
S-2	LABORATORY SINK SINGLE COMPARTMENT	2"	1½"	1/2"	1/2"	JUST MFG CO. (OR APPROVED EQUAL) MODEL SLX-2125-A-GR-1 25" X 21" X 10½" DEEP. 18 GA. STAINLESS STEEL SINK; CHICAGO FAUCET (OR APPROVED EQUAL) MODEL 900-CP-GN8BVBJKCP GOOSENECK FAUCET AND MODEL 625-CP FOOT PEDALS; MCGUIRE 8912CBSAN PTRAP, LF2165LK STOPS, J. R. SMITH 8710T SOLIDS INTERCEPTOR
S-3	DENTURE PROCESSING SINK	2"	1½"	1/2"	1/2"	VA FURNISHED, CONTRACTOR INSTALLED SINK WITH BOIL-OUT TANK; PROVIDE J. R. SMITH 8710T SOLIDS INTERCEPTOR, MCGUIRE 8912CBSAN P-TRAP, LF2165LK STOPS

EQUIPMENT SCHEDULE

TAG	DESCRIPTION	VOLTAGE	PHASE	HP	TANK SIZE	SPECIFICATIONS
DVS 1 / DVS 2	DENTAL VACUUM SYSTEM, NFPA 99C COMPLIANT	208-230	3	5 (1)	INFINI-TANK 30 GALLONS	RAMVAC (OR APPROVED EQUAL) BISON COMBO 9 WITH VACUUM UNIT STACKED ON 30 GALLON INFINI-TANK; PROVIDE Hg5 AMALGAM SEPARATORS; ON WALL LOGIC (OWL) CONTROLLERS (ONE CONTROLLER CONTROLS ONE VACUUM UNIT AND ONE AIR COMPRESSOR), AUTOWASH SYSTEM.
DAS 1 / DAS 2	DENTAL AIR COMPRESSOR SYSTEM, NFPA 99C COMPLIANT	208-230	1	1 (3)	30 GALLONS	RAMVAC (OR APPROVED EQUAL) CUSTOMAIR MODEL 1029T30 PROVIDE PRIMARY AND SECONDARY AIR DRYERS, FILTERS, PRESSURE REGULATORS AND CONTINUOUS LINE DEW POINT AND CARBON DIOXIDE MONITORING.

PUMP SCHEDULE

TAG	SERVICE	MFR (OR APPROVED EQUAL)	MODEL	GPM	HEAD	HP	VOLTS	PHASE	REMARKS
HWR-1	DOMESTIC HOT WATER RETURN PUMP	ARMSTRONG	H-41	7	15 FT	1/8	120	1	LEAD-FREE BRONZE CONSTRUCTION

WATER HEATER SCHEDULE

TAG	SERVICE	MFR (OR APPROVED EQUAL)	MODEL	GAS INPUT (BTU/HR)	RECOVERY	TANK CAPACITY	ELECTRICAL	APPROX. OPERATING WT.	REMARKS
WH-1	DOMESTIC HOT WATER	A. O. SMITH	BTN-100	90,000	87 GPH @100°F	98 GAL.	120V/1PH	1650 LBS	COMPLIES WITH SCAQMD RULE 1146.2
WH-2	DOMESTIC HOT WATER	A. O. SMITH	BTN-100	90,000	87 GPH @100°F	98 GAL.	120V/1PH	1650 LBS	COMPLIES WITH SCAQMD RULE 1146.2

"FULLY SPRINKLERED"

Revisions: Date

CONSULTANTS:

ARCHITECT/ENGINEERS:

K.F. DAVIS ENGINEERING, INC
530 LA GONDA WAY, SUITE E
DANVILLE, CA 94526

Drawing Title: PLUMBING SCHEDULES

Approved: Project Director

Project Title: DESIGN OF BUILD BACK BLDG 88 McCLELLAN

Location: McCLELLAN, CA

Date: 09/12/2012 | Checked: KL | Drawn: RMK

Project Number: 612-12-288

Building Number: MCC-88

Drawing Number: PL102

Dwg. 48 of 73

Office of Facilities Management

Department of Veterans Affairs

VA FORM 08-6231, OCT 1978