


- 1 REUSE EXISTING THERMOSTAT, UNLESS NOTED OTHERWISE. FIELD VERIFY EXACT LOCATION.
- 2 EXHAUST DUCT UP TO ROOF. SEE ROOF PENTRATION DETAIL, SEE M-6.
- 3 REPLACE EXISTING 208 VOLT 3 PHASE MOTOR WITH NEW 460 VOLT 3 PHASE MOTOR.
- 4 8"Ø CD BALANCE TO 190 CFM.
- 5 8"Ø CD BALANCE TO 205 CFM.
- 6 9x9 SQUARE TRANSITION TO 8"Ø REQUIRED.
- 7 6x6 SQUARE TRANSITION TO 6"Ø REQUIRED.



5' 0 5' 10' 15'



SCALE: $1/8" = 1'-0$

FULLY SPRINKLERED

85% SUBMITTAL	03.24.05
100% SUBMITTAL	05.03.05
FINAL SUBMITTAL	06.10.05
Revisions:	Date

ARCHITECT/ENGINEERS:

Cochran, Stephenson & Donkervoet, Inc.
The Warehouse at Camden Yards
323 West Camden Street
Baltimore, MD 21201
WWW.CSDARCH.COM
CSD Project Number: 04103.00

Wiley & Wilson
Employee-Owned
2550 Huntington Avenue
Alexandria, VA 22303
WWW.WileyWilson.com

Drawing Title

**Mechanical Floor Plan
HVAC New Work**

Approved: Project Director

Project Title	Expand Community Based Outpatient Clinic
---------------	---

V.A.M.
Building Number
6

Date
05.03.05

Project Number
512.514

Drawing Number

M-

Dwg 44 of

Loch Raven Outpatient Clinic

