

TESTING AREA
AS PER REQUIREMENTS
OF THE CITY OF
SALISBURY.

18" OF CONCRETE UNDERNEATH
EXISTING ASPHALT PARKING

CORE DRILL THROUGH
EXISTING CONCRETE

4" SEWER LINE AS PER
SPECIFICATIONS

EXISTING LIGHT POLE

EXISTING NATURAL
GAS
HAVE PIEDMONT NATURAL GAS
PERFORM
DETECTION BEFORE
ANY DIGGING

EXISTING ELECTRICAL
CHAMBERS
PERFORM UTILITY DETECTION

(BH6)
ELECTRICAL EQUIP. RM
1066

REPLACE EXISTING DRAINS
AND LINES TO CONNECT
TO NEW SEWER
LINE

18

EXISTING WATER SUPPLY
TO BE TEE INTO AND MAKE
NEW CONNECTIONS

(BH8)
PUMP ROOM
892

(BH7)
VESTIBLE
510

(BH7)
LOUNGE
281

(BH7)
CONTROL RM
192

(BH7)
LOUVER RM
151

(BH7)
OFFICE
195

8

U2

165

- EXISTING SEWER LINE
- SEWER LINE TO INSTALL
- CONNECT INTO EXISTING

Revision	Date

RECOMMEND APPROVAL			
REQUESTER	Date		
CHIEF OF SERVICE	Date	CHIEF OF STAFF	Date
ASSOC. DIR. PATIENT CARE SVC.	Date	ASSOC. DIR. for OPERATIONS	Date
APPROVAL BY:	Date		
MEDICAL CENTER DIRECTOR			

Drawing Title	NEW DRAINAGE WORK INTERIOR & EXTERIOR
Approved:	Safety Manager/M&O Supervisor
Approved:	Chief of Facilities Management Svr.

Project Title	BOILER PLANT MODIFICATIONS		
Building Number	BUILDING #10	Checked	
Location	W.G.(Bill) Hefner Medical Center 1601 Brenner Ave. Salisbury, NC 28144		

Date	15 JAN 13
Project No.	658-13-210
DRAWING NO.	P-102
DWG. 8 OF 10	



Department of
Veterans Affairs