

SECTION 23 52 33
WATER-TUBE BOILERS

PART 1 - GENERAL

1.1 DESCRIPTION:

This section specifies packaged water tube boiler with trim (accessories), dual fuel (natural gas and fuel oil) burner, fuel trains

1.2 RELATED WORK:

- A. Section 09 91 00, PAINTING.
- B. Section 23 21 11, BOILER PLANT PIPING SYSTEMS: Valves for boiler trim, non-return stop-check valve, piping for fuel and feedwater trains.

1.3 QUALITY ASSURANCE:

- A. Coordinate all new and existing equipment and conditions. This includes, but is not limited to: boiler, boiler trim, burner, fuel trains, gas pressure regulators and available gas pressure, fuel oil header back pressure regulator on house oil pump set and available fuel oil pressure, burner control system, combustion control system, economizer (if provided), breeching and stacks.
- B. Provide written certification that the entire assembly has been coordinated to achieve the required performance and to provide the required features.
- C. The model and size of the proposed burner shall have been previously applied to at least three boilers that are similar in size, proportion, and arrangement to the proposed boiler. In each of the three installations, burner performance shall have conformed to requirements listed in Part 2, BURNER and FUEL TRAINS. Provide list of these installations, and name, address and telephone number of person familiar with each project who will serve as a reference source.
- D. Regardless of fuel input rating, the equipment, installation and operation shall conform to NFPA 85. Where conflicts exist between NFPA 85 and this specification, this specification will govern.

1.4 SUBMITTALS:

- A. Before executing any work, submit in accordance with Section 01 33 23, SHOP DRAWINGS, PRODUCT DATA, and SAMPLES.
- B. Boiler:
 - 1. Complete catalog information and outline drawing of boiler and accessories with dimensions.
 - 2. Arrangement and description of construction of pressure parts, casings, drum internals, drum handhole covers and yokes, and support frame.
 - 3. Drum piping connection sizes, locations, construction.

4. Technical data including temperature ratings and arrangement of refractory and insulation.
5. Steam nozzle construction. Capability of steam nozzle and attachment to steam drum to withstand forces and moments imposed by connecting piping. Refer to table of forces and moments on the drawings.
6. Amount of heating surface, combustion volume.
7. Weight of boiler and burner assembly, empty and flooded.
8. Design pressures and temperatures.
9. Loading diagram of support frame. Evidence that boiler support requirements have been coordinated with foundation design.
10. Recommended anchorage of boiler support frame to foundation.
11. Furnace viewport construction, locations.
12. Dimensioned location of normal water line, lowest and highest permissible water level, set points of water level alarms and cutoffs.
13. Predicted surface temperature at front, rear and sides of boiler.

STRUCTURAL COMPONENTS.

- C. Boiler Trim: Includes bottom blowoff valves, water column with conductivity probe assembly, water level gage with illuminator, auxiliary low water cutoff, piping, all valves and fittings furnished by boiler manufacturer, feedwater control valve, safety valves, steam pressure gage, steam pressure switches.
1. Design, construction, arrangement on the boiler.
 2. Pressure and temperature limitations.
 3. ASTM numbers and schedule numbers of piping.
 4. Type and pressure ratings of pipe fittings.
 5. Flow and pressure drop data on feedwater control valve.
 6. Scale ranges of gages, thermometers, and pressure switches.
 7. Location of water level sensing and indicating devices in relation to normal water line of boiler and highest and lowest permissible water lines of boiler.
 8. Set pressure and capacity of safety valves.
- D. Burner and Fuel Trains:
1. Catalog data and drawings showing construction of burner parts and assembly of complete system.
 2. Drawings, with dimensions, showing burner over all size and mounting on the boiler.
 3. Catalog data and outline drawings of forced draft fan, flue gas recirculation ductwork (if provided), dampers, motors and sound attenuators on fan intake or discharge.

4. Drawings showing assembly of throat refractory into furnace refractory wall.
5. Type and temperature rating of throat refractory.
6. Drawings and catalog data on all equipment in igniter (pilot) train, main fuel trains, atomizing media train. Include data on pressure and temperature ratings, flow vs. pressure drop, performance characteristics, and inspection agency approvals. Complete data on oil atomization air compressor systems with sound attenuators.
7. ASTM number and schedule numbers on all piping.
8. Type and pressure ratings of pipe fittings.
9. Burner flow and pressure data:
 - a. Main burner fuel and atomizing media pressures and flows at maximum required firing rate.
 - b. Igniter (pilot) fuel flow and burner pressure.
 - c. Natural gas main fuel pressure at outlet of burner-mounted pressure regulator.
 - d. Igniter fuel pressures (natural gas and LP gas) at outlet of burner-mounted pressure regulators.
 - e. Forced draft fan static pressure, power and air flow at maximum firing rate. Amount of flue gas recirculation.
10. Full load efficiency and power factor of all motors.
11. Predicted sound level at maximum firing rate.
12. Weight of burner assembly.
13. Drawings showing location and arrangement of drive units and jackshaft system (if provided) for controlling fuel and air flow.
14. Weight of burner assembly.

E.N/A

F. Flue Gas Economizer:

1. Drawings showing arrangement and dimensions of unit and all accessories.
2. Design and construction of unit and accessories including soot blowers, safety relief valve.
3. Weight of entire unit, empty and flooded.
4. Pressure and temperature limitations of unit and accessories.
5. Performance data on safety relief valve.
6. Drawing showing tube arrangement, clearance for tube removal (rectangular units) and soot blower nozzle locations. Written recommendations of soot blower manufacturer on number of elements and locations of nozzles for this economizer design and size.
7. Manufacturers operating recommendations for mounting and support requirements for economizer (weight-flooded).

H. Boiler and Burner Predicted Performance Data, for Each Fuel, Site Altitude:

1. At Maximum Required Output With and Without Economizer (If Applicable) In Service, at 15 Percent Excess Air: Fuel and steam flow, boiler flue gas outlet temperature, economizer (if provided) flue gas outlet temperature, steam quality, boiler efficiency, windbox and furnace pressures, predicted boiler radiation and unaccounted losses, feedwater and flue gas pressure losses in the economizer (if provided).
2. At Low Fire, 25%, 50% and 75% of Maximum Firing Rate: Percent excess air, carbon monoxide (CO) ppm and NOx ppm.

I. ASME "P" Forms, Manufacturer's Data Report, on boiler and economizer construction.

J. Pretest Data - Boiler, Burner, Controls: As required by Part 3.

K. Final Test Report - Boiler, Burner, Controls: As required by Part 3.

L. Completed System Readiness Checklists provided by the Commissioning Agent and completed by the contractor, signed by a qualified technician and dated on the date of completion.

1.5 PROJECT CONDITIONS:

- A. Modification to existing system see construction drawings.

1.6 APPLICABLE PUBLICATIONS

- A. The publications listed below form a part of this specification to the extent referenced. The publications are referenced in the text by basic designation only.

B. ASTM International (ASTM):

A106/A106M-08.....Standard Specification for Seamless Carbon Steel Pipe for High Temperature Service.

A178/178M-02(2007).....Standard Specification for Electric-Resistance-Welded Carbon Steel and Carbon-Manganese Steel Boiler and Superheater Tubes

A269-10.....Standard Specification for Seamless and Austenitic Welded Stainless Steel Tubing for General Service

C612-10.....Standard Specification for Mineral Fiber Block and Board Thermal Insulation

D396-09a.....Standard Specification for Fuel Oils

C. American Society of Mechanical Engineers (ASME):

Boiler and Pressure Vessel Code - 2007 Edition with Amendments.

Section I.....Power Boilers

Section II.....Material

Section VII.....Recommended Rules for Care of Power Boilers

Section IX.....Welding and Brazing Qualifications

Performance Test Code (PTC):

PTC 4-2008.....Fired Steam Generators

Code for Pressure Piping:

B31.1-2007.....Power Piping

D. National Fire Protection Association (NFPA):

70-2008.....National Electric Code

85-2007.....Boiler and Combustion Systems Hazards Code

E. National Board of Boiler and Pressure Vessel Inspectors (NBPVI):

NB-232007.....National Board Inspection Code

F. Fluid Controls Institute (FCI):

70-2-2006.....Control Valve Seat Leakage

G. Department of Health and Human Services, Food and Drug Administration (FDA):

CFR 21, 173.310,.....Boiler Water Additives Permitted in Plants Where
Steam Contacts Food

H. Environmental Protection Agency (EPA):

CFR 40, PART 60, Appendix A, Method 9, Visual Determination of the
Opacity of Emissions from Stationary Sources

PART 2 - PRODUCTS

2.1 D-TYPE WATER TUBE BOILER

A. Factory-assembled, packaged water tube, industrial-class, high pressure steam boiler. Two drum, "D-type" furnace tube configuration, two pass. Designed for natural gas and fuel oil firing.

B. Service: Designed to continuously receive feedwater at 100 °C (212 °F) and generate steam at pressures and quantities shown.

C. Performance:

1. Steam output quantity, refer to drawings.

2. Steam output quality, 99 percent minimum at all steam flow rates.

Based on water quality in boiler of 3500-ppm maximum total solids, 15-ppm maximum suspended solids, 700-ppm maximum alkalinity.

3. Minimum Efficiency at Required Maximum Output:

a. Natural Gas Fuel ~~(37.3 MJ/cubic meter)~~ (1000 Btu/cubic foot): 78 percent at 15 percent excess air or 80 percent at 5 percent excess air.

b. Fuel Oil (ASTM D396 Grade 2, 4, 5, or 6): 83 percent at 15 percent excess air or 81.5 percent at 5 percent excess air.

D. Boiler Heating Surface and Furnace Volume:

1. Heating Surface Area: Provide surface area necessary to obtain required performance, however surface area shall not be less than

shown on the drawings. Heating surface is defined as flat projected tube surface, including fins, in combustion space, whether or not covered by refractory, plus outside (gas side) circumferential area of all convection tubes.

2. Furnace (Combustion) Volume: Heat release at full load shall not exceed 518,000 watts per cubic meter (50,000 Btu per hour, per cubic foot). Combustion volume limits shall not extend beyond first plane of entry into convection tubes. Screen tubes, when used, shall be considered the first plane of entry.

E. Minimum Design Pressure, 1375 kPa (200 psi).

F. Construction:

1. Codes; Comply with ASME Boiler and Pressure Vessel Code, Sections I, II, VII, and IX.
2. Design shall accommodate thermal expansion and seismic shocks (in seismic areas).
3. No element of the boiler or accessories shall be overstressed, displaced, or have cracks, broken welds or excessive deflection. All vertical elements of the boiler and accessories shall be plumb and all horizontal elements shall be level.
4. Base Frame: Design for mounting on flat concrete base. All elements shall be level and square. Provide attachments for anchorage to concrete foundation.
5. Provide lifting lugs and jacking pads.
6. Drums:
 - a. Steam drum shall be minimum 914 mm (36-inch) diameter. Bottom drum shall be minimum 610 mm (24-inch) diameter. Equip steam drum with elliptical side-hinged manway on each end. Equip bottom drum with non-hinged elliptical manways at each end. Equip all manways with properly fitted forged steel yokes, bolts, nuts, and non-asbestos gaskets. Manway covers shall have bolt slots forged integral with covers. Provide access to all manways clear of piping, valves.
 - b. All tube holes shall be grooved and sized for 50 mm (2 inch) tubes and shall be radial and properly located to permit proper alignment of tubes. Swaged tubes with reduced drum openings will not be permitted.
 - c. Intermediate header for water wall or convection tubes will not be permitted.
7. Drum Piping Connections:
 - a. Flanged, except threaded are permitted for pipe size under 65 mm (2-1/2 inches).

- b. Steam nozzle shall be 2050 kPa (300 psi) ANSI flanged. Design nozzle and drum assembly to withstand forces and moments imposed by connected piping. Studding nozzle will not be permitted.
 - c. Locate boiler manual steam vent to permit access to gate valve from platform located above boiler.
 - d. Soot blower outlets.
 - e. Locate safety valve outlets to permit straight run of vents through roof and to permit valve handle access from platform located above boiler.
 - f. Separate connections for water column and auxiliary low water cutoff.
 - g. Connections for boiler feedwater, chemical admission, combined continuous blow down and water sampling. Locate as shown on the drawings.
 - h. Bottom drum blowoff.
 - i. Water level sensor connections (for incoming feedwater control).
 - j. Pressure gage and pressure switch connections.
 - k. Two 50 mm (2 inch) piping connections on rear head of bottom drum for steam heater for keeping boiler warm in standby mode. Also, connection for temperature sensor for temperature control valve.
8. Drum Internals:
- a. Steam purification equipment, including dry pan separators, plate-type baffles and other devices as necessary, to meet steam quality requirements and provide proper water levels in the boiler steam drum.
 - b. Boiler feedwater admission system to properly distribute feedwater.
 - c. Chemical feed piping to permit infusion of mixture of water treatment compounds along entire length of drum by continuous feed system.
 - d. Continuous blowdown and water sampling system as combined unit designed to collect water along entire length of drum.
 - e. Bottom drum blowoff system to properly collect sediment from bottom drum and to permit complete collection of sediment and drainage.
 - f. Steam heating pipes in bottom drum to keep boiler warm on standby. Cap for future connections of steam supply and condensate return.
 - g. Drum internal fittings shall be provided, securely mounted and easily removable for boiler internal access for inspections and cleaning.
9. Tubes:

- a. ASTM A178 Grade A, seamless or electric resistance welded, outside diameter 50 mm (2 inch) or greater. Uniform internal area, not swaged at drum connections, bend radii permitting turbine cleaning by mechanical tube cleaner.
 - b. Arrange convection tubes in alternate narrow and wide rows to permit tube removal without removing adjacent tubes. Align tubes to prevent impingement of soot blower steam jet directly on tube surface.
 - c. Front furnace tubes (if provided) shall be completely clear of burner throat and bullring and arranged to permit maintenance of front wall refractory system without tube removal.
 - d. Provide rear water wall tubes covering a minimum of 80 percent of the rear wall area. Arrange tubes to permit unobstructed view through observation ports in the rear wall and to permit maintenance of rear wall refractory without removing tubes.
 - e. Tubes separating the furnace from the convection area shall have continuous fins welded to each side of the tubes and to each other to form a pressure-tight membrane wall to prevent flue gas bypass of the furnace and convection spaces.
 - f. Soot blower and baffle supports from tubes shall be properly arranged to eliminate excessive stress on tubes.
10. Refractory:
- a. Refractory quality and temperature characteristics shall be suitable for long-term service at the maximum operating conditions and shall be the boiler manufacturer's experience-proven selection. Incorporate refractory systems in the front and rear walls, and seal interface between combustion and convection areas. Repair and replacement of refractory shall be possible without alteration to pressure parts of boiler.
 - b. Front and Rear Walls: Construct of shiplap firebrick arranged to permit expansion and contraction. Do not use castable refractory except to seal locations where bricks cannot be used. Provide bullring constructed of firebrick to protect burner throat refractory from forces generated within front wall. Provide expansion joint between bullring and burner throat. Incorporate openings in rear wall for observation ports, and for access to furnace as specified under paragraph "Casing." Access opening shall include a removable refractory plug.
11. Casing, Setting and Insulation:
- a. Provide double wall casing system with insulation between the walls. Inner casing can be a welded finned-tube inner wall. The

inner casing or welded fin tube construction shall be sealed to prevent the combustion gases from coming in contact with the outer casing.

- b. Design casing at the combustion gas outlet to receive approved stack or breeching transition section as shown. Refer to plans for details of gas outlet arrangement.
- c. Provide furnace access door located near the furnace floor. Use of burner throat as access is not permitted. Equip furnace access door opening with refractory, backed up by insulation and airtight cover system.
- d. Provide three 50 mm (2 inch) diameter observation ports in rear wall of furnace located to permit observation of each sidewall of furnace and full area of burner throat and bullring. Furnish each port with clear and tinted interchangeable glass; gas tight sliding metal closure between glass and furnace, forced air-cooling.
- e. Provide convection space inspection openings sealed with caps removable for inspection.
- f. Insulation shall be manufacturer's proven standard materials and methods. No part of the external casing (except for areas within one foot of a casing penetration) shall reach a temperature exceeding 30 °C (86 °F) above ambient. Field-repair hot spots exceeding requirements.
- g. Provide water wash troughs and drains (piped to accessible point) on both sides of lower drum to allow cleaning of exterior of convection tubes.

G. Factory Inspection and Tests:

- 1. Pressure Vessel Inspection and Certification: Inspect and certify the completed boiler assembly in accordance with the requirements of the ASME Boiler and Pressure Vessel Code, Section I. Submit four copies of completed ASME Form P-3 for each boiler.
- 2. Inner Casing Pressure Test: Perform test after erection of the boiler pressure parts and inner casing. Seal boiler openings air-tight and pressurize the furnace and convection area to 2.5 kPa (10-inches of water) minimum. Check all welded joints with soap solution. Seal all leaks by rewelding. The inner casing shall be assumed to be tight when it holds pressure for 10 minutes with a loss not exceeding 10 percent. Test shall be certified by manufacturer and may be witnessed by a Government representative.

- H. Finish: Provide surface preparation, heat resistant prime and finish coats using standard color of boiler manufacturer as specified in Section 09 91 00, PAINTING.

2.2 BOILER TRIM (ACCESSORIES):

- A. Conform to ASME Boiler and Pressure Vessel Code, Section I. for operation of water level and steam pressure controls.
- B. Soot Blowers: Provide one or more systems on each boiler that burns oil as primary or secondary fuel. Arrange the system to completely clean the convection area.
1. Type: Steam-operated, valve-in-head, chain-operated to control rotation of element and admission of steam.
 2. Elements: Equip with venturi nozzles located to clean all tubes without damaging impingement on any tube as evidenced by tube surface erosion. Provide materials that meet temperature gradient characteristics of the boiler/element arrangement. All materials in the element shall be selected and certified as having temperature characteristics in excess of temperature requirements.
 3. Heads: Located in front or rear, as necessary to allow removal of element or as shown, securely mounted and structurally supported to prevent binding in operation. Equip heads with liquid-filled pressure gage of proper scale to check soot blower operation. Provide purging air from burner wind box to soot blower elements.
 4. Bearings: Shall support the element without bending, binding or distortion, and shall be mounted in boiler convection space in manufacturer's standard and approved method.
- C. Steam Safety Valves:
1. Provide two or three on each boiler. Capacities certified by National Board of Boiler and Pressure Vessel Inspectors (NB).
 2. Type: Angle pattern, flanged or threaded inlet, flanged or threaded side outlet, lifting lever, bronze or cast iron bodies, stainless steel trim, dual control rings. Valves with bronze bodies shall have EPDM O-ring seat seals. Valves with cast iron bodies shall have lapped seats.
 3. Settings and Adjustments: Factory set, sealed, and stamped on nameplate. Set pressures as shown. Lowest set pressure shall not exceed normal operating pressure by more than 210 kPa (30 psi). Provide 30 kPa (5 psi) difference in setting between each of the valves.
- D. Steam Pressure Gage:
1. Construction:

- a. Case: Surface-mounting, bottom or back connection, threaded ring, blowout disc in rear.
 - b. Dial: 200 mm (8 inch) minimum diameter, non-corrosive, black markings on white background.
 - c. Measuring Element: Bourdon tube designed for steam service.
 - d. Movement: Stainless steel, rotary.
 - e. Pointer: Micrometer adjustable, black color.
 - f. Window: Laminated safety glass, or plastic.
 - 2. Accuracy: Full span, 1/2 percent.
 - 3. Range: 0 - 160 psi
 - 4. Installation: Stop valve, steel piping, valved blowdown, siphon, union at gage, valved connection for inspector's gage. Mount gage on sheet metal panel affixed to front of boiler. Use spacers between panel and gage to permit operation of blow-out disc.
- E. Water Column with Water Level Indicator:
- 1. Type: Conductivity probe type water level sensing, tilted prismatic gage glass with illumination, 1725 kPa (250 psi) steam minimum design.
 - 2. Conductivity Probes: Stainless steel with virgin Teflon insulation, AC power. High water alarm, low water alarm, primary low water cutoff, grounding probe. Low water alarm point higher than low water cutoffs. High and low alarms operate bell and warning lamp on boiler control panel but do not cause a burner shutdown.
 - 3. Gage Glass - Prismatic: Single or double (offset) tilted prismatic tempered borosilicate reflex units of sufficient length to include all low water cutoff points and high water alarm point without discontinuity. Provide gage illuminator, mounted vertically, designed to direct light at gage only. Locate in front of gage. Do not block view of gage from personnel standing 1800 mm (6 feet) in front of burner. Provide chain-operated 1/4 turn gage valves. Extend chains to within 1800 mm (6 feet) of the floor.
- F. Auxiliary Low Water Cutoff:
- 1. Type: Float chamber with float-actuated sealed snap switch. Water piping connections to the steam drum shall be independent from other devices such as the water column.
 - 2. Construction:
 - a. UL listed.
 - b. Float chamber shall have drain connection.
 - c. Packless construction with pivot and bearing point remote from high temperature areas.
 - d. Design for 1725 kPa (250 psi) steam.

- G. Low Water Cutoff Shunt Switches: Provide two separate non-latching pushbutton controls, one to short-circuit probe-type primary low water cutoff and the second to short-circuit the auxiliary low water cutoff when each is blown down. Locate pushbuttons within reach of drain valves for cutoffs.
- H. High Steam Pressure Cutouts:
1. Provide two units with different set points. Unit with lowest set point shall be automatic reset; unit with highest set point shall be manual reset.
 2. Type: Bellows actuated sealed snap-acting or mercury switch with adjustable set point and adjustable differential pressure (automatic reset unit).
 3. Construction:
 - a. UL listed.
 - b. Design for 1375 kPa (200 psi) minimum emergency pressure.
 - c. Switch position indicator visible without removing cover.
 - d. Set pressure range: To 110 percent of required set pressure.
 - e. Provide set point indicators with graduated scales for set point and differential pressure that are visible without removing cover.
 4. Mounting: Pipe directly to boiler steam drum or to water column. There shall be no valves between cutouts and steam drum. Provide siphons at each switch to protect bellows from high temperature.
 5. Set Points:
 - a. Automatic Reset Unit: Refer to boiler schedule shown on the drawings.
 - b. Manual Reset Unit: 35 kPa (5 psi) higher than automatic reset cutout but below safety valve set pressure. Subtractive differential not to exceed 70 kPa (10 psi).
- I. Feedwater Control Valve:
1. Type: Single-seated, cage guided, balanced valve plug, or characterized rotary valve, designed for throttling service. Equal-percent valve flow characteristic. Electric actuator with positioner.
 2. Performance: Refer to schedules on drawings for pressure, temperature and flow requirements. If not scheduled, flow capacity shall be 125% of maximum boiler steam flow with a maximum pressure drop of 35 kPa (5 psi). Maximum seat leakage at shut-off shall not exceed 0.01% of maximum valve capacity (FCI 70-2, Class IV).
 3. Construction - Plug Type:

- a. Body Type: Cast iron or bronze, flanged for 65 mm (2-1/2 inch) pipe size and larger, threaded for 50 mm (2 inch) pipe size and under, rated for 1725 kPa, 138 °C (250 psi, 280 °F) minimum.
- b. Plug, Cage, Seat Ring: Replaceable, hardened stainless steel.
- 4. Construction - Rotary Type:
 - a. Three-piece body, cast steel or bronze, flanged for 65 mm (2-1/2 inch) pipe size and larger, threaded for 50 mm (2 inch) pipe size
 - b. 316 SS ball and stem, Polyfil seat, TFE coated SS seal.

2.3 BURNER AND FUEL TRAINS:

- A. Burner Type: Combination natural gas and fuel oil, packaged, forced draft, single burner, modulating firing, register type on D-type boilers
Interrupted igniter (pilot), electrically ignited, natural gas and propane. \
 - 1. Gas Burner: Ring type with multiple ports and spuds, or spud type.
 - 2. Oil Burner: Gun type, inside mix, steam or low pressure air atomizing.
 - 3. Igniter (Pilot): Interrupted, electrically ignited, natural and LP (propane) gas.
- B. Service:
 - 1. Continuous long term operation at all firing rates on each fuel listed under PROJECT CONDITIONS in Part 1. Design the entire burner and fuel train system for application to the specific boiler furnished and for service at the available fuel pressures and heating values.
 - 2. Operate at all loads on any one fuel without any manual changes to burners, fuel trains or fuel pressures, atomizing media trains or pressures.
 - 3. Igniter (Pilot) Fuels: Normal fuel will be natural gas. Propane will be used if there is an interruption in natural gas service.
- C. Performance:
 - 1. Igniter (pilot) flame on natural gas and propane shall form close to the point of ignition and shall be stable. Ignite both the gas and oil burner with single igniter.
 - 2. Main flame on gas and oil fuels shall ignite at lowest firing rate.
 - 3. Main flame characteristics at all firing rates:
 - a. Flame retained within 150 mm (6 inches) of diffuser.
 - b. Flame stable with no blowoff from the burner or flashback into the burner. No pulsations.
 - c. Throat refractory shall be sufficiently heated to provide stable flame on gas firing.

- d. No deposits of unburned fuel or carbon at any location.
- e. No carryover of flame beyond the end of the first pass (furnace).
- f. Flame impingement on furnace tubes or refractory is not permitted if it results in hard carbonaceous deposits on furnace tubes or refractory or excessive emissions in the flue gas, or failure of furnace tubes, or deterioration of refractory.

4. Main Burner Operation:

- a. Minimum turndown
- b. Utilize full travel of fuel control valve characterization cams (if cam type valve is utilized).
- c. Operate at all loads on any one fuel without any manual changes to burners, fuel or atomizing media trains or pressures, air train.

d. Excess Air in Flue Gases with Oxygen Trim at Null Position:

Boiler Steam Output, Percent of Maximum Required Capacity	Percent Excess Air Allowable Range
Below 25	15 minimum
25 - 39	15 - 35
40 - 100	15 - 25

e. Excess Air in Flue Gases (Low Excess Air Burners) with Oxygen Trim at Null Position:

Boiler Steam Output Percent of Maximum required Capacity	Percent Excess Air Allowable Range
Below 20	10 minimum
20 - 39	5 - 15
40 - 100	5 - 10

- f. Performance at any load point shall be repeatable after increasing or decreasing the firing rate. Repeatability plus or minus two percent excess air, at 20 percent and higher boiler loading except excess air must remain within ranges specified above.

5. n/a

- 6. Oil Atomization: If plant is cold (no steam available), and if steam-atomizing burners are provided, light-off shall be with compressed air atomization media supplied by house compressor. Boiler shall operate with combustion controls on "manual" and continuously generate at least 13 percent of the maximum rated steam flow with

input compressed air at 550 kPa (80 psi) and a maximum of 0.8 standard cubic meters per minute (30 SCFM).

D. Flue Gas Emissions Limits:

1. Carbon Monoxide: Shall not exceed 200 PPM.
2. Smoke: On natural gas and No. 2 oil shall not be visible and shall not exceed No. 1 on the Bacharach smoke scale.

E. Burner Design, Construction and Arrangement:

1. Burner Access (Main Burner and Igniter): Arrange fuel trains, controls and other devices so that they do not interfere with the removal and replacement of burner parts.
2. Arrangement of Fuel Trains: All devices shall be accessible for maintenance or replacement without removal of other devices. Do not mount any piping or devices within 600 mm (2 feet) of boiler side and top casings, and do not attach any piping or devices to boiler casings.
3. Coatings: Provide surface preparation, heat resistant prime and finish coats using standard color of boiler manufacturer. Refer to Section 09 91 00, PAINTING.
4. Combustion Air System and Flue Gas Recirculation (FGR) System (if provided):
 - a. Air flow rates controlled by forced draft fan inlet or outlet dampers.
 - b. Symmetrical, balanced distribution of combustion air into the burner.
 - c. N/A
 - d. Forced Draft Fan: Airfoil or backwardly inclined wheel, electric motor driven. Design for required excess air and for static pressure that is based on losses from fan inlet to stack or chimney outlet, including economizer (if provided), at jobsite altitude. Fan shall have no resonant frequencies at all operating speeds.
 - e. Motor: TEFC or open drip proof, non-overloading under all fan operating conditions, design for 40 °C ambient, premium efficiency type. Motors for variable speed service shall be rated inverter-ready.
 - f. Damper: Design to provide accurate control of excess air with minimum hysteresis. On variable speed systems, the damper shall control only at lower firing rates.
 - g. Motor Starter Panel: Provide motor starter mounted in NEMA 4 enclosure, readily accessible\

- h. Sound Attenuators: Provide attenuators on forced draft air intakes to reduce sound levels to allowable limits.
5. Provide viewport, with one clear and one tinted replaceable interchangeable glass. Locate to permit view of main and igniter flames.
 6. Burner Throat: Refractory tile, shaped to promote proper combustion, arranged with provisions for expansion and contraction and rated by the refractory manufacturer for the maximum service conditions.
 7. Electrical Conduit: Provide liquid-tight flexible metal conduit with sealing fittings for all power and control services to fuel trains and burners. Refer to Section 26 05 33, RACEWAY and BOXES FOR ELECTRICAL SYSTEMS.
 8. Factory Testing (Factory-Assembled Boilers): Mount burner and controls on boiler at factory and fire-test at all load points.
- F. Natural Gas Main Fuel Valve and Piping Train:
1. Arrangement: Comply with typical arrangement in NFPA 85, Annex A, as modified by the following description: Starting at the entrance to the train, the devices are, in sequence: plug valve, filter, pressure gage, pressure regulator, valved connection to pilot burner fuel train, flow meter (if required), pressure gage, low pressure switch, two automatic safety shut off valves, valved leak test, high pressure switch, fuel flow control valve, plug valve, pressure gage, burner. Provide tee connection for vent between the automatic safety shut off valves. Vent line shall include valved leak test connection, automatic vent valve, valved leak test connection, lockable plug valve, vent thru roof. High and low pressure switches shall be located to sense the constant pressure controlled by the burner pressure regulator and not the variable burner pressure.
 2. Filter: Replaceable fiberglass or cellulose cartridge, 10 micron or smaller particle retention. Static pressure capability two times the maximum lock-up pressure of nearest upstream pressure regulator. Maximum pressure loss at high fire 1.3 kPa (5 inches water column). Provide vent with cock for relieving pressure in filter.
 3. Pressure Regulator:
 - a. Type: Single seated, diaphragm-operated, designed for natural gas service. Controlled pressure shall be sensed downstream of main valve. Valve may be self-operated or pilot-operated as necessary to comply with performance requirements.
 - b. Service: Provide precisely controlled downstream pressure in fuel train, with upstream pressure as shown or specified. Inlet and

outlet emergency pressure rating shall be at least twice the lock-up pressure of the nearest upstream pressure regulator. Purpose of high performance regulator is to provide more accurate flow control and thus greater burner efficiency and to allow set points of high and low gas pressure switches to be closer to the normal operating pressure.

- c. Performance: Coordinate with burner requirements. Lock-up pressure shall not exceed 1.5 times regulated pressure. Coordinate speed of response with opening and closing time of automatic safety shut-off valves so that controlled pressure will be maintained during the opening and closing of the safety shut-off valves. The outlet pressure droop from low fire to high fire shall not exceed 5 percent of the set pressure.
 - d. Construction, Main Valve: Cast iron body, replaceable plug and seat.
4. Automatic Safety Shut-Off Valves:
- a. Type: Motorized-opening, spring closing, controlled by burner control system. Two valves required.
 - b. Service: Provide open-shut control of fuel flow to burner. Valves shall shut bubble tight and be suitable for operation with upstream pressure of two times the highest pressure at entrance to boiler-mounted regulators.
 - c. Performance: Timed opening of six seconds or less to safely and smoothly ignite main flame, and close within one second.
 - d. Construction: Valves 65 mm (2-1/2 inches) and larger, flanged ends; valves 50 mm (2 inches) and below threaded ends; position indicator showing open and shut, visible from front or side of boiler. Aluminum seating surfaces not permitted. Proof of closure interlock switch on each valve. Proof of closure electrical circuit shall include non-latching push button interrupter for testing the circuit. Valved leak test fittings before and after each valve.
 - e. Approval: FM approved, UL listed for burner service.
 - f. Proof of Closure Test: Provide non-latching push button control in the proof of closure circuit to interrupt the circuit for testing.
5. Automatic Vent Valve:
- a. Type: Motorized or solenoid closing, spring opening, full port, controlled by burner control system.
 - b. Service: Provide open-shut control of vent line that is connected between the two safety shut-off valves. Valves shall shut bubble-tight and be suitable for operation with upstream pressure

of two times the highest pressure at entrance to boiler-mounted regulators. Valve shall be open whenever safety shut-off valves are closed.

c. Approval: UL listed for burner service.

6. Vent System Manual Plug Valve for Leak Tests: Located on vent line on outlet side of automatic vent valve. Provide locking device and lock wrench to lock valve to open position. Provide cylinder padlock keyed to VA Engineering key. Provide valved leak test connections between automatic vent valve and plug valve and ahead of the automatic vent valve.

G. Fuel Oil Valve and Piping Train:

1. Arrangement: Comply with typical arrangement in NFPA 85, Annex A, as modified by the following description. Starting at the entrance to the train, the devices are, in order: manual shut off valve, filter, pressure gage, pressure regulator (if required by burner furnished), low pressure switch, high pressure switch, meter (if specified), oil flow control valve, thermometer, valved drain, automatic safety shut off valve, valved leak test, automatic safety shut off valve, valved leak test, manual shut off valve, pressure gage, burner.
2. Filter: Permanent edge-type elements, cleanable by rotation of a handle without interruption of flow. Filter element spacing 0.1 mm (0.0035 inch). Pressure rating shall exceed upstream safety relief valve set pressure plus accumulation. Maximum pressure loss 20 kPa (3 psi) at high fire. Provide plugged drain. Temperature rating 120 °C (250 °F) on heated oil service.
3. Automatic Safety Shut-Off Valves:
 - a. Type: Motorized-opening, spring closing, controlled by burner control system. Two 2-way valves required on No. 2 oil service; one 3-way and one 2-way required on heated oil service.
 - b. Service: Provide open-shut control of fuel flow to burner. Valves shall shut bubble-tight and be suitable for operation with upstream pressure exceeding upstream safety relief valve set pressure plus accumulation. Temperature rating 250 °F on heated oil service.
 - c. Performance: Timed opening of eight seconds or less to safely and smoothly ignite oil burner, one-second closure.
 - d. Construction: Threaded ends, valve position indicator visible from front or side of boiler. Proof of closure interlock switch on each valve. Provide non-latching push button switch in proof of closure circuit to interrupt circuit for testing.

- e. Approval: FM approved, UL listed for burner service.
- f. Provide 9.5 mm (3/8 inch) relief valve on piping between safety shut-off valves, 1375 kPa (200 psi) rating, tight shut-off. Set pressure lower than pressure rating of safety shut-off valves. Provide valved leak-test connections between the two safety shut off valves and after the second safety shut off valve.

4. Pressure Switches

Set points shall be as required by the burner manufacturer. If there are no requirements, the set points shall be within 50% of the controlled pressure.

5. Fuel Flow Control Valve:

- a. Type: Throttling, controlled by combustion control system. Valve with adjustable characterization cam required for single point positioning control systems.
- b. Performance and Service: Control fuel flow in exact proportion to combustion airflow over the entire firing range of the burner. Pressure rating shall exceed oil pump safety relief valve pressure setting plus accumulation.
- c. Construction: If provided, characterization cam shall be shaped by at least twelve adjustment screws.
- d. Option: Burner manufacturer's standard fuel flow control system may be utilized for single point positioning systems if it has an adjustable characterization feature equal to the flow control valve specified.

6. Oil Guns and Nozzles: On steam atomizing systems, provide two special nozzles if necessary for cold start on compressed air atomization. Provide special guns if nozzles do not fit guns furnished for steam atomizing nozzles.

7. Provide oil pump arranged and piped to provide automatic drainage of oil gun when burner is shut down manually. Not required when oil gun is less than 600 mm (2 feet) long.

8. Pressure Gages, Thermometers, Flow Meter:

9. Boiler/Burner-Mounted Oil Pump and Relief Valve: Do not provide. House pumps are provided that include relief valves.

H. Steam Atomizing Valve and Piping Train (with Compressed Air for Cold Start):

- 1. Steam/Air Selection: Provide flexible hose or three-way valve to permit selection of steam or compressed air. Refer to Section 23 21 11, BOILER PLANT PIPING SYSTEMS. Hose connections or three-way valve shall be within 1800 mm (6 feet) of the floor.
- 2. Differential Pressure Control Valve:

- a. Type: Spring loaded, diaphragm-actuated, controlled by oil pressure at burner.
 - b. Service: Provide control of steam or air pressure to the oil burner. Base valve size on steam and air pressure available at valve inlet. Valve body shall be rated for 1375 kPa (200 psi) steam pressure.
 - c. Performance: As required by burner.
 - d. Construction: Cast iron body, stainless steel trim, double stainless steel diaphragms with vented space between to separate oil and steam or air.
3. Pressure Switches:
4. Shut-Off Valve:
- a. Type: Motorized or solenoid opening, spring closing, controlled by burner control system.
 - b. Service: Provide open-shut control of atomizing media flow to burner. If solenoid valve requires a minimum differential pressure for operation, coordinate pressure requirements with available pressures. Valve body shall be rated for 1025 kPa (150 psi) steam, dead-end shut-off.
 - c. Approval: UL listed.
- I. Low Pressure Air Atomizing System:
- 1. Complete system for each burner, furnished by burner manufacturer, including compressor and drive, air filter, after cooler, low pressure switch and all piping systems. Where compressor is driven by separate motor and coupling drive system, provide all equipment including motor, coupling, compressors, starter, wiring and protection.
 - 2. Motor:
 - 3. Motor Controls: Provide motor starter in NEMA 4 enclosure for burner management control interlock proving power supply to motor.
 - 4. Shaft couplings: All metal, flexible.
 - 5. Sound Attenuators: Provide compressor enclosure, air intake silencer, or other means to reduce sound levels to those required. Gages and Pressure Switches:
- J. Igniter (Pilot) Fuel Valve and Piping Train, Burner and Ignition System:
- 1. Arrangement: Comply with typical arrangement in NFPA 85, Annex A, as modified by the following description: Arrange the system to allow selection of either natural gas or propane for the ignition fuel. Provide separate piping with plug valve, pressure gage, filter and pressure regulator for natural gas and for propane. Connect to the main burner natural gas service downstream of the main burner

- pressure regulator. Join the natural gas and propane services by means of a three-way plug valve. Continue with one pipe line including a low pressure switch, pressure gage, automatic safety shut off valve, automatic vent, automatic safety shut off valve, igniter.
2. Filters: Replaceable elements, five micron or smaller particle retention. Static pressure capability two times the maximum lockup pressure of nearest upstream pressure regulator. Maximum pressure loss, at full flow, 1.3 kPa (5 inches water column). Provide unions for filter removal.
 3. Pressure Regulators:
 - a. Type: Single-seated, diaphragm-operated. Provide separate regulators for natural gas service and for LP gas service. (Refer to the schematic diagrams shown on the drawings).
 - b. Service: Provide controlled pressure in igniter train as required by igniter, with upstream pressures as shown or specified. Inlet and outlet emergency pressure rating shall be at least twice the lockup pressure of the nearest upstream pressure regulator. As an alternate to the outlet emergency pressure rating, provide internal relief valve vented to outside set at pressure that will avoid overpressure on regulator outlet that could damage the regulator.
 - c. Performance: Lockup pressure shall not exceed 1.5 times the regulated pressure.
 - d. Construction: LP gas regulator must be designed for 1725 kPa (250 psi) maximum pressure.
 4. Automatic Safety Shut-Off and Vent Valves:
 - a. Type: Solenoid-type, two normally closed shut-off valves and one normally-open vent valve, arranged as shown, controlled by the burner control system. Provide threaded leak-test ports with threaded plugs on each shut-off valve body.
 - b. Service: Provide open-shut control of fuel flow to igniter and vent between shut-off valves. Design for 140 kPa (20 psi) differential at shut-off.
 - c. Approval: Safety shut-off valves UL listed, FM approved for burner service. Vent valves UL listed for burner service.
 5. Vent System Manual Plug Valve for Leak Tests: Located on vent line on outlet side of automatic vent valve. Provide locking device and lock wrench to lock valve to open position. Provide cylinder padlock keyed to VA Engineering key. Provide valved leak test connections between automatic vent valve and plug valve and ahead of the automatic vent valve.

6. Igniter and Ignition System: Provide removable igniter, ignition electrodes, ignition transformer, high voltage cable. Provide shield at ignition area so that spark is not visible to ultraviolet (if provided) flame scanner from any position on its mounting.
7. Igniter fuel train pipe and fittings: ASME B31.1 requirements do not apply. Refer to Section 23 21 11, BOILER PLANT PIPING SYSTEMS.

2.5 BURNER MANAGEMENT CONTROL (FLAME SAFEGUARD) SYSTEM AND ACCESSORIES:

- A. Control Panel: Controls shall be mounted in free standing NEMA 4 enclosure. There shall be no power wiring in this enclosure.
- B. Factory Testing: Install controls on boiler and burner at factory and test operation of all devices.

2.6 FLUE GAS ECONOMIZER:

- A. Heat exchangers to transfer heat from boiler flue gases to boiler feedwater.
- B. Type: Rectangular configuration, replaceable finned tubes, up flow flue gas, parallel flow water, insulated casing with removable panels allowing access to all tubes for cleaning and replacement. Arrange tube to permit lane-type soot blowing.
- C. Performance: Refer to schedules shown on the drawings. Coordinate input flue gas temperatures with data from boiler manufacturer.
- D. Construction:
 1. Comply with ASME Boiler and Pressure Vessel Code, Section I. Design unit to permit operation with no water in the tubes at the temperature listed below.
 2. Design Pressure:
 - a. Water tubes, 2050 kPa (300 psi) minimum.
 - b. Inner casing, 2.5 kPa (10 inches water column) minimum.
 3. Design temperature 370 °C (700 °F) minimum.
 4. Tubes: ASTM A269 Type 316 stainless steel tubing. Helical-wound non-serrated Type 316 fins continuously welded to tubes. Headers of Type 316 seamless carbon steel tubing, Schedule 40 minimum. 2050 kPa (300 psi) flanged piping connections. Gravity drainage. Return bend areas shall be exposed to the bulk temperature of the flue gas. Headers shall be external to the casing. Fin density shall not exceed 157 fins per meter (48 fins per foot). Maximum fin height 13 mm (0.5 inches).
 5. Casing: Inner and outer casing with insulation between. 80 mm (3 inch) angle flanges on flue gas inlet and outlet for attachment of breeching and stack.

- a. Inner Casing, 3.5 mm (10 gage) thick Type 316 stainless steel, all welded. Stainless steel angles for breeching attachment to casing. Entire casing system must be gas tight.
 - b. Insulation: Mineral fiber, ASTM C612, 50 mm (2 inches) thick.
 - c. Outer Casing: Galvanized or painted steel, 0.4 mm (27 gage) thick.
 - d. Access and Inspection Openings: Insulated, 400 mm (16 inches) square minimum.
6. Design to permit field replacement of tubes without removing unit from stack. Provide bolted access doors for tube replacement.
- E. Accessories:
- 1. Safety Relief Valve: Valve designed for steam and water service, ASME - National Board certified, selected by economizer manufacturer in accordance with ASME Code requirements. Set pressure 1900 kPa (275 psi) gage.
 - 2. Soot Blowers: Steam-operated, rotating valve-in-head. Provide sufficient number of blowers to clean all tube areas. Location, arrangement and quantity based on recommendations of soot blower manufacturer for type and size of economizer furnished. Soot blowing shall be lane-type.
 - 3. Inlet and Outlet Transitions: Designed and furnished by economizer manufacturer.
- F. Factory Test and Inspections: Inspect the completed economizer assembly in accordance with the ASME Boiler and Pressure Vessel Code, Section I. Certify the inspection and submit four copies of the completed ASME Form P-3 for each economizer.

2.7 TOOLS:

- A. Oil Burner Vise and Wrenches: Deliver to the Contracting Officers Technical Representative (COR)/Resident Engineer (RE) for mounting by VA personnel. Furnish only if burner requires wrench not found in commercial hardware store.
- B. Device for Hanging Oil Burner Guns: Space for total number of guns furnished. Deliver to the COR/RE for mounting by VA personnel. Furnish only if oil gun must be removed from burner when firing gas.
- C. Burner throat sweep to provide proper shape for reconstruction of castable refractory throats. Not required for throats made of preshaped tiles.

2.8 SPARE PARTS

- A. Fuel Trains:
 - 1. One assembly of electrodes, transformer, and high voltage cable with end connectors for the igniter.

2. One of each type and size of main and pilot fuel motorized and solenoid automatic safety shut-off valves and automatic vent valves.
3. One atomizing steam admission solenoid valve.
4. Complete set of filter elements and gaskets for each gas filter for each boiler.
5. Complete set of all gaskets for each edge-type oil filter for each boiler.

B. Boiler, Burner, Trim, Feedwater Control Valve:

1. Drum handhole gaskets, three complete sets for each boiler.
2. One clear lens and one tinted lens for each furnace and burner observation port on each boiler.
3. Sufficient glass inserts and gaskets to re-equip all water level gage glasses on one boiler.
4. One set of drive belts for each belt-driven apparatus on each boiler.
5. One gallon oil for burner-mounted atomizing air compressors.
6. If cast refractory plug is utilized for furnace access, provide sufficient refractory material to rebuild one plug for each boiler.
7. One set of all gaskets for each type of oil gun.
8. One oil gun and nozzle of each type and size utilized.
9. Valve and actuator complete for electrically-operated feedwater control valve.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Boiler, Burner and Economizer Access Openings: Arrange all equipment and piping to allow access to openings without disassembly of equipment or piping.
- B. Soot Blower Element Position: Adjust so that nozzles do not blow directly on tubes.
- C. Drainage Facilities for Boiler Water Column, Gage Glass, Low Water Cutoffs, Water Level Alarms:
 1. Refer to Articles, BOILER and BOILER TRIM. After individual drain valves, combine all drains into one pipe with a sight flow indicator, gate valve and check valve. Pipe to boiler blowoff line.
 2. Locate and orient sight flow indicator on common drain line so that one person can view the fluid flow while simultaneously operating drain valves and low water cutoff shunt switch.
- D. Boiler Drum Level Transmitter for Feedwater Regulator System:
 1. Provide three-valve isolation and equalizing system rated for 1035 kPa (150 psi), 182 °C (360 °F).

2. Provide valved drain on all level sensing lines. Connect to water column drain system upstream of sight flow indicator.
- E. Boiler Casing Flashing: Flash or seal all pipe penetrations in casing at steam drum to prevent leakage of water into boiler insulation.
- F. Air and steam hose connections for selection of atomizing media shall be within 1800 mm (6 feet) of the floor.

3.2 CLEANING AND PROTECTION FROM CORROSION

A. Boiler Cleaning:

1. Upon completion of installation, the initial firing of the burner shall be performed to boil out, under supervision of boiler manufacturer, all internal surfaces with chemical solution recommended by boiler manufacturer, to remove all mill scale, corrosion products and other foreign material. Following boil out, boiler shall be washed and flushed until water leaving the boiler is clear. Inspect internal surfaces for cleanliness. Then, drain and refill boiler with softened and treated water or place boiler in dry storage as specified below.
2. Refer to the paragraph at the end of PART 3, Article, INSPECTION AND TESTS "Internal Inspection of Pressure Parts and Furnace", for the requirements for cleaning the boiler after the operational tests are completed.

B. Protection from Corrosion:

1. Protect the boilers from fireside and waterside corrosion at all times.
2. Dry Storage: When the boilers are not filled with water, protect the watersides and firesides with a dry storage method recommended by either the boiler manufacturer or the ASME Code, Section VII.
3. Wet Storage: If, after water is placed in the boilers, they are not fired for equipment adjustment or testing for more than two weeks, the boilers shall be protected with a wet storage method recommended either by the boiler manufacturer or the ASME Code, Section VII. If boilers are not fired for equipment adjustment and testing for more than one month, drain the boilers and place in dry storage.
4. Chemical Treatment: The quality of the water in the boilers shall be maintained by a professional water treatment organization. This organization shall provide on-site supervision to maintain the required water quality during periods of boiler storage, operating, standby and test conditions. Furnish monthly reports, by the water treatment organization, to the Resident Engineer (RE). The Contractor shall provide all chemicals, labor and professional services until the boilers have been accepted by the Government for operation. All

chemicals utilized must conform to FDA Regulation CFR 21, 173.310, guidelines applicable for steam used in food preparation.

3.3 INSPECTIONS AND TESTS

- A. The following tests and demonstrations, except pretests, must be witnessed by the RE or their representative and must prove that boilers, economizers, burners, controls, instruments, and accessories comply with requirements specified. When test results are not acceptable, corrections must be made and the test repeated at no additional cost to the Government. Pretests do not require the presence of the RE.
- B. Condition of Boiler and Economizer (if provided) After Delivery, Rigging, Placement: After setting boiler on foundation and placing economizer on supports, and prior to making any connections to boiler and economizer, Contractor and RE jointly will inspect interior and exterior for damage. Correct damage by repair or replacement to achieve a like new condition. After completion of repairs, perform air pressure test of the boiler casing. The Contractor shall conduct these tests at no cost to the Government.
- C. Hydrostatic Tests:
 - 1. Boiler, Economizer (if provided): Conduct tests after the equipment is installed and connected for operation and prior to initial firing. Contractor shall provide inspector certified by National Board of Boiler and Pressure Vessel Inspectors (NB). Test pressure shall be 150% of the design pressure of the boiler held for a period required by the inspector. Provide written certification of the satisfactory test, signed by the inspector. Correct any deficiencies discovered during the testing, and retest equipment until satisfactory results are achieved and are accepted by the inspector.
 - 2. Boiler External Piping (as defined by ASME B31.1, Power Piping):
 - a. Refer to Section 23 21 11, BOILER PLANT PIPING SYSTEMS.
 - b. Test may be conducted concurrently with boiler and economizer testing.
 - 3. Identify and remove any connecting equipment which is not rated for the test pressure. Cap the openings left by the disconnected equipment. Reinstall the equipment after the tests are complete.
- D. Boiler Steam Safety Valves:
 - 1. Test each safety valve set pressure and blowdown pressure with boiler steam pressure. Perform accumulation test to verify that safety valves have sufficient capacity to relieve full boiler output at maximum firing rate of burner. Tests shall be performed with boiler isolated from the main steam header and all generated steam exhausting through the safety valves.

2. Valve Popping Tolerance: Plus or minus three percent of set pressure for set pressures over 480 kPa (70 psi).
 3. Valve Blowdown Tolerance: Reset at not less than six percent below set pressure of valve with the lowest set pressure. Minimum blowdown two percent of the set pressure.
 4. Accumulation Test: With burner at high fire, the boiler pressure shall not rise more than six percent above the set pressure of the safety valve with the highest pressure setting and no more than six percent above the maximum allowable working pressure of the boiler.
 5. Make repairs and adjustments in manner recommended by National Board (NB) Inspection Code, NB-23. Retest valves after completion of repairs and adjustments.
- E. Burner Management Control (Flame Safeguard) System:
1. Experienced personnel representing the manufacturer of the system shall conduct the tests.
- F. Performance Testing of Boiler, Burner, Economizer, Combustion Control, Boiler Plant Instrumentation, Computer Workstation (if provided):
1. Perform tests on each boiler on all main burner fuels.
 2. If required by local emissions authorities, provide the services of a testing firm to determine the NO_x and carbon monoxide at boiler loads as required by the emissions authorities. Test firm shall be acceptable to emissions authorities.
3. Test No. P-1:
- a. Operate boiler on each fuel, with economizer (if provided) in service, and record data for at least six evenly spaced steam outputs between low fire start and 100 percent of full steam output, and in the same sequence back to low fire. Demonstrate performance required by paragraphs under the Article, BURNER AND FUEL TRAINS and ECONOMIZER in Part 2 and by boiler and economizer equipment list shown on the drawings.
 - b. Demonstrate proper operation of combustion controls, draft controls (if provided), feedwater level controls, instrumentation and computer workstation programming (if provided).
 - c. When flue gas oxygen trim is provided, conduct tests with trim control on manual at the zero trim (null) position.
4. Test No. P-2:
- a. Demonstrate sound level of burner system and atomizing air compressor (if provided).
 - b. Test point shall be at pre-purge, and firing at 100 percent of maximum boiler load.

5. Test No. P-3:
 - a. Check current draw of forced draft fan motor at pre-purge and at 100 percent of maximum boiler load with combustion air control at maximum position.
 - b. Current draw shall not exceed full load current stamped on the motor nameplates.
 - c. This test may be combined with Test No. P-1.
6. Test No. P-4: Operate boiler on both fuels, flue gas oxygen trim in service on automatic control, and record data at a minimum of 6 evenly spaced steam output points between low fire start and full steam output and in the same sequence back to low fire.
7. Test No. P-5: Operate boiler on one fuel, flue gas oxygen trim in service on automatic control, and record data at the following load points: Low fire start, 13, 20, 40, 60, 80, 100, 80, 60, 40, 20 and 13 percent of full steam output.
8. Test Methods:
 - a. Utilize permanent instrumentation systems for data. All instrumentation systems and computer workstation (if provided) shall be operational and in calibration.
 - b. Provide portable thermocouple pyrometer furnished and retained by the Contractor to measure stack temperature as a verification of permanent stack temperature instrumentation.
 - c. Use portable electronic flue gas analyzer furnished by Contractor to determine constituents of flue gas and stack temperature. Analyzer shall be capable of measuring oxygen in percent with accuracy of plus or minus 0.5 percent and carbon monoxide in parts per million (ppm) with accuracy of plus or minus 5 percent of reading (Range 0-1000 ppm). Obtain oxygen and carbon monoxide readings at each test point. Instrument shall have been calibrated with certified test gases within three months prior to use and immediately after cell replacement.
 - d. In Test Nos. P-1, 2 and 5 P, retain boiler at each load point for a time period sufficient to permit stabilization of flue gas temperature and other parameters.
 - e. Steam loads for test may be furnished by the VA Medical Center hospital systems, by operation of the steam silencer vent system, or by a combination of the above. If variable hospital loads interfere with the testing, conduct tests at night or on weekends when the loads are more stable.
 - f. Provide dry bulb and wet bulb thermometers furnished and retained by Contractor for checking combustion air.

- g. Smoke testing shall be by visual observation of the stack and by smoke density monitor (permanent instrument - if provided). If smoke density monitor is not provided, utilize Bacharach Model 21-7006 Smoke Test Kit. If there is disagreement with the results of these tests, provide qualified observation person and tests in compliance with EPA Reference Method 9 (CFR 40, Part 60, Appendix A).
 - h. Sound level instruments will be Government furnished.
 - i. NO_x emissions shall be tested with electronic analyzer reading in parts per million. Analyzer shall be calibrated at with certified test gas within three months prior to use and immediately after cell replacement. Analyzer shall be accurate to plus or minus 5 percent of reading.
9. Pretesting:
- a. Perform pretest at the final stage of the burner fine-tuning process.
 - b. Prior to scheduling final test, submit evidence of pretest. Evidence shall consist of data sheet signed and dated by personnel representing burner manufacturer, combustion controls manufacturer, burner controls manufacturer.
 - c. Pretest data sheets shall list the following data for each fuel and each screw on the fuel flow valve characterization cam starting at the minimum position, proceeding to the maximum position and returning to the minimum position.
 - 1) Fuel valve screw number or actuator position.
 - 2) Steam flow rate (at minimum, 50 percent, maximum firing position only).
 - 3) Steam pressure: At boiler drum, and at header (at minimum, 50 percent, maximum firing position only).
 - 4) Fuel Pressures: At burner and also upstream of fuel flow control valve.
 - 5) Fuel temperature (heated oil only).
 - 6) Fuel flow rate.
 - 7) Boiler feed pressure, upstream of feedwater regulator (at minimum, 50 percent and maximum firing positions only).
 - 8) Boiler feed temperature (at minimum, 50 percent, maximum firing positions only).
 - 9) Stack temperature: Boiler outlet, economizer outlet.
 - 10) Flue gas oxygen and carbon monoxide (utilize instrument which has been calibrated with certified test gases).
 - 11) Flue gas NO_x (if limit specified).

- 12) Percent excess air.
- 13) Opacity of flue gas.
- 14) Submaster position.
- 15) Flame shape: Note and describe any flame contact with refractory or heating surface.
- 16) Combustion air temperature-dry bulb and wet bulb.
- 17) Barometric pressure (one reading).

d. Calibrate all pressure gages prior to the pretest.

G. Capacity - Efficiency Test of Boiler and Burner:

- 1. Perform test on one of each size boiler in the project, selected by RE, on all main burner fuels.
- 2. Test No. E-1: Test boiler on each fuel, with no water in economizer (if provided), at full load. Demonstrate performance required by paragraphs under the Article, BOILER in Part 2 and by boiler equipment list shown on the drawings.
- 3. Test Methods:
 - a. Conform to ASME Performance Test Code PTC 4.1. Use abbreviated input-output and heat balance methods. Utilize ASME Test Forms PTC 4.1-a, 4.1-b.
 - b. Test Meters and Instruments:
 - 1) Feedwater Flow Meter: Vortex or turbine-type, totalizing in increments, pressure rating exceeding feed pump no flow shut-off pressure, temperature rating exceeding normal feedwater temperature, calibrated immediately prior to test by independent laboratory. Calibrate at three points, ten percent above, ten percent below, and at the required flow rate at high fire. Furnish calibration data. Remove meter from the line and deliver to RE after tests are accepted.
 - 2) Fuel Oil Flow Meters: Displacement type, totalizing, smallest reading one liter (one gallon), pressure rating exceeding oil pump safety relief valve set pressure plus accumulation, 120 °C (250 °F) (if heated oil), calibrated immediately prior to test by independent laboratory. Calibrate at three points: Ten percent above, ten percent below, and at the required flow rate at high fire. Furnish calibration data. Remove meter from the line and deliver to RE after tests are accepted.
 - 3) Natural Gas Flow Meter: Utilize permanent meter serving boiler plant.
 - 4) Steam Calorimeter (for measuring steam quality): Throttling, U-path, temporary instrument, furnished and retained by

Contractor, with thermometer that has been calibrated immediately prior to test. Provide one spare calibrated thermometer.

- 5) Portable electronic flue gas analyzer as specified for the performance testing.
- 6) Thermocouple Pyrometer (for measuring flue gas temperature): Temporary instrument furnished and retained by Contractor, 100 - 400 °C (200 - 800 °F) range, automatic ambient temperature compensation.
- 7) Thermometers: Utilize contractor-furnished and retained temporary thermometers and permanent thermometers to measure fuel and air temperatures. All must be calibrated immediately prior to test. Furnish calibration data.
- 8) Pressure Gages: Utilize permanent gages. Calibrate each gage immediately prior to test. Furnish calibration data.
- 9) Plant Instruments and Computer Work Station (if provided): Must be calibrated, programmed and in proper operation.

- c. Fuel Analyses: The Government will furnish analysis of natural gas. The Contractor must obtain an ultimate type analysis of fuel oil prior to the final boiler tests. Fuel oil analysis must include heating value, specific gravity, viscosity and percent carbon, hydrogen, sulfur, ash, oxygen, and nitrogen. Test by independent laboratory.
- d. Duration of each test will be four hours after all systems and measured parameters have stabilized.
- e. Water quality in the boiler shall be checked immediately prior to the start of the tests. Solids and alkalinity must be adjusted prior to the test to conform to limits listed in Paragraph, BOILER in Part 2.

4. Pretesting: None required.

H. Internal Inspection of Pressure Parts and Furnace:

1. After all operational tests are satisfactorily completed, a Government retained licensed boiler inspector will determine if the boiler is free from corrosion and any other type of damage or defect.
2. In preparation for the inspection, open all drum handholes and the furnace access opening, drain and clean the interior of all pressure parts and clean all soot and debris from the furnace.
3. Any corrosion, damage or defect shall be corrected to a like new condition in the judgment of the boiler inspector.
4. Hard carbonaceous deposits on heating surface or refractory are evidence of flame impingement and are not permitted. Remove all

- deposits, make corrections to burners and provide complete retest of boiler and burner performance.
5. After the boiler inspector has approved the boiler, all handholes and furnace access openings shall be closed with new gaskets.
 6. Hard carbonaceous deposits in the furnace are evidence of flame impingement. Within one year after acceptance of the boiler for Government operation, the Government will inspect the furnace for the carbonaceous deposits. If deposits are present, the Contractor shall remove them. If tubes or refractory are damaged, the Contractor shall replace them to achieve a like new condition. The Contractor shall make corrections to burners to eliminate the conditions that have caused the problems and shall provide complete retest of boiler and burner performance.
- I. Report: Furnish complete written report (three copies) that includes test data, calculations, results compared with requirements, list of personnel, and other pertinent information. Furnish report within three weeks after completion of tests.

3.4 STARTUP AND TESTING

- A. The Commissioning Agent will observe startup and contractor testing of selected equipment. Coordinate the startup and contractor testing schedules with the Resident Engineer and Commissioning Agent. Provide a minimum of 7 days prior notice.

3.5 COMMISSIONING

- A. Provide commissioning documentation in accordance with the requirements for all inspection, start up, and contractor testing required above and required by the System Readiness Checklist provided by the Commissioning Agent.
- B. Components provided under this section of the specification will be tested as part of a larger system.

3.6 DEMONSTRATION AND TRAINING

- A. Provide services of manufacturer's technical representative for four hours to instruct each VA personnel responsible in the operation and maintenance of units.

- - - E N D - - -