



400 West Main Street

Christiansburg, Virginia 24073

Telephone: (540) 381-7999

Lead Testing for Construction

Louis A. Johnson VA Medical Center
1 Medical Center Drive
Clarksburg, WV 26301

Boiler #3 Burner Replacement Project

READING	DATE & TIME	TYPE	COMPONENT	SUBSTRATE	SIDE	CONDITION	COLOR	SITE	INSPECTOR	FLOOR	ROOM	RESULTS	PbC
1	7/31/2012 11:37	SHUTTER_CAL											2.55
2	7/31/2012 11:40	PAINT	CAL FRNT					BOILER #3	RHL			Positive	1
3	7/31/2012 11:41	PAINT	CAL BACK					BOILER #3	RHL			Positive	1
4	7/31/2012 11:43	PAINT	WALL					BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
5	7/31/2012 11:44	PAINT	WALL		B	INTACT	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	0.14 -
6	7/31/2012 11:45	PAINT	WALL		C	PEELING	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
7	7/31/2012 11:45	PAINT	WALL		C	PEELING	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
8	7/31/2012 11:50	PAINT	WALL		D	INTACT	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
9	7/31/2012 11:51	PAINT	WALL		D	INTACT	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
10	7/31/2012 11:51	PAINT	DOOR		D	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
11	7/31/2012 11:51	PAINT	DOOR FRM		D	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
12	7/31/2012 11:52	PAINT	WINDOW FRM		D	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
13	7/31/2012 11:53	PAINT	WINDOW FRM		D	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
14	7/31/2012 11:53	PAINT	DOOR		A	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
15	7/31/2012 11:54	PAINT	DOOR FRM		A	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
16	7/31/2012 12:00	PAINT	CABINET		A	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
17	7/31/2012 12:00	PAINT	CABINET		D	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
18	7/31/2012 12:02	PAINT	CEILING			INTACT	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
19	7/31/2012 12:03	PAINT	CEILING			INTACT	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
20	7/31/2012 12:09	PAINT	BURNER		C	INTACT	BLUE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
21	7/31/2012 12:09	PAINT	BURNER		C	INTACT	BLUE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
22	7/31/2012 12:19	PAINT	BEAM			INTACT	YELLOW	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
23	7/31/2012 12:19	PAINT	HANGER			INTACT	YELLOW	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
24	7/31/2012 12:33	PAINT	TANK		A	INTACT	GREY	BOILER #3	RHL	FIRST	DA TANK	Negative	< LOD
25	7/31/2012 12:42	PAINT	WALL		A	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
26	7/31/2012 12:43	PAINT	WALL		A	INTACT	WHITE	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
27	7/31/2012 12:43	PAINT	WINDOW FRM		A	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
28	7/31/2012 12:44	PAINT	WINDOW FRM		A	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
29	7/31/2012 12:49	PAINT	CAL FRNT		A	INTACT	GREY	BOILER #3	RHL	BASEMENT	CNTRL RM	Negative	< LOD
30	7/31/2012 12:50	PAINT	CAL FRNT					BOILER #3	RHL			Negative	0.9
31	7/31/2012 12:52	PAINT	CAL BACK					BOILER #3	RHL			Positive	1