

TELECOMMUNICATONS CABLING

PART 1 - GENERAL

SUMMARY

This section includes installation, testing, documentation and training for a fully functional local area network cabling system.

Furnish, Install, and Test Horizontal UTP Copper cabling, patch panels, patch cords, termination units, information outlets, respective cable termination connections, and other items necessary to "terminate" selected information outlets (IO) as shown on the Drawings.

WORK PROVIDED UNDER OTHER SECTIONS

Data cabling pathways, power wiring devices, lighting and other work related to the Local Area Network System will be provided by the Electrical Contractor unless noted otherwise.

WORK FURNISHED, INSTALLED, AND CONNECTED BY OTHER

Electronic data communication equipment is not specified under this contract.

SUBMITTALS

Submit a complete list of all proposed equipment and materials, including manufacturer's specifications and product cut sheets.

Submit a labeling scheme approved by the owner.

Telecommunications Maintenance Manual: Furnish one (1) complete Telecommunications Maintenance Manual containing the following:

1. Descriptions of network cabling equipment and normal operating procedures.
2. Riser Diagrams showing complete installed UTP and Fiber cabling.
3. Proof of Performance Report outlining the operating parameters tested, complete test results, and a summary of industry standards used for each parameter.
4. Warranty information.

APPLICABLE PUBLICATIONS, STANDARDS, CODES, TESTING LABORATORIES, GUIDELINES

ANSI/EIA/TIA Standard 568B.1, 568B.2, AND 568B.3

ANSI/EIA/TIA Standard 569

ANSI/EIA/TIA Standard 606

ANSI/EIA/TIA Standard 607

Technical Service Bulletins TSB-36, TSB-40, TSB 67

NFPA 70 National Electrical Code.

Provide products specified in this section that are listed and labeled.

5. The terms "listed" and "labeled": As defined in the "National Electrical Code", Article 100.

GUARANTEES AND WARRANTIES

Guarantee system, in writing, against defects in workmanship and associated material not covered by cabling system warranty, for one year after final acceptance. During this time, the entire system shall be kept in proper operating condition at no additional labor or material cost to the Owner.

The manufacturer of the major components shall maintain a replacement parts department and provide test equipment when needed. The parts department shall be located in a geographical proximity consistent with rendering service within the stated period of time. An ample stock of individual components and equivalent unit replacement shall be carried for as long a period as demand warrants. This period shall extend beyond the normal life expectancy of the equipment.

QUALITY ASSURANCE

Contractor shall be currently licensed to install low-voltage cabling systems in the state of Minnesota.

Contractor shall meet manufacturer's requirements for the provision and installation of specified equipment.

Contractor shall provide proof of certification as a structured cabling system installer for the system provided under this bid.

Contractor shall utilize the following test equipment and shall have operators trained for use of such equipment:

6. Copper Cable Test Equipment:
 - a. Fluke / MicroTest (level 3 tester)
 - b. Agilent WireScope 350 (level 3 tester).
 - c. Prior approved equal.
7. Fiber Optic Cable Test Equipment:
 - a. Approved OTDR.
 - b. Approved OLS/OPM.

PROJECT/SITE CONDITIONS

Examine areas and conditions under which the system is to be installed, and notify COTR in writing of conditions detrimental to proper completion of the work. Do not proceed with that portion of the work affected until unsatisfactory conditions have been corrected in an acceptable manner.

MANUFACTURER

Subject to compliance with specified requirements, provide specified materials, or prior approved equal to the referenced products included for the design of the Local Area Network Cabling system.

UPGRADED PRODUCTS

Due to the fast-changing technology, products shall be the most current and up-to-date quality and labor-saving versions available for the application, unless otherwise restricted.

Prior to bidding, provide written notification of any discrepancies in model or part numbers specified. Corrections will be clarified by addendum.

Prior to bidding, provide written notification to COTR of announced discontinuation or upgrade replacements of specified materials.

Provide necessary supplies, mounting hardware and accessories required to install specified materials.

PRODUCT SUBSTITUTION

No manufacturer substitutions will be allowed for the structured cabling system.

MANUFACTURER'S CERTIFICATION

Manufacturer of cabling products shall be ISO9001 Certified.

UTP COPPER CABLE LENGTHS, TERMINATIONS, MARKINGS

Copper Cable runs shall be compliant with EIA/TIA recommended lengths: Horizontal cables shall not exceed 295 feet. Cable runs shall be continuous with no allowance for splicing.

For construction on Sioux Falls VAMC Campus: Copper cable Eight-Position Jack Pin/Pair Assignments shall match the VA Hospital's existing facilities. Coordinate with the owner prior to installation.

PART 2 - PRODUCTS

MANUFACTURERS

Manufacturers: Subject to compliance with requirements, provide a certified structured cabling system by: General Cable or approved equal.

Data/ Voice Cable: Part Number 7131688, Cat 6, **blue.**

For this project all cable will be CAT 6

EQUIPMENT RACK:

Rack: Free-standing, 19"Wx84"H, self-supporting rack. Leave enough room to walk behind the rack.

CABLE SUPPORT

Supply velcro straps, length and strength as required to properly organize and bundle cables. Vinyl/plastic tie wraps are prohibited throughout

Install cables in conduit and wireway systems provided by the Electrical Contractor. Coordinate with the Electrical Contractor for specific requirements.

CATEGORY 6 CHANNEL

The Category 6 - 4 pair UTP channel consists of all cable and components with up to four connections that comprise the full 100 meter circuit from the LAN Electronics to the work station device. The channel shall support applications such as 10Base-T, 100Base-T, 155 Mbs ATM, 77 channel broadband video, 1.0 Gbps Ethernet, 1.2 Gbps, and proposed 2.4 Gbps ATM technologies.

The channel shall include the patch panels, horizontal cabling, and the station cord, and shall have a positive PSACR across the full frequency range of 1MHz - 250MHz.

All components shall be backward compatible with existing Category 3, and 5 networks.

The cabling channel with specified manufacturers above shall exceed Category 6 requirements.

INFORMATION OUTLETS

Activations: 2, 4, or 6 outlets will be required at each location shown on the plans with tabs down.

Modular Faceplates: Ivory, smooth nylon, UL rated 94V-0 high impact, flame-retardant, thermoplastic, integral label card and cover, sized as follows:

1. Data information outlets: Devices shown on plans as data information outlets shall be four position faceplates. Panduit 4 position face plate Part Number CFP4E1Y.
2. Telephone information outlets: same as data.

Modular Information outlets: Modular single information outlet designed for high-performance networking applications. Panduit gigaspeed information outlet:

3. Data outlet Cat 6 Blue 568B: Panduit CJ688TPBU

Minimum electrical requirements:

4. Insulation resistance: 500 MΩ minimum
5. Dielectric withstand voltage 1,000 VAC RMS, 60 Hz, minimum contact-to-contact and 1,500 VAC RMS, 60 Hz minimum from any contact to exposed conductive surface.
6. Contact resistance: 20 MΩ maximum
7. Current rating: 1.5A at 68 degrees F per IEC Publication 512-3, Test 5b

Dust Cover/Blank: Contractor shall provide dust covers for each outlet as required to close all faceplate openings. Panduit PN: CMBEI-X

Where data/voice jacks are fished into a hollow wall space without a raceway, Arlington LV-1 or approved equal shall be used. Metal types such as Caddy brand are not allowed.

MODULAR PATCH PANELS

Furnish and install Modular Patch Panels, Panduit CP24BLY. The panels shall be 19-in. wide for rack mounting. The panels shall accommodate Panduit CJ688TPBU Cat 6 Blue 568B Data Jack, All cables shall be secured to the strain relief bar Velcro tie wraps. Provide labeling strip above each jack. Contractor shall be responsible for sizing the modular patch panels according to the following specifications:

8. Number of Modular Patch Panel Ports shall be 125 percent of the total number of terminated information outlets required for the VRT project.
9. Patch panels will be 24 port or 48 port.

HORIZONTAL UTP CABLE

Furnish and install copper Unshielded Twisted-Pair (UTP) horizontal cable as follows:

10. General Cable Cat6, plenum rated, 24 AWG bare solid copper conductors. The cable shall conform to UL Type CMP listing for plenum and riser applications.
11. Each cable sheath shall contain 4 pairs of unshielded copper twisted-pairs with each pair having a different twist ratio of 12 to 24 twists per foot. Each pair shall be separated by a pair isolator.
12. The cables shall exceed the requirements of:
 - a. EIA/TIA 568B Commercial Building Wiring Standard Horizontal Cable Section for category 6.
 - b. Plenum - UL 910, CMP.

13. Provide colors for each defined system as follows: Blue

FIBER OPTIC CABLE:

Fiber optic cable shall be (12 strands) (6 pair) of multi-mode fiber.
Provide fiber with the following optical characteristics:

1. Multi Mode:

850nm:	Maximum Attenuation	3.5 dB/km
1300nm:	Maximum Attenuation	1.5 dB/km
850 nm	Minimum Bandwidth:	1500 MHz/km
1300 nm	Minimum Bandwidth:	500 MHz/km
2. Supports 10Gb/s Ethernet using 850nm VCSEL to 300m.
3. Fiber tension rating - 600 lbs.
4. Fiber minimum bending radius during installation - 20 x diameter.
5. The fiber cable shall meet the following technical specifications:
 - a. Multi-Mode Fiber Dimensions: 62.5 micron core
125 micron cladding
250 micron coating
900 micron buffering
6. Fiber Identification: Individually color-coated PVC buffer.
7. Buffer Material: Plenum PVC
8. Jacket Material: Plenum PVC (color: Orange).
9. Strength Material: Aramid Yarn
10. Operating Temperature: 0 to + 50 deg. C
11. Storage Temperature: -40 to +70 deg. C
12. Fiber should be run in orange 1" interduct plenum, to protect the fiber.
13. EIA Fiber Cable tests:

<u>TEST</u>	<u>REFERENCE</u>
Impact	EIA-RS-455, FOTP-25
Compression	EIA-RS-455, FOTP-41
Flexure	EIA-RS-455, FOTP-104
Tensile Bending	EIA-RS-455, FOTP-33
Temperature Bending	EIA-RS-455, FOTP-37
Twist Testing	EIA-RS-455, FOTP-85
Flame Test (OFNP)	UL 910 (NEC) [CSA OFN-FT4, FT6]

FIBER TERMINATION UNITS:

Furnish and install Panduit FRME1 front access sliding shelf connector panel equipped with SC couplings and cover plate for all Data racks. Units shall provide top or bottom cable entry, fiber termination, cross connection, interconnection, routing, fiber identification labels, and fiber storage and radius organizers.

Voice Backbone Cable

Provide and install UTP CAT 3 Solid 100 Pair for closet to closet use. Owner will provide all required 66 blocks for termination

PART 3 - EXECUTION

GENERAL

Install equipment and components in accordance with manufacturer's written instructions, in compliance with NEC, and with recognized industry practices. Ensure that all work complies with specifications and serves the intent of the construction documents. Cabling and equipment shall be installed in accordance with good engineering practices as established by the EIA/TIA and the NEC.

INSTALLATION

Cabling - General:

1. Provide dedicated horizontal cable runs from data closets to all "terminated" information outlets as described above and indicated on the Drawings.
2. Provide faceplates for all data and voice information outlets.
3. Where data or voice outlets are shown on plans, this Contractor shall provide jack termination, faceplate, and cabling.
4. Provide Modular Information Outlets in outlet boxes for all "terminated" data information outlets.
5. Excess cable behind faceplate connections shall be pulled back into ceiling spaces and secured in such a manner as to prevent damage to cabling or connections.
6. A minimum 10 foot loop of extra horizontal cable shall be secured in the accessible ceiling space.
7. Tighten connectors and terminals, including screws and bolts, in accordance with equipment manufacturer's published torque tightening values for equipment connectors.
8. Avoid excessive and sharp bends that may damage cabling. Do not exceed manufacturer's recommended pulling tensions for backbone and horizontal cables.
9. Allow sufficient slack (10 feet) in cable to prevent premature deterioration of cable system components and to assist in the maintenance and servicing of cable and/or other building systems and components.
10. Provide Cable Distribution J-Hooks as necessary to route and support cables within the data closet. All cables shall be properly supported.
11. Provide Velcro straps to bundle and organize cabling for a quality and professional installation. **Vinyl/plastic tie wraps are prohibited.** Fittings or connections are allowed only at the input and output of devices. Splicing shall not be accepted in cable runs. Spliced cable runs shall be rejected and replaced with continuous cables, prior to acceptance.
12. Separation of Wires: Comply with EIA/TIA-569 rules for separation of UTP cables from potential EMI sources.
13. All cabling outside the data closet shall be routed in conduit or wire way, installed by the electrical contractor.

B. Sleeving: All cabling penetrating a wall or floor shall be sleeved. A penetrator sleeve system and method for using same provides an encasement for wires and cables passing through a wall or floor. The system should include appropriate securing devices for tightly retaining the penetrant in place. This will also create a space between the penetrant and


surrounding structure, which must be firestopped in order to restore the fire-resistance rating of the parent assembly. The penetrant shall be one of the following;

1. EMT conduit with bushed ends.
 2. Prefabricated fire-rated pathway. Recommend the following or approved equivalent.
 - a. EZ-PATH Fire Rated Pathway
 - b. Spec Seal Ready Sleeve
- C. Firestopping: Provide firestopping after cabling installation at all fire wall/floor penetrations.
- D. Grounding: The general contractor shall be responsible for installing a ground bus adjacent to the rack. Ground all racks and cable runway to this ground bus. The contractor shall provide a #6 copper conductor from each rack/runway to the ground bus. Ground equipment per manufacturers' instructions and NEC requirements.
- E. Labeling, in accordance with VA Standards:
1. Use Owner's room numbers for labeling. Confirm room numbers with Owner's Representative prior to labeling. See attached graphical information for labeling of face plates.
 2. Utilize the following labeling scheme:


Utilize manufacturer designed labeling method at Outlet and Patch Panels. Labeling method shall be permanent and minimally susceptible to vandalism. Labels shall be permanent, and contractor shall replace fallen labels as part of the warranty.

Jack and Block Terminations as follows:

Face Plate Labeling Conventions



Wiring closet Labeling Guide



14. Label Faceplates for outlet locations. Jack numbering will begin at the first jack on the left hand wall as you enter the room and be labeled clockwise around the room. Continue the numbering sequence throughout the area served by that data closet.
15. Label patch panel terminations with the identical numbers used at the outlets.
16. Label both ends of each cabling run within 6 inches of termination points with Panduit Pan-Ty marker and flag ties, a label machine, or approved equal. Label the room end of the cable with the data closet identification number (closet number and jack number) and label the data closet end of the cable with the room jack number (room number, voice and data jack number).
17. Whenever possible, cross connect riser pairs shall be run sequentially.

COPPER CABLE TESTING

Testing of all copper wiring shall be performed prior to system cutover.

Cables shall be tested for all Category 6 100% Channel parameters using the specified level 3 tester. Test all Category 6 Channel parameters, including attenuation, NEXT, PS NEXT, FEXT, ELFEXT, return loss, and delay skew.

Faults shall be corrected and retested.

Test information along with manufacturer and model number of test equipment shall be recorded and provided to Owner as part of the project Telecommunications Manual.

Provide proof of factory calibration of test meter within 6 months of the beginning of testing.

The "** pass" option on the test meter must be set to the "on" state. The "** pass" symbol indicates a channel that is within 1 db of failing.

Provide test data in electronic format with corresponding software for viewing of testing documentation on CD-ROM provided from the test meter. Contractor shall provide one CD-ROM to Owner and one to Engineer.

Provide all cross connect information (X-Conn) to COTR.

ANY FURTHER QUESTIONS CAN BE DIRECTED TO

JOSH KOOISTRA 605-323-8356 OR MATT O'FARRELL 605-759-2598

---END---

