

A B C D E F G H J



SHEET NOTES:

1. SEE SHEET FP0.1 FOR SYMBOL LEGEND AND NOTES.
2. INSTALL ORDINARY TEMPERATURE RATED SPRINKLERS A MINIMUM OF 30 INCHES FROM THE EDGE OF SUPPLY AIR DIFFUSERS.
3. INSTALL CEILING MOUNTED SPRINKLERS IN THE CENTER OF SUSPENDED CEILING TILES.
4. DRAWINGS SHOW PROPOSED SPRINKLER LOCATIONS ONLY. COORDINATE ACTUAL LAYOUT WITH OTHER BUILDING UTILITIES AND SYSTEMS.
5. CONTRACTOR SHALL RE-USE THE EXISTING SPRINKLER PIPING TO THE MAXIMUM EXTENT POSSIBLE. ALL NEW SPRINKLER PIPING INSTALLATION SHALL BE IN ACCORDANCE WITH APPLICABLE CODES.


KEYED NOTES

- 1 EXISTING RISER AND ZONE CONTROL VALVE TO REMAIN AND FEED MODIFIED SYSTEM.

three inches = one foot
 one and one half inches = one foot
 one inch = one foot
 three quarters inch = one foot
 one half inch = one foot
 three eighths inch = one foot
 one quarter inch = one foot
 one eighth inch = one foot
 one sixteenth inch = one foot
 C:\Users\jvaugher\Documents\Projects\Shreveport VA\22 Dwg\VA-VASH-013-FP1.N1.dwg 1-09-13 12:24:17 PM sjungler

01 FIRST FLOOR - NORTH
 FIRE PROTECTION NEW PLAN
 SCALE: 1/8"=1'-0"
 0 4' 8' 16'
 1/8"=1'-0"

KEYPLAN: FIRST FLOOR



FULLY SPRINKLERED
 Scale: AS NOTED

Revisions	Date

CONSULTANTS:

The Estopinal Group
CONSULTING ENGINEERS
 820 Jordan Street, Suite 507 tel. 318.424.3700
 Shreveport, LA 71101 fax 318.424.3764

HUGHES ASSOCIATES, INC.
FIRE PROTECTION ENGINEERS
 CODE CONSULTANTS
 2121 W. Spring Creek Parkway, Suite 108
 Plano, Texas 75023 Phone: 972-491-1900

PROJECT MANAGERS AND ENGINEERS:

TNF A VETERAN OWNED COMPANY
 3 EXECUTIVE COURT, UNIT 4
 SOUTH BARRINGTON, IL 60010

Drawing Title	FIRST FLOOR - NORTH FIRE PROTECTION NEW PLAN
Approved Project Director	

Project Title	RENOVATE ED + PRIMARY CARE	Project Number	667-10-100
Location	SHREVEPORT VAMC 510 EAST STONER AVE	Building Number	1N, 1E
Date	01/09/13	Checked	SU
Drawn	MP	Drawing Number	FP1.N1
		Dwg. 88 of 12	

**Office of
 Construction
 and Facilities
 Management**