



- 1 NEW REMOTE ANNUNCIATOR PANEL LOCATION. COORDINATE LOCATION WITH VA.
- 2 POTENTIAL LOCATION FOR NOTIFICATION APPLIANCE CIRCUIT POWER PANEL AND DISTRIBUTED AMPLIFIER. COORDINATE LOCATION WITH VA.
- 3 DUCT SMOKE DETECTOR SERVING DUCTWORK FOR AHU-IN.
- 4 ADDRESSABLE CONTROL MODULE FOR INTERFACE WITH AHU-IN FOR SHUTDOWN UPON ACTUATION OF DUCT SMOKE DETECTOR.



Scale: AS NOTED

[illegible]