

DISTRIBUTION PANEL MDP											
		VOLTAGE		208 / 120V		BUSING		1200 A		MOUNTING SURFACE	
				3 Ph 4-W				65,000		LOCATION ELEC RM	
OCT #	ITEM SERVED	CIRCUIT BREAKER RATING			COMMENTS						
		POLE	TRIP	FRAME							
1	MAIN CIRCUIT BREAKER	3	1000 A	1200 A	100% RATED BREAKER						
2	PANEL 1LPL1	3	400 A	400 A							
3	PANEL 1LPL2	3	225 A	225 A							
4	PANEL 1LPL3	3	225 A	225 A							
5	ATS1	3	150 A	250 A							
6	ACCU-1	3	80 A	150 A							
7	ACCU-2	3	100 A	150 A							
8	ACCU-3	3	100 A	150 A							
9	SPARE	3	225 A	250 A							
10	SPARE	3	150 A	250 A							
11	SPARE	3	150 A	250 A							
12	SPARE	3	100 A	150 A							
13	SPACE	3	-	-							
14	SPACE	3	-	-							

PANEL 1LPL1											
MAIN		400		MCB		VOLTAGE		208 /120V		MOUNTING SURFACE	
BUSING		400		AMPS				3-Ph 4-W		LOCATION ELEC RM 15/1	
SCR		22,000		AIC						FED FROM MDP	
NO	DESCRIPTION					AMPS/POLE(S)	AMPS/POLE(S)	DESCRIPTION		NO	
1	-					-	-	-		2	
3	AHU-1-SF-1					70/3	30/3	AHU-1-RF-1		4	
5	-					-	-	-		6	
7	-					-	-	-		8	
9	AHU-2-SF-2					80/3	45/3	AHU-2-RF-2		10	
11	-					-	-	-		12	
13	-					-	-	-		14	
15	AHU-3-SF-3					80/3	45/3	AHU-3-RF-3		16	
17	-					-	-	-		18	
19	-					-	-	-		20	
21	LIFT STATION					50/3	15/3	DUPLEX VACUUM PUMP SYSTEM		22	
23	-					-	-	-		24	
25	EXHAUST FAN EF-1					20/1	20/1	EXHAUST FAN EF-2		26	
27	EXHAUST FAN EF-3					20/1	20/1	EXHAUST FAN EF-4		28	
29	VARIABLE VOLUME BOXES - LEFT POD					20/1	20/1	VARIABLE VOLUME BOXES - LEFT POD		30	
31	MOTOR OPERATED DAMPER - LEFT POD					20/1	20/1	MOTOR OPERATED DAMPER - MIDDLE POD		32	
33	VARIABLE VOLUME BOXES - MIDDLE POD					20/1	20/1	VARIABLE VOLUME BOXES - MIDDLE POD		34	
35	VARIABLE VOLUME BOXES - MIDDLE POD					20/1	20/1	VARIABLE VOLUME BOXES - RIGHT POD		36	
37	VARIABLE VOLUME BOXES - RIGHT POD					20/1	20/1	MOTOR OPERATED DAMPER - RIGHT POD		38	
39	MOTOR OPERATED DAMPER - MECH RM					20/1	20/1	EXHAUST FAN EF-5		40	
41	HORIZONTAL UNIT HEATER - MECH RM					20/1	20/1	EXHAUST HOOD - DINING KITCHEN		42	
43	WASHER/DRYER					30/2	-	-		44	
45	-					-	15/3	DUPLEX CONDENSATE PUMPS - DCP-1		46	
47	WASHER/DRYER					20/1	-	-		48	
49	CONTROLS FOR AHU-1					20/1	20/1	LIGHTS & RECEPTACLES FOR AHU-1		50	
51	CONTROLS FOR AHU-2					20/1	20/1	LIGHTS & RECEPTACLES FOR AHU-2		52	
53	CONTROLS FOR AHU-3					20/1	20/1	LIGHTS & RECEPTACLES FOR AHU-3		54	
55	SPARE					20/1	20/1	SPARE		56	
57	SPARE					20/1	20/1	SPARE		58	
59	SPARE					20/1	20/1	SPARE		60	
61	SPARE					20/1	20/1	SPARE		62	
63	SPARE					20/1	20/1	SPARE		64	
65	SPARE					20/1	20/1	SPARE		66	
67	SPARE					20/1	20/1	SPARE		68	
69	SPARE					20/1	20/1	SPARE		70	
71	SPARE					20/1	20/1	SPARE		72	
73	SPARE					20/1	20/1	SPARE		74	
75	SPARE					20/1	20/1	SPARE		76	
77	SPARE					20/1	20/1	SPARE		78	
79	SPARE					20/1	20/1	SPARE		80	
81	SPARE					20/1	20/1	SPARE		82	
83	SPARE					20/1	20/1	SPARE		84	

PANEL 1LPL2									
MAIN 225 MCB		VOLTAGE 208 /120V		MOUNTING SURFACE		ELEC RM 1551			
BUSING 225 AMPS		3-Ph 4-W		LOCATION					
NO	DESCRIPTION	AMPS/POLE(S)	AMPS/POLE(S)	DESCRIPTION	MDP	NO			
1	LIGHTING - LEFT POD - NW QUARTERS	20/1	20/1	LIGHTING - LEFT POD - NE QUARTERS		2			
3	LIGHTING - CORRIDOR - LEFT POD	20/1	20/1	LIGHTING - LEFT POD - SW QUARTERS		4			
5	LIGHTING - LEFT POD - SE QUARTERS	20/1	20/1	LIGHTING - MISC RMS - LEFT POD		6			
7	LIGHTING - MIDDLE POD - NW QUARTERS	20/1	20/1	LIGHTING - MIDDLE POD - NE QUARTERS		8			
9	LIGHTING - MIDDLE POD - SW QUARTERS	20/1	20/1	LIGHTING - MIDDLE POD - SE QUARTERS		10			
11	LIGHTING - CORRIDOR - MIDDLE POD	20/1	20/1	LIGHTING - MISC RMS - MIDDLE POD		12			
13	LIGHTING - LOUNGE AREA - WALL WASHERS	20/1	20/1	LIGHTING - LOUNGE AREA		14			
15	LIGHTING - LOUNGE AREA	20/1	20/1	LIGHTING - CANOPIES		16			
17	LIGHTING - RIGHT POD - NW QUARTERS	20/1	20/1	LIGHTING - RIGHT POD - NE QUARTERS		18			
19	LIGHTING - RIGHT POD - SW QUARTERS	20/1	20/1	LIGHTING - RIGHT POD - SE QUARTERS		20			
21	LIGHTING - CORRIDOR - RIGHT POD	20/1	20/1	LIGHTING - MISC RMS - RIGHT POD		22			
23	WHIRLPOOL	20/1	20/1	RECEPS - L POD - N QUARTERS - UC FRIDGE		24			
25	RECEP - L POD - N QUARTERS - MICROWAVE	20/1	20/1	RECEPS - LEFT POD - NORTH QUARTERS		26			
27	RECEPS - LEFT POD - NORTH QUARTERS	20/1	20/1	RECEPS - LEFT POD - NORTH QUARTERS		28			
29	RECEPS - LEFT POD - NORTH QUARTERS	20/1	20/1	BED RECEPS - LEFT POD - NORTH QUARTERS		30			
31	RECEPS - L POD - N QUARTERS - UC FRIDGE	20/1	20/1	RECEP - L POD - N QUARTERS - MICROWAVE		32			
33	RECEPS - L POD - S QUARTERS - UC FRIDGE	20/1	20/1	RECEP - L POD - S QUARTERS - MICROWAVE		34			
35	RECEPS - LEFT POD - SOUTH QUARTERS	20/1	20/1	RECEPS - LEFT POD - SOUTH QUARTERS		36			
37	BED RECEPS - LEFT POD - SOUTH QUARTERS	20/1	20/1	RECEPS - LEFT POD - SOUTH QUARTERS		38			
39	RECEPS - LEFT POD - SOUTH QUARTERS	20/1	20/1	RECEPS - LEFT POD - SOUTH QUARTERS		40			
41	RECEPS - L POD - S QUARTERS - MICROWAVE	20/1	20/1	RECEPS - L POD - S QUARTERS - UC FRIDGE		42			
43	RECEPTACLES - CORRIDOR - LEFT POD	20/1	20/1	RECEPTACLES - WHIRLPOOL ROOM		44			
45	RECEPTS - COR & EXT - LEFT & MIDDLE PODS	20/1	20/1	RECEPS - M POD - N QUARTERS - UC FRIDGE		46			
47	RECEP - M POD - N QUARTERS - MICROWAVE	20/1	20/1	RECEPS - MIDDLE POD - NORTH QUARTERS		48			
49	RECEPS - MIDDLE POD - NORTH QUARTERS	20/1	20/1	BED RECEPS - MI POD - NORTH QUARTERS		50			
51	RECEPS - MIDDLE POD - NORTH QUARTERS	20/1	20/1	RECEPS - MIDDLE POD - NORTH QUARTERS		52			
53	RECEPS - MIDDLE POD - NORTH QUARTERS	20/1	20/1	RECEP - M POD - N QUARTERS - MICROWAVE		54			
55	RECEPS - M POD - N QUARTERS - UC FRIDGE	20/1	20/1	RECEPS - M POD - S QUARTERS - UC FRIDGE		56			
57	RECEP - M POD - S QUARTERS - MICROWAVE	20/1	20/1	RECEPS - MIDDLE POD - SOUTH QUARTERS		58			
59	RECEPS - MIDDLE POD - SOUTH QUARTERS	20/1	20/1	BED RECEPS - M POD - SOUTH QUARTERS		60			
61	RECEPS - MIDDLE POD - SOUTH QUARTERS	20/1	20/1	RECEPS - MIDDLE POD - SOUTH QUARTERS		62			
63	RECEPS - MIDDLE POD - SOUTH QUARTERS	20/1	20/1	RECEP - M POD - S QUARTERS - MICROWAVE		64			
65	RECEPTACLES - STAFF LOUNGE - FRIDGE	20/1	20/1	RECEPTACLES - STAFF LOUNGE - REFRIG		66			
67	RECEP - STAFF LOUNGE - MICROWAVE	20/1	20/1	RECEP - STAFF LOUNGE - REFRIGERATOR		68			
69	RECEPTACLES - MISC RMS - MIDDLE POD	20/1	20/1	RECEPTACLES - MISC RMS - MIDDLE POD		70			
71	RECEPS - LEFT POD - NORTH QUARTERS	20/1	20/1	PLUGMOLD - STORAGE RM 117		72			
73	SPARE	20/1	20/1	SPARE		74			
75	SPARE	20/1	20/1	SPARE		76			
77	SPARE	20/1	20/1	SPARE		78			
79	SPARE	20/1	20/1	SPARE		80			
81	SPARE	20/1	20/1	SPARE		82			
83	SPARE	20/1	20/1	SPARE		84			
CKT NUMBER 23 SHALL BE GFI TYPE BREAKER									

CKT NUMBER 23 SHALL BE GFI TYPE BREAKER

PANEL 1LPL3									
MAIN		MCB		VOLTAGE		208 /120V		MOUNTING SURFACE	
BUSING		225		AMPS		3-Ph 4-W		LOCATION ELEC RM (151)	
SCR		22,000		AIC				FEED FROM	
NO	DESCRIPTION	AMPS/POLE(S)	AMPS/POLE(S)	DESCRIPTION	NO				
1	RECEP - DINING/KITCHEN - FRIDGE	20/1	20/1	RECEP - DINING/KITCHEN - DISHWASHER	2				
3	SPARE	20/1	20/1	RECEP - DINING/KITCHEN - MICROWAVE	4				
5	RECEPTACLES - OFFICE	20/1	20/2	FIREPLACE - LOUNGE AREA	6				
7	RECEPTACLES - DINING LOUNGE EXTERIOR	20/1							
9	RECEPTACLES - OFFICE & CORRIDOR	20/1	20/1	RECEPTACLES - OFFICE & EXTERIOR	10				
11	RECEPTACLES - OFFICE & CORRIDOR	20/1	20/1	RECEPTACLES - OFFICE & CORRIDOR	12				
13	RECEPTACLES - MEDICATION & CORRIDOR	20/1	20/1	RECEPTACLES - MISC AREAS - RIGHT POD	14				
15	RECEPS - R-POD - N QUARTERS - UC FRIDGE	20/1	20/1	RECEP - R-POD - N QUARTERS - MICROWAVE	16				
17	RECEPS - RIGHT POD - NORTH QUARTERS	20/1	20/1	BED RECEPS - R-POD - NORTH QUARTERS	18				
19	RECEPS - RIGHT POD - NORTH QUARTERS	20/1	20/1	RECEPS - RIGHT POD - NORTH QUARTERS	20				
21	RECEPS - RIGHT POD - NORTH QUARTERS	20/1	20/1	RECEPS - RIGHT POD - NORTH QUARTERS	22				
23	RECEPS - R-POD - N QUARTERS - UC FRIDGE	20/1	20/1	RECEPS - R-POD - S QUARTERS	24				
25	RECEPS - R-POD - S QUARTERS	20/1	20/1	RECEP - R-POD - S QUARTERS - MICROWAVE	26				
27	RECEPS - RIGHT POD - SOUTH QUARTERS	20/1	20/1	BED RECEPS - R-POD - SOUTH QUARTERS	28				
29	RECEPS - RIGHT POD - SOUTH QUARTERS	20/1	20/1	RECEPS - RIGHT POD - SOUTH QUARTERS	30				
31	RECEPS - RIGHT POD - SOUTH QUARTERS	20/1	20/1	RECEPS - RIGHT POD - SOUTH QUARTERS	32				
33	RECEP - R-POD - S QUARTERS - MICROWAVE	20/1	20/1	RECEPS - R-POD - S QUARTERS - UC FRIDGE	34				
35	RECEP - L-POD - N QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - L-POD - N QUARTERS - PATIENT LIFT	36				
37	RECEP - L-POD - N QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - L-POD - N QUARTERS - PATIENT LIFT	38				
39	RECEP - L-POD - S QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - L-POD - S QUARTERS - PATIENT LIFT	40				
41	RECEP - L-POD - S QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - L-POD - S QUARTERS - PATIENT LIFT	42				
43	RECEP - M-POD - N QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - M-POD - N QUARTERS - PATIENT LIFT	44				
45	RECEP - M-POD - N QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - M-POD - N QUARTERS - PATIENT LIFT	46				
47	RECEP - M-POD - S QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - M-POD - S QUARTERS - PATIENT LIFT	48				
49	RECEP - M-POD - S QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - M-POD - S QUARTERS - PATIENT LIFT	50				
51	RECEP - R-POD - N QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - R-POD - N QUARTERS - PATIENT LIFT	52				
53	RECEP - R-POD - N QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - R-POD - N QUARTERS - PATIENT LIFT	54				
55	RECEP - R-POD - S QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - R-POD - S QUARTERS - PATIENT LIFT	56				
57	RECEP - R-POD - S QUARTERS - PATIENT LIFT	20/1	20/1	RECEP - R-POD - S QUARTERS - PATIENT LIFT	58				
59	OVER - DINING/KITCHEN RM 108	30/2		SPARE	60				
61	-	-	-	20/1	SPARE	62			
63	SPARE	20/1	20/1	SPARE	64				
65	SPARE	20/1	20/1	SPARE	66				
67	SPARE	20/1	20/1	SPARE	68				
69	SPARE	20/1	20/1	SPARE	70				
71	SPARE	20/1	20/1	SPARE	72				
73	SPARE	20/1	20/1	SPARE	74				
75	SPARE	20/1	20/1	SPARE	76				
77	SPARE	20/1	20/1	SPARE	78				
79	SPARE	20/1	20/1	SPARE	80				
81	SPARE	20/1	20/1	SPARE	82				
83	SPARE	20/1	20/1	SPARE	84				