



## CONSULTANTS:

## ARCHITECT:

## SECOND FLOOR PLAN AREA 4

## STEAM TRAP MONITORING INSULATION AND PIPING UPGRADES

# Office of Facilities Management

**SECOND FLOOR KEY PLAN**  
SCALE: N.T.S.

**CODED NOTES:**

1 FURNISH & INSTALL STEAM DRIP TRAPS AHEAD OF STEAM CONTROL VALVES AT ELEVEN (11) LOCATIONS IN WEST PENTHOUSE. SEE DETAIL NO. 3 ON SHEET 1-02.

## PARTIAL SECOND FLOOR - STEAM PIPING - AREA 4

