

ADDENDUM No. 1

January 4, 2013

To the specifications for:

Renovation of Gait Lab and EMS Offices

Audie L. Murphy Memorial Veterans Hospital, San Antonio, TX

VA Project No. 671-13-102

Audie L. Murphy Memorial Veterans Hospital

7400 Merton Minter Blvd.

San Antonio, TX 78229

210-617-5300

TECHNICAL SPECIFICATION

1. SECTION 010000 – General Requirements:

a. Delete paragraph 1.4.F.2 - Separate permits shall be issued for General Contractor and its employees for parking in designated areas only.

b. Revise paragraph 1.5.D to read - Separate temporary facilities, such as dumpsters, from existing buildings and new construction by distances in accordance with NFPA 241. For small facilities with less than 6 m (20 feet) exposing overall length, separate by 3m (10 feet).

This written amendment is hereby made a part of the contract documents to the same extent as though it were originally included therein. This amendment shall take precedence over the original drawings and specifications where its provisions apply.