



- [illegible]

This figure is a detailed architectural drawing titled "FIRE SPRINKLER BUILDING CROSS SECTION". It shows a cross-section of a multi-story building with various rooms and levels. The drawing includes a keynotes section on the right side, which lists items such as "SPR, 5.6K, 155\", WHITE, SEMI-RECESSED", "SSU, 5.6K, 200\", BRASS", "T-BAR CEILING", "CROSS MAIN", "BRANCHLINE PIPING", and "UF BEAM". The drawing also features a scale bar at the bottom left, indicating dimensions from 0 to 16 feet. The drawing is labeled with "VA FORM 08-6231" at the bottom left.

The drawing shows a cross-section of a building with multiple floors. The levels are indicated on the right side:

- T.O.S. +53'-6"
- ROOF +41'-6"
- THIRD FLOOR +28'-0"
- SECOND FLOOR +14'-0"
- FIRST FLOOR +0'-0"

The rooms and areas shown include:

- MEN TOILET 3A-2, WOMEN TOILET 3A-4
- CORRIDOR C3-2, STORAGE 3A-5
- CLINICAL TEACHING LAB 3A-6
- CORRIDOR C3-8, CORRIDOR C3-8
- OFFICE C3-25
- MEN TOILET 2A-2, WOMEN TOILET 2A-6
- CORRIDOR C2-1
- AREA #2 2A-12
- AREA #1 2A-20
- CORRIDOR C2-4
- CONFERENCE/CLASSROOM 2A-19
- MEN TOILET 1A-2, WOMEN TOILET 1A-4
- MALL
- LIBRARY 1A-5
- BASEMENT B-1
- UTILITY TUNNEL

The keynotes section lists the following items:

- ① SPR, 5.6K, 155", WHITE, SEMI-RECESSED
- ② SSU, 5.6K, 200", BRASS
- ③ T-BAR CEILING
- ④ CROSS MAIN
- ⑤ BRANCHLINE PIPING
- ⑥ UF BEAM

The scale bar indicates dimensions from 0 to 16 feet.

Revisions:

No.	Description	Date

CONSULTANTS:

**LP Consulting Engineers, Inc.**  
895 W. Ashlan Ave., Suite 101 Clovis, CA 93612  
p 559-348-2130 - f 559-348-2131  
www.lpengineers.com  
Job #: 10-1096

ARCHITECT/ENGINEERS:

**HMC Architects**  
1827 E. Fir Avenue, Studio 103 / Fresno, CA 93720  
T 559 322 2444 / www.hmcarchitects.com

Drawing Title:  
**FIRE SPRINKLER BUILDING CROSS SECTION**

Approved: Project Director

Project Title:  
**BUILDING 24 SEISMIC CORRECTION AND ADDITION**

Location:  
**VAMC FRESNO, CA**

Date:  
**March 12, 2013**

Checked:  
**SA**

Drawn:  
**ES**

Project Number:  
**570-215**

Building Number:  
**24**

Drawing Number:  
**FP302**  
Dwg. 129 of 180

Office of Construction and Facilities Management  
Department of Veterans Affairs

Architectural drawing showing a building cross-section with fire sprinkler details. The drawing includes a keynotes section on the right and a title block at the bottom.

**KEYNOTES**

- 1. 68P, 5.6K, 155°, WHITE, SEMI-RECESSED
- 2. 68U, 5.6K, 200°, BRASS
- 3. T-BAR CEILING
- 4. CROSS MAIN
- 5. BRANCHLINE PIPING
- 6. UF BEAM

**1 FIRE SPRINKLER BUILDING CROSS SECTION**  
1/8"=1'-0"

**CONSULTANTS:**

**LP Consulting Engineers, Inc.**  
895 W. Ashlan Ave, Suite 101 Clovis, CA 93612  
p 559-348-2130 - f 559-348-2131  
www.lpengineers.com  
Job #: 10-1096

**ARCHITECT/ENGINEERS:**

**HMC Architects**  
1827 E. Fir Avenue, Studio 103 / Fresno, CA 93720  
T 559 322 2444 / www.hmcarchitects.com

**Drawing Title:** FIRE SPRINKLER BUILDING CROSS SECTION

**Approved:** Project Director

**Project Title:** BUILDING 24 SEISMIC CORRECTION AND ADDITION

**Location:** VAMC FRESNO, CA

**Date:** March 12, 2013

**Checked:** SA

**Drawn:** ES

**Project Number:** 570-215

**Building Number:** 24

**Drawing Number:** FP302

**Dwg. 129 of 180**

**Office of Construction and Facilities Management**

**Department of Veterans Affairs**