



KEYNOTES

- 1 68P, 5.6K, 155", WHITE, SEMI-RECESSED
- 2 68U, 5.6K, 200", BRASS
- 3 T-BAR CEILING
- 4 CROSS MAIN
- 5 BRANCHLINE PIPING
- 6 WF BEAM

1 FIRE SPRINKLER BUILDING CROSS SECTION
1/8"=1'-0"

CONSULTANTS:



LP LP Consulting
Engineers, Inc.
895 W. Ashlan Ave, Suite 101 Clovis, CA 93612
p 559-349-2130 • f 559-349-2131
www.lpengineers.com
Job #: 10-1096



ARCHITECT/ENGINEERS:

HMC Architects

1827 E. Fir Avenue, Studio 103 / Fresno, CA 93720
T 559 322 2444 / www.hmcarchitects.com

Drawing Title
FIRE SPRINKLER
BUILDING CROSS SECTION

Approved Project Director

Project Title
BUILDING 24
SEISMIC CORRECTION
AND ADDITION

Location
VAMC FRESNO, CA

Date
March 12, 2013

Checked
SA

Drawn
ES

Project Number
570-215
Building Number
24

Drawing Number
FP302
Dwg. 129 of 180

Office of
Construction
and Facilities
Management

