


1 DEMOLITION FIRST FLOOR LIGHTING PLAN



- FIRST FLOOR LIGHTING DEMO NOTES:**
- REMOVE EXISTING LIGHTS AND RELATED CONDUITS AND WIRING IN ROOM. VERIFY WORK REQUIRED IN FIELD.
  - EXISTING SWITCHES TO BE REPLACED. REMOVE EXISTING SWITCHES AND WIRING.
  - REMOVE EXISTING CEILING MOUNTED PUBLIC ADDRESS SPEAKER AND RELATED BRACKET, CONDUITS AND WIRING.
  - VERIFY EXISTING LIGHTING HOVERLUN IN FIELD. REMOVE EXISTING CONDUITS AND WIRING.
  - REMOVE EXISTING LIGHTING HOVERLUN CONDUIT AND WIRING.
  - REMOVE EXISTING LIGHTING HOVERLUN CONTROLLED LIGHTING CONTACTOR.
  - EXISTING LIGHTS CONNECTED TO EXISTING 120V EMG PANEL, E-1, VIA 120V/277V TRANSFORMER. REMOVE EXISTING LIGHTS, CONDUITS AND WIRING.
  - EXISTING EXIT SIGNS CONNECTED TO EXISTING 120V EMG PANEL, E-1, VIA 120V/277V TRANSFORMER. REMOVE EXISTING SIGNS, CONDUITS AND WIRING.
  - EXISTING EMERGENCY LIGHTING CIRCUIT TO EXISTING 120V EMG PANEL, E-1, VIA 120V/277V TRANSFORMER. REMOVE EXISTING TRANSFORMER AND HOVERLUN TO PANEL, E-1, TO REMAIN.
  - EXISTING STAIR LIGHTS CONNECTED ON EXISTING 120V EMG PANEL, E-1, TO REMAIN.
  - REMOVE EXISTING RECESSED LIGHTS, OUTLETS AND RELATED CONDUITS AND WIRING IN EXISTING FOSTER SOUTH BEING REMOVED.
  - EXISTING EXTERIOR WALL LIGHTS AND WIRING TO REMAIN AND TO BE RECONNECTED TO EXISTING CIRCUIT.
  - ELECTRICAL DEMO WORK IN AUDITORIUM TO BE INCLUDED IN DEDUCTIVE ALTERNATE 4.
  - REMOVE EXISTING LIGHTS, OUTLETS AND RELATED CONDUITS AND WIRING.
  - REMOVE EXISTING TRACK LIGHTS, OUTLETS AND RELATED CONDUITS AND WIRING.
  - EXISTING EXIT SIGNS TO BE REPLACED. REMOVE EXISTING LIGHTS, OUTLETS AND RELATED CONDUITS AND WIRING.
  - REMOVE EXISTING DIMMERS, SWITCHES, CABINET, CONDUITS AND WIRING.
  - EXISTING REAR LIGHTING CONTROL CABINET TO BE ABANDONED IN PLACE IN EXISTING BLOCK WALL. REMOVE ALL EXISTING DEVICES AND WIRING.
  - REMOVE EXISTING CEILING SPEAKERS, OUTLETS AND RELATED CONDUITS AND WIRING.
  - REMOVE EXISTING SWITCH AND WIRING.
  - EXISTING PANELS TO REMAIN.

CONSULTANTS:		ARCHITECT/ENGINEERS:	
 LP Consulting Engineers, Inc. 895 W. Ashland Ave., Suite 101, Chico, CA 95912 P 530-424-3434, F 530-424-7025 www.lpe.com JDE # 70-1008		 HMC Architects 1827 E. 9th Avenue, Suite 103, Fresno, CA 93720 T 559-322-2444 / www.hmcarchitects.com	
Project Title DEMOLITION FIRST FLOOR LIGHTING PLAN		Project Title BUILDING 24 SEISMIC CORRECTION AND ADDITION	
Approved Project Director Date March 12, 2018		Location VAMC FRESNO, CA	
Drawing Number ED101		Building Number 24	
Drawing Number Dwg 166 of 160		Drawing Number ED101	
Office of Construction and Facilities Management		Department of Veterans Affairs	