



1. REMOVE ALL OBSOLETE ELECTRICAL EQUIPMENT, FIXTURES, CONDUIT, WIRING, CONTROLS, HANGERS, PADS, AND SUPPORTS UNLESS OTHERWISE INDICATED TO REMAIN. DISCONNECT CIRCUITS TO BE REMOVED BY THE CONTRACTOR WHICH IS TO BE REMOVED BY OTHERS. WIRING MADE OBSOLETE BY THE NEW CONSTRUCTION SHALL BE REMOVED. CONDUIT AND WIRING MADE OBSOLETE BY THE NEW CONSTRUCTION SHALL BE REMOVED OR SECURELY SEALED AND CAPPED ABOVE CEILINGS, BELOW FLOORS, OR IN WALLS SO THAT IT IS CONCEALED AND NOT CONCEALED AT THE COMPLETION OF THE PROJECT. PIPING AND WIRING REMOVED FROM THE EXISTING ELECTRICAL SYSTEMS SHALL NOT BE USED IN THE INSTALLATION OF THE NEW SYSTEM.
2. DEMOLITION INCLUDES, BUT IS NOT LIMITED TO, REMOVAL AND LEGAL DISPOSAL OF EQUIPMENT AND SYSTEMS MADE OBSOLETE AND/OR REPLACED BY NEW WORK. DEMOLITION INCLUDES RELOCATION OR REINSTALLATION, DISCONNECTIONS AND REWIRING, REPAIRS, SERVICES, SUPPORTS, AND SUBSEQUENT FINAL SUPPORTS, TEMPORARY CAPPING, AND REROUTING OF TEMPORARY SUPPORTS TO PERMIT NEW OR RENOVATION WORK TO PROCEED.
3. THE DEMOLITION WORK AS NOTED ON THE DRAWING IS INTENDED TO ASSIST THE CONTRACTOR AND GIVE GENERAL INFORMATION. DEMOLITION ITEMS ARE NOT SHOWN AND MUST BE IDENTIFIED DURING THE CONTRACTOR'S WORK. THROUGH PRIOR TO THE DEMOLITION OF TEMPORARY CONNECTIONS ARE SHOWN. PRIOR TO SUBMITTING BID, THE CONTRACTOR SHALL VISIT THE PROJECT SITE AND REVIEW ALL DRAWINGS. THE CONTRACTOR IS RESPONSIBLE TO DETERMINE THE FULL EXTENT OF DEMOLITION, AND INCLUDE ALL REQUIRED DISCONNECT WORK AND HIS BID, WHETHER OR NOT SPECIFICALLY SHOWN ON DRAWINGS. NO ADDITIONAL COST WILL BE GRANTED FOR DEMOLITION. LEGALLY DISPOSE OF EQUIPMENT AND MATERIALS NOT SPECIFICALLY DESIGNATED BY THE COR TO BE SALVAGED. REMOVE AND REPLACE THE DESIGNATED SALVAGED EQUIPMENT IN A LOCATION DETERMINED BY THE OWNER AT NO ADDITIONAL EXPENSE.
4. REFER TO GENERAL CONSTRUCTION TRADE DEMOLITION DRAWINGS FOR DEVICES AND EQUIPMENT THAT HAVE TO BE REMOVED DUE TO THE NEW CONSTRUCTION AND RENOVATIONS AND EXTENT OF AREA TO BE DEMOLISHED. DISCONNECT POWER TO ALL DEVICES AND EQUIPMENT WHICH DEVICES AND EQUIPMENT WHETHER OR NOT SPECIFICALLY SHOWN ON ELECTRICAL DRAWINGS TO FACILITATE DEMOLITION AND NEW CONSTRUCTION.
5. IN ALL AREAS WHERE PATCHING IS REQUIRED, THE ELECTRICAL CONTRACTOR SHALL PATCH THE SURFACE WHERE THE NEW SURFACE IS TO BE FINISHED BY THE GENERAL CONTRACTOR. THIS SURFSUBSTANCE MUST BE PATCHED SO THAT IT DOES NOT AFFECT THE APPEARANCE OF THE NEW FINISH. IF A NEW FINISH WILL NOT BE PROVIDED BY THE GENERAL CONTRACTOR, THE ELECTRICAL CONTRACTOR IS RESPONSIBLE TO PATCH THE SURROUNDING SURFACE TO MATCH EXISTING.
6. MAINTAIN CONTINUITY OF EXISTING CIRCUITS FOR EQUIPMENT AND DEVICES TO REMAIN. IF A DEVICE OR EQUIPMENT IS REMOVED AND IS PART OF AN EXISTING CIRCUIT TO REMAIN, THE CONTRACTOR SHALL BE RESTORED TO IT'S ORIGINAL CONDITION.



100% SUBMISSION
FOR CONSTRUCTION
MARCH 27th, 2013

[illegible]