

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF 2
2. AMENDMENT/MODIFICATION NO. A00001		3. EFFECTIVE DATE 05-09-2013	4. REQUISITION/PURCHASE REQ. NO. 575-13-2-6040-0013		5. PROJECT NO.(If applicable) 575-12-807	
6. ISSUED BY CODE Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246		7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NO. VA259-13-R-0549		
				9B. DATED (SEE ITEM 11) 5/09/2013		
				10A. MODIFICATION OF CONTRACT/ORDER NO.		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required) 575-3630162-6040-854100-3220 23NRNR000						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return ¹ _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) a) Changes were made to the solicitation: (see attached "revised solicitation." a. Period of performance discrepancy in the solicitation has corrected: 90 days. b. Reference to "demolition building 4" in the price schedule has been deleted. b) Additional drawing has been attached - see attached "Demo WSD" c) Questions and answers received prior to the date required for submission are attached. d) The date set for the receipt of offers has not been changed.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Daniel J. Pagone V1912L3-4593			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)		16C. DATE SIGNED	
NSN 7540-01-152-8070 PREVIOUS EDITION NOT USABLE						
STANDARD FORM 30 (REV. 10-83) Prescribed by GSA - FAR (48 CFR) 53.243						

Questions

1. Will the downspout to the roof drain gutter need to be replaced or just put back together? **NO**
2. Who will move the Connex, Contractor or the VA? **VA**
3. In the patch area, is it asphalt or concrete? **CLASS 6 ABC**
4. The electrical plans do not show a switch at the new main door. Will there need to be a switch there? **YES**
5. The specs call for the new main door and frame to be galvanized steel. Will 18ga. cold rolled steel with paint be acceptable? **YES**
6. Please advise for the new wall panels height. Is it all the way to the roof height or spliced at the bottom of the existing panels? **FULL HEIGHT REPLACEMENT PANELS**
7. In the solicitation the performance date is 30 days but in the Price Schedule is 90 days. Please clarify. **90**
8. What kind of material needed to seal openings in walls? **WEATHERPROOF/INDUSTRY BASED**