

## AMENDMENT NO. 001



**DATE:** May 10, 2013

**PROJECT NAME:** SICU Modifications, 2<sup>nd</sup> Floor – VA Audie Murphy Hospital

**PROJECT NO.:** 12053

---

**TO:** All Prime Contract Bidders and all others to whom Drawings and Specifications have been issued by the Architect.

This Amendment forms a part of the Contract Documents. This Amendment modifies and supplements the Contract Documents as follows for the above-mentioned project, and includes **one (1) page, zero (0) attachments, and two (2) revised drawing sheets.** All other provisions of the Documents remain unchanged.


---

### **CHANGES TO DRAWINGS: (RB)**

---

#### **MECHANICAL: (RB)**

1. Sheet H1-1
  - a. The re-balancing of the 2C clinic area is an add alternate. Refer to architectural documents.
2. Sheet H1-2
  - a. Clarification: New Work keyed note #4 refers to floor grating. The Contractor is responsible for providing steel grating to match the existing, routed to provide access to allow filter replacement.
3. Sheet H1-3 (refer to full size sheet)
  - a. Revise requirements for existing fan.
  - b. Delete requirement for demo of existing split system.
4. Sheet H2-1 (refer to full size sheet)
  - a. Delete details 1, 4, and 5.
  - b. Delete the Fan and Coil Schedule
  - c. Revise the Fan Schedule.
5. Sheet H2-2
  - a. Delete detail 1.



Y:\12053\File\Addenda\Amendment 1.docx

1344 S. Flores, Suite 101  
San Antonio, Texas 78204  
T 210.447.6100 / F 210.447.6101



ClearyZimmermann.com