three inches = one foot

one and one half inches = one foot

one inch = one foot

three quarters inch = one foot

one half inch = one foot

three eighths inch = one foot

one quarter inch = one foot

one eighth inch = one foot

KEYED NOTES

1. DEMOLISH EXISTING RECEPTACLES, LIGHT SWITCHES, FIRE ALARM DEVICES AND VOICE/DATA DEVICES ON WALLS TO BE DEMOLISHED. DEMOLITION OF RECEPTACLES AND SWITCHES SHALL INCLUDE ASSOCIATED WIRE AND CONDUIT BACK TO SOURCE. WHERE CIRCUIT IS TO REMAIN ACTIVE, CONTRACTOR SHALL ADJUST EXISTING CIRCUITING TO ENSURE REMAINING DEVICES ON CIRCUIT ARE OPERATIONAL. VOICE/DATA CABLING SHALL BE REMOVED BACK TO DATA CLOSET.
2. DEMOLISH EXISTING LIGHT FIXTURES IN THIS AREA. OWNER SHALL HAVE FIRST RIGHT OF REFUSAL FOR ALL DEMOLISHED LIGHT FIXTURES. DEMOLITION OF LIGHT FIXTURES SHALL INCLUDE ASSOCIATED WIRE AND CONDUIT. WHERE LIGHTING CIRCUIT IS TO REMAIN ACTIVE, CONTRACTOR SHALL ADJUST EXISTING CIRCUITING TO ENSURE REMAINING LIGHT FIXTURES ON CIRCUIT ARE OPERATIONAL.
3. DEMOLISH EXISTING ELECTRICAL FEEDER TO X-RAY EQUIPMENT IN THIS AREA. DEMOLITON SHALL INCLUDE COMPLETE REMOVAL OF CONDUIT AND CONDUCTORS BACK TO PANEL 'DH-24-2' IN ELECTRICAL ROOM 2454 EC. RE-LABEL BREAKER AS "SPARE".
4. EXISTING INTERCOM CEILING SPEAKER SHALL BE REMOVED AND SAVED FOR RE-INSTALLATION IN NEW CEILING. EXISTING SPEAKER CABLING SHALL REMAIN FOR RE-USE. CONTRACTOR SHALL PROTECT EXISTING CABLING DURING CONSTRUCTION TO ENSURE IT REMAINS FUNCTIONAL.
5. EXISTING EMERGENCY PULL CORD STATION IN THIS AREA SHALL BE SALVAGED FOR RE-INSTALLATION. SEE SHEET ES-501 FOR NEW LOCATION.
6. EXISTING DOME/TONE LIGHT AND ASSOCIATED POWER SUPPLY SHALL BE SALVAGED FOR RE-INSTALLATION. SEE SHEET ES-501 FOR NEW LOCATION.
7. EXISTING MOBILE FLUOROSCOPY DEDICATED RECEPTACLE AND EMERGENCY STOP BUTTON SHALL BE SALVAGED FOR RE-INSTALLATION. SEE SHEET ES-301 FOR NEW LOCATION.

1 SECOND FLOOR DEMOLITION - ELECTRICAL
1/8" = 1'-0"

KEYPLAN - BUILDING 111

95% SUBMISSION - NOT FOR CONSTRUCTION

Revisions:	Date

Stamp / Seal

THESE DOCUMENTS ARE FOR INTERIM REVIEW AND NOT INTENDED FOR CONSTRUCTION, BIDDING, OR PERMIT PURPOSES.
DATE: 2.14.2013
ENGINEER OF RECORD
DOUGLAS G. CARDER, PE
STATE: KANSAS
REGISTRATION #: 15811

CONSULTANTS:

IEA
9201 West Broadway
Brooklyn Park, MN 55445
Toll Free: 800.233.9513
Tel: 763.315.7900
Fax: 763.315.7920

SSR Smith Seckman Reid, Inc.
11460 Tomahawk Creek Pkwy, Suite 320
Leawood, KS 66211
(913) 319-3560
FAX (913) 319-3579
www.ssr-inc.com
Project # 1255071

ARCHITECT/ENGINEERS:

COX DESIGN ASSOCIATES
ARCHITECTURE PLANNING INTERIORS

CHICAGO
345 N. Canal Street Suite 701
Chicago, Illinois 60606
T: 312.454.9434
F: 312.454.9439

AUSTIN
5121 Bee Cave Road #203
Austin, Texas 78746
T: 512.327.4149
F: 512.327.7679

Drawing Title: SECOND FLOOR DEMOLITON - ELECTRICAL

Location: CLEMENT J. ZABLOCKI VA MEDICAL CENTER MILWAUKEE, WI

Project Name: 111 RENOVATE X-RAY 5

Building Number: 111 | Checked: DGC | Drawn: RDS

Project Number: 695-12-195

Date: 02.14.13

Drawing Number: **ED-101**

Dwg. of

Office of Construction and Facilities Management

VA FORM 08-6231