

SECTION 28 31 00

FIRE ALARM

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes expansion of existing fire alarm systems with manual stations, detectors, signal equipment, controls, and devices.
- B. Related Sections include the following:
 - 1. Division 8 Section "Hardware" for door closers/holders/smoke detectors, electric door locks, and release devices that interface with fire alarm systems.

1.3 DEFINITIONS

- A. FACP: Fire alarm control panel.
- B. LED: Light-emitting diode.
- C. Definitions in NFPA 72 apply to fire alarm terms used in this Section.

1.4 SYSTEM DESCRIPTION

- A. General: Noncoded, addressable-analog system with manual and automatic alarm initiation; automatic sensitivity control of certain smoke detectors; and multiplexed signal transmission dedicated to fire alarm service only.

1.5 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings:
 - 1. Wiring Diagrams: Detail wiring and differentiate between manufacturer-installed and field-installed wiring. Include diagrams for equipment and for system with all terminals and interconnections identified.
 - 2. Battery: Sizing calculations.
 - 3. Floor Plans: Indicate final outlet locations and routings of raceway connections.
 - 4. Device Address List: Coordinate with final system programming.

5. System Operation Description: Detailed description for this Project, including method of operation and supervision of each type of circuit and sequence of operations for manually and automatically initiated system inputs and outputs.

Manufacturer's standard descriptions for generic systems are not acceptable.

- C. Operating Instructions: For mounting at the FACP.
- D. Product Certificates: Signed by manufacturers of system components certifying that products furnished comply with requirements.
- E. Installer Certificates: Signed by manufacturer certifying that installers comply with requirements.
- F. Field Test Reports: Indicate and interpret test results for compliance with performance requirements. Comply with NFPA 72.
- G. Maintenance Data: For fire alarm systems to include in maintenance manuals specified in Division 1. Comply with NFPA 72.
- H. Submissions to Authorities Having Jurisdiction: In addition to distribution requirements for Submittals specified in Division 1 Section "Submittals," make an identical submission to authorities having jurisdiction. Include copies of annotated Contract Drawings as needed to depict component locations to facilitate review. Resubmit if required to make clarifications or revisions to obtain approval. On receipt of comments from authorities having jurisdiction, submit them to Architect for review.
- I. Certificate of Completion: Comply with NFPA 72.

1.6 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who is an authorized representative of the FACP manufacturer for both installation and maintenance of units required for this Project.
- B. Manufacturer Qualifications: A firm experienced in manufacturing systems similar to those indicated for this Project and with a record of successful in-service performance.
- C. Source Limitations: Obtain fire alarm system components through one source from a single manufacturer.
- D. Compliance with Local Requirements: Comply with applicable building code, local ordinances and regulations, and requirements of authorities having jurisdiction.
- E. Comply with NFPA 72.

1.7 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Horn/Strobe and Strobe Units: Quantity equal to 10 percent of amount installed, but not less than one unit.
 - 2. Smoke Detectors, Fire Detectors, and Flame Detectors: Quantity equal to 10 percent of amount of each type installed, but not less than one unit of each type.
 - 3. Detector Bases: Quantity equal to 2 percent of amount of each type installed, but not less than one unit of each type.
 - 4. Printer Ribbons: Six spares.
 - 5. Keys and Tools: One extra set for access to locked and tamperproofed components.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Siemens (to match existing).

2.2 FUNCTIONAL DESCRIPTION OF SYSTEM

- A. Control of System: By the FACP.
- B. System Supervision: Automatically detect and report open circuits, shorts, and grounds of wiring for initiating device, signaling line, and notification-appliance circuits.
- C. Priority of Signals: Automatic alarm response functions resulting from an alarm signal from one zone or device are not altered by subsequent alarm, supervisory, or trouble signals. An alarm signal is the highest priority. Supervisory and trouble signals have second- and third-level priority. Higher-priority signals take precedence over signals of lower priority, even when the lower-priority condition occurs first. Annunciate and display all alarm, supervisory, and trouble signals regardless of priority or order received.
- D. Noninterference: A signal on one zone shall not prevent the receipt of signals from other zones.

- E. System Reset: All zones are manually resettable from the FACP after initiating devices are restored to normal.
- F. Transmission to Remote Alarm Receiving Station: Automatically route alarm, supervisory, and trouble signals to a remote alarm station by means of a digital alarm communicator transmitter and telephone lines.
- G. System Alarm Capability during Circuit Fault Conditions: System wiring and circuit arrangement prevent alarm capability reduction when a single ground or open circuit occurs in an initiating device circuit, signal line circuit, or notification-appliance circuit.
- H. Loss of primary power at the FACP initiates a trouble signal at the FACP and the annunciator. An emergency power light is illuminated at both locations when the system is operating on the secondary power supply.
- I. Basic Alarm Performance Requirements: Unless otherwise indicated, operation of initiating device initiates the sequence of operation as indicated in the fire alarm matrix.
- J. Alarm Silencing, System Reset and Indication: Controlled by switches in the FACP and the remote annunciator.
 - 1. Silencing-switch operation halts alarm operation of notification appliances and activates an "alarm silence" light. Display of identity of the alarm zone or device is retained.
 - 2. Subsequent alarm signals from other devices or zones reactivate notification appliances until silencing switch is operated again.
 - 3. When alarm-initiating devices return to normal and system reset switch is operated, notification appliances operate again until alarm silence switch is reset.
- K. Water-flow alarm switch operation initiates the following:
 - 1. Notification-appliance operation.
 - 2. Flashing of the device location-indicating light for the device that has operated.
- L. Operating a heat detector in the elevator shaft shuts down elevator power by operating a shunt trip in a circuit breaker feeding the elevator.
 - 1. A field-mounted relay actuated by the fire detector or the FACP closes the shunt trip circuit and operates building

notification appliances and annunciator.

- M. Sprinkler valve-tamper switch operation initiates the following:
 - 1. A supervisory, audible, and visible "valve-tamper" signal indication at the FACP and the annunciator.
 - 2. Flashing of the device location-indicating light for the device that has operated.
 - 3. Recording of the event by the system printer.
 - 4. Transmission of supervisory signal to remote alarm receiving station.
- N. Low-air-pressure switch operation on a dry-pipe or preaction sprinkler system initiates the following:
 - 1. A supervisory, audible, and visible "sprinkler trouble" signal indication at the FACP and the annunciator.
 - 2. Flashing of the device location-indicating light for the device that has operated.
 - 3. Recording of the event by the system printer.
 - 4. Transmission of trouble signal to remote central station.
- O. Remote Detector Sensitivity Adjustment: Manipulation of controls at the FACP causes the selection of specific addressable smoke detectors for adjustment, display of their current status and sensitivity settings, and control of changes in those settings. Same controls can be used to program repetitive, scheduled, automated changes in sensitivity of specific detectors. Sensitivity adjustments and sensitivity-adjustment schedule changes are recorded in system memory and are printed out by the system printer.
- P. Removal of an alarm-initiating device or a notification appliance initiates the following:
 - 1. A "trouble" signal indication at the FACP and the annunciator for the device or zone involved.
 - 2. Recording of the event by the system printer.
 - 3. Transmission of trouble signal to remote alarm receiving station.
- Q. Printout of Events: On receipt of the signal, print alarm, supervisory, and trouble events. Identify zone, device, and function. Include type of signal (alarm, supervisory, or trouble), and date and time of occurrence. Differentiate alarm signals from all other printed indications. Also print system reset event,

including the same information for device, location, date, and time. Commands initiate the printout of a list of existing alarm, supervisory, and trouble conditions in the system and a historical log of events.

- R. FACP Alphanumeric Display: Plain-English-language descriptions of alarm, supervisory, and trouble events; and addresses and locations of alarm-initiating or supervisory devices originating the report. Display monitoring actions, system and component status, system commands, programming information, and data from the system's historical memory.

2.3 MANUAL PULL STATIONS

- A. Description: Fabricated of metal or plastic, and finished in red with molded, raised-letter operating instructions of contrasting color.
 - 1. Double-action mechanism requires two actions, such as a push and a pull, to initiate an alarm.
 - 2. Station Reset: Key or wrench operated; double pole, double throw; switch rated for the voltage and current at which it operates.
 - 3. Integral Addressable Module: Arranged to communicate manual-station status (normal, alarm, or trouble) to the FACP.

2.4 SMOKE DETECTORS

- A. General: Include the following features:
 - 1. Operating Voltage: 24-V dc, nominal.
 - 2. Self-Restoring: Detectors do not require resetting or readjustment after actuation to restore them to normal operation.
 - 3. Plug-in Arrangement: Detector and associated electronic components are mounted in a module that connects in a tamper-resistant manner to a fixed base with a twist-locking plug connection. Terminals in the fixed base accept building wiring.
 - 4. Integral Visual-Indicating Light: LED type. Indicates detector has operated.
 - 5. Sensitivity: Can be tested and adjusted in-place after installation.

6. Integral Addressable Module: Arranged to communicate detector status (normal, alarm, or trouble) to the FACP.
 7. Remote Controllability: Unless otherwise indicated, detectors are analog-addressable type, individually monitored at the FACP for calibration, sensitivity, and alarm condition, and individually adjustable for sensitivity from the FACP.
- B. Photoelectric Smoke Detectors: Include the following features:
1. Sensor: LED or infrared light source with matching silicon-cell receiver.
 2. Detector Sensitivity: Between 2.5 and 3.5 percent/foot (0.008 and 0.011 percent/mm) smoke obscuration when tested according to UL 268A.
- C. Duct Smoke Detector: Photoelectric type.
1. Sampling Tube: Design and dimensions as recommended by the manufacturer for the specific duct size, air velocity, and installation conditions where applied.

2.5 OTHER DETECTORS

- A. Heat Detector, Combination Type: Actuated by either a fixed temperature of 135 deg F (57 deg C) or rate of rise of temperature that exceeds 15 deg F (8.3 deg C) per minute, unless otherwise indicated.
1. Mounting: Plug-in base, interchangeable with smoke detector bases.
 2. Integral Addressable Module: Arranged to communicate detector status (normal, alarm, or trouble) to the FACP.
- B. Heat Detector, Fixed-Temperature Type: Actuated by temperature that exceeds a fixed temperature of 190 deg F (88 deg C).
1. Mounting: Plug-in base, interchangeable with smoke detector bases.
 2. Integral Addressable Module: Arranged to communicate detector status (normal, alarm, or trouble) to the FACP.

2.6 NOTIFICATION APPLIANCES

- A. Description: Equip for mounting as indicated and have screw terminals for system connections.
1. Combination Devices: Factory-integrated audible and visible devices in a single-mounting assembly.

- B. Selectable-Tone Horns: Electronic-vibrating type, field selectable tone (temporal pattern, chime, high/low/silent), 24 VDC, Horns produce a sound-pressure level of 90dBA, measured 10 feet (3m) from the horn. Built-in provisions for reducing the output to 87dBA and 84dBA.
- C. Weather-Proof Horns (outdoors only): Electronic-vibrating-polarized type, 24-V dc; with provision for housing the operating mechanism behind a grille. Horns produce a sound-pressure level of 90 dB, measured 10 feet (3 m) from the horn.
- D. Visible Alarm Devices: Xenon strobe lights listed under UL 1971 with clear polycarbonate lens. Mount lens on an aluminum faceplate. The word "FIRE" is engraved in minimum 1-inch- (25-mm-) high letters on the lens.
 - 1. Rated Light Output: as shown on drawings, field selectable outputs of 15CD, 30CD, 75CD, and 110CD.
 - 2. Sleeping Room Rated Light Output: 177CD.
 - 3. Synchronization.
 - 4. Strobe Leads: Factory connected to screw terminals.
- E. Voice/Tone Speakers:
 - 1. High-Range Units: Rated 2 to 15 W.
 - 2. Low-Range Units: Rated 1/4 to 2 W, field selectabe.
 - 3. Mounting: Flush, semi-recessed, surface, or surface-mounted; bi-directional as indicated.
 - 4. Matching Transformers: Tap range matched to the acoustical environment of the speaker location.

2.7 MAGNETIC DOOR HOLDERS

- A. Description: Units are equipped for wall or floor mounting as indicated and are complete with matching door plate.
 - 1. Electromagnet: Requires no more than 3 W to develop 25-lbf (111-N) holding force.
 - 2. Wall-Mounted Units: Flush mounted, unless otherwise indicated.
 - 3. Rating: 24-V ac or dc.
 - 4. Furnished by Div. 8.

2.8 CENTRAL FACP

- A. Cabinet: Lockable steel enclosure. Arrange interior components so operations required for testing or for normal maintenance of the

system are performed from the front of the enclosure. If more than one unit is required to form a complete control panel, fabricate with matching modular unit enclosure to accommodate components and to allow ample gutter space for field wiring and interconnecting panels.

1. Identify each enclosure with an engraved, red, laminated, phenolic-resin nameplate with lettering not less than 1 inch (25 mm) high. Identify individual components and modules within cabinets with permanent labels.
 2. Mounting: Surface.
- B. Alarm and Supervisory Systems: Separate and independent in the FACP. Alarm-initiating zone boards consist of plug-in cards. Construction requiring removal of field wiring for module replacement is unacceptable.
- C. Control Modules: Include types and capacities required to perform all functions of fire alarm systems.
- D. Indications: Local, visible, and audible signals announce alarm, supervisory, and trouble conditions. Each type of audible alarm has a different sound.
- E. Resetting Controls: Prevent the resetting of alarm, supervisory, or trouble signals while the alarm or trouble condition still exists.
- F. Alphanumeric Display and System Controls: Arranged for interface between human operator at the FACP and addressable system components, including annunciation, supervision, and control.
1. Display: A minimum of 80 characters; alarm, supervisory, and component status messages; and indicate control commands to be entered into the system for control of smoke detector sensitivity and other parameters.
 2. Keypad: Arranged to permit entry and execution of programming, display, and control commands.
- G. Voice Alarm: An emergency voice/alarm communication system, includes central voice alarm system components complete with microphones, preamplifiers, amplifiers, tone generators, and multiple message memory. Features include the following:
1. Single channel output automatically broadcasts to all zones or floors simultaneously upon alarm. Digitally stored voice message indicates the specific zone of alarm. Include recording

of voice messages for each building smoke compartment zone as indicated on life safety plans.

2. Stored speech memory capacity for 15 sec. alarm messages indicating up to 60 different smoke compartment zones per building. Messages may be broken into words and word stings to form sentences in the message. Refer to fire alarm detail drawings for sample message.
3. Central control microphone allows broadcast of live voice messages.
4. All announcements are made over dedicated, supervised communication lines.
5. Status annunciator indicates the status of various voice alarm speaker zones and the status of firefighters' two-way telephone communication zones.
6. Manual override switch panels for manual control of speaker circuits by floor for live voice announcements from the fire command.
7. One-to-one back up of amplifiers to automatically switch to back up amplifiers in the event of amplifier failure.

2.9 REMOTE ANNUNCIATOR

- A. Description: Duplicate annunciator functions of the FACP for alarm, supervisory, and trouble indications. Also duplicate manual switching functions of the FACP, including acknowledging, silencing, reset, and test.
 1. Mounting: Flush cabinet, NEMA 250, Class 1.
- B. Display Type and Functional Performance: Alphanumeric display same as the FACP. Controls with associated LEDs permit acknowledging, silencing, resetting, and testing functions for alarm, supervisory, and trouble signals identical to those in the FACP.

2.10 EMERGENCY POWER SUPPLY

- A. General: Components include valve-regulated, recombinant lead acid battery; charger; and an automatic transfer switch.
 1. Battery Nominal Life Expectancy: 10 years, minimum.
- B. Battery Capacity:
 1. Comply with NFPA 72.
 2. Magnetic door holders are not served by emergency power.
Magnetic door holders are released when normal power fails.

- 3. Minimum Capacity: 24 hour operation of complete system (except where specifically noted otherwise) plus 15 minutes with all indicating devices. In addition, include 25% spare capacity.
- C. Battery Charger: Solid-state, fully automatic, variable-charging-rate type. Provide capacity for 150 percent of the connected system load while maintaining batteries at full charge. If batteries are fully discharged, the charger recharges them completely within four hours. Charger output is supervised as part of system power supply supervision.
- D. Integral Automatic Transfer Switch: Transfers the load to the battery without loss of signals or status indications when normal power fails.

2.11 ADDRESSABLE INTERFACE DEVICE

- A. Description: Microelectronic monitor module listed for use in providing a multiplex system address for listed fire and sprinkler alarm-initiating devices with normally open contacts.
- B. Integral Relay: Capable of providing a direct signal to the elevator controller to initiate elevator recall or to a circuit-breaker shunt trip for power shutdown.

2.12 DIGITAL ALARM COMMUNICATOR TRANSMITTER

- A. Listed and labeled under UL 864 and NFPA 72.
- B. Functional Performance: Unit receives an alarm, supervisory, or trouble signal from the FACP panel, and automatically captures one or two telephone lines and dials a preset number for a remote central station. When contact is made with the central station(s), the signal is transmitted. The unit supervises up to two telephone lines. Where supervising two lines, if service on either line is interrupted for longer than 45 seconds, the unit initiates a local trouble signal and transmits a signal indicating loss of telephone line to the remote alarm receiving station over the remaining line. When telephone service is restored, unit automatically reports that event to the central station. If service is lost on both telephone lines, the local trouble signal is initiated.
- C. Secondary Power: Integral rechargeable battery and automatic charger. Battery capacity is adequate to comply with NFPA 72 requirements.

- D. Self Test: Conducted automatically every 24 hours with report transmitted to central station.

2.13 SYSTEM PRINTER

- A. Description: Listed and labeled as an integral part of the fire alarm system.

2.14 WIRE

- A. Non-Power-Limited Circuits: Solid-copper conductors with 600-V rated, 75 deg C, color-coded insulation.
 - 1. Low-Voltage Circuits: No. 16 AWG, minimum.
 - 2. Line-Voltage Circuits: No. 12 AWG, minimum.
- B. Power-Limited Circuits: NFPA 70, Types FPL, FPLR, or FPLP, as recommended by manufacturer.

PART 3 - EXECUTION

3.1 EQUIPMENT INSTALLATION

- A. Connect the FACP with a disconnect switch with lockable handle or cover.
- B. Manual Pull Stations: Mount semiflush in recessed back boxes.
- C. Water-Flow Detectors and Valve Supervisory Switches: Connect for each sprinkler valve station required to be supervised.
- D. Ceiling-Mounted Smoke Detectors: Not less than 4 inches (100 mm) from a side wall to the near edge. For exposed solid-joist construction, mount detectors on the bottom of joists. On smooth ceilings, install not more than 30 feet (9 m) apart in any direction.
- E. Wall-Mounted Smoke Detectors: At least 4 inches (100 mm), but not more than 12 inches (300 mm), below the ceiling.
- F. Smoke Detectors near Air Registers: Install no closer than 60 inches (1520 mm).
- G. Duct Smoke Detectors: Comply with manufacturer's written instructions.
 - 1. Verify that each unit is listed for the complete range of air velocity, temperature, and humidity possible when air-handling system is operating.
 - 2. Install sampling tubes so they extend the full width of the duct.
- H. Heat Detectors in Elevator Shafts: Coordinate temperature rating

and location with sprinkler rating and location.

- I. Audible Alarm-Indicating Devices: Install not less than 6 inches (150 mm) below the ceiling. Install bells and horns on flush-mounted back boxes with the device-operating mechanism concealed behind a grille. Combine audible and visible alarms at the same location into a single unit.
- J. Visible Alarm-Indicating Devices: Install adjacent to each alarm bell or alarm horn and at least 6 inches (150 mm) below the ceiling.
 - 1. Synchronization: synchronize any two strobes located such that they are visible from the same location.
- K. FACP: Surface mount with tops of cabinets not more than 72 inches (1830 mm) above the finished floor.
- L. Annunciator: Install with the top of the panel not more than 60 inches (1524 mm) above the finished floor.

3.2 WIRING INSTALLATION

- A. Wiring Method: Install wiring in metal raceway according to Division 16 Section "Raceways and Boxes." Conceal raceway except in unfinished spaces and as indicated.
- B. Wiring within Enclosures: Separate power-limited and non-power-limited conductors as recommended by the manufacturer. Install conductors parallel with or at right angles to sides and back of the enclosure. Bundle, lace, and train conductors to terminal points with no excess. Connect conductors that are terminated, spliced, or interrupted in any enclosure associated with the fire alarm system to terminal blocks. Mark each terminal according to the system's wiring diagrams. Make all connections with approved crimp-on terminal spade lugs, pressure-type terminal blocks, or plug connectors.
- C. Cable Taps: Use numbered terminal strips in junction, pull and outlet boxes, cabinets, or equipment enclosures where circuit connections are made.

Color-Coding: Color-code fire alarm conductors differently from the normal building power wiring. Use one color-code for alarm circuit wiring and a different color-code for supervisory circuits. Color-code audible alarm-indicating circuits differently from alarm-

initiating circuits. Use different colors for visible alarm-indicating devices. Paint fire alarm system junction boxes and covers red.

- D. Risers: Install at least two vertical cable risers to serve the fire alarm system. Separate risers in close proximity to each other with a minimum one-hour-rated wall, so the loss of one riser does not prevent the receipt or transmission of signal from other floors or zones.
- E. Wiring to Remote Alarm Transmitting Device: 1-inch (25-mm) conduit between the FACP and the transmitter. Install number of conductors and electrical supervision for connecting wiring as needed to suit monitoring function.

3.3 IDENTIFICATION

- A. Identify system components, wiring, cabling, and terminals according to Division 16 Section "Electrical Identification."
 - 1. Paint all fire alarm system junction boxes, device boxes, and pull boxes with red paint.
- B. Install instructions frame in a location visible from the FACP.
- C. Prepare laminated drawings showing each device and identifying the device address or zone
- D. Paint power-supply disconnect switch red and label "FIRE ALARM."

3.4 GROUNDING

- A. Signal Ground Terminal: Locate at main equipment rack or cabinet. Isolate from power system and equipment grounding.
- B. Install grounding electrodes of type, size, location, and quantity as indicated. Comply with installation requirements in Division 16 Section "Grounding."
- C. Ground equipment and conductor and cable shields. For audio circuits, minimize, to the greatest extent possible, ground loops, common-mode returns, noise pickup, cross talk, and other impairments. Provide 5-ohm ground at main equipment location. Measure, record, and report ground resistance.

3.5 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect field-assembled components and connections

and to supervise pretesting, testing, and adjustment of the system. Report results in writing.

- B. Pretesting: After installation, align, adjust, and balance the system and perform complete pretesting. Determine, through pretesting, the compliance of the system with requirements of Drawings and Specifications. Correct deficiencies observed in pretesting. Replace malfunctioning or damaged items with new ones, and retest until satisfactory performance and conditions are achieved. Prepare forms for systematic recording of acceptance test results.
- C. Report of Pretesting: After pretesting is complete, provide a letter certifying the installation is complete and fully operable, including the names and titles of witnesses to preliminary tests.
- D. Final Test Notice: Provide a minimum of 10 days' notice in writing when the system is ready for final acceptance testing.
- E. Minimum System Tests: Test the system according to procedures outlined in NFPA 72. Minimum required tests are as follows:
 - 1. Verify the absence of unwanted voltages between circuit conductors and ground.
 - 2. Test all conductors for short circuits using an insulation-testing device.
 - 3. With each circuit pair, short circuit at the far end of the circuit and measure the circuit resistance with an ohmmeter. Record the circuit resistance of each circuit on record drawings.
 - 4. Verify that the control unit is in the normal condition as detailed in the manufacturer's operation and maintenance manual.
 - 5. Test initiating and indicating circuits for proper signal transmission under open circuit and ground fault conditions. One connection each should be opened at not less than 10 percent of initiating and indicating devices. Observe proper signal transmission according to class of wiring used.
 - 6. Test each initiating and indicating device for alarm operation and proper response at the control unit.
 - a. Test smoke detectors with actual products of combustion.

- b. Test each heat detector with hair dryer or other means approved by the manufacturer.
 - c. Test fan shut down, sprinkler flow and tamper switches, door closers, magnetic door holders, and elevator return.
 - 7. Test the system for all specified functions according to the approved operation and maintenance manual. Systematically initiate specified functional performance items at each station, including making all possible alarm and monitoring initiations and using all communications options. For each item, observe related performance at all devices required to be affected by the item under all system sequences. Observe indicating lights, displays, signal tones, and annunciator indications.
 - 8. Test Both Primary and Secondary Power: Verify by test that the secondary power system is capable of operating the system for the period and in the manner specified.
 - a. Disconnect fire alarm from primary power source 24 hours prior to test, or longer as specified. Test all indicating devices to determine whether audio and visual devices comply with testing requirements for a 15 minute test.
 - F. Retesting: Correct deficiencies indicated by tests and completely retest work affected by such deficiencies. Verify by the system test that the total system meets Specifications and complies with applicable standards.
 - G. Report of Tests and Inspections: Provide a written record of inspections, tests, and detailed test results in the form of a test log. Submit log on the satisfactory completion of tests.
 - H. Tag all equipment, stations, and other components at which tests have been satisfactorily completed.
- 3.6 CLEANING AND ADJUSTING**
- A. Cleaning: Remove paint splatters and other spots, dirt, and debris. Touch up scratches and marred finish to match original finish. Clean unit internally using methods and materials recommended by manufacturer.
- 3.7 DEMONSTRATION**
- A. Engage a factory-authorized service representative to train Owner's maintenance personnel as specified below:

1. Train Owner's maintenance personnel on procedures and schedules for starting and stopping, troubleshooting, servicing, adjusting, and maintaining equipment and schedules. Provide a minimum of 8 hours' training.
2. Training Aid: Use the approved final version of the operation and maintenance manual as a training aid.
3. Schedule training with Owner, through Architect, with at least seven days' advance notice.

3.8 ON-SITE ASSISTANCE

- A. Occupancy Adjustments: When requested within one year of date of Substantial Completion, provide on-site assistance in adjusting sound levels, controls, and sensitivities to suit actual occupied conditions. Provide up to three requested visits to Project site for this purpose.

- - - E N D - - -