



FLOOR PLAN – DEMOLITION
SCALE: 1/4"=1'-0"



FLOOR PLAN – PIPING
SCALE: 1/4"=1'-0"

GENERAL NOTES


- A. PROJECT WILL NEED TO BE DONE IN PHASES AND WILL REQUIRE AFTER HOURS WORK. COORDINATE CAREFULLY WITH THE VA TO MAINTAIN WATER SUPPLY TO THE HOSPITAL AND KEEP INTERRUPTIONS TO A MINIMUM.
- B. INSULATE NEW PIPING WITH FIBERGLASS INSULATION AND REPAIR ALL EXISTING INSULATION DISTURBED DURING CONSTRUCTION (PER VA DESIGN MANUAL).
- C. PROVIDE HANGERS AND SUPPORTS TO PROPERLY SUPPORT AND ALIGN PIPING (PER ASME AND VA DESIGN MANUAL).
- D. NEW DRIVES AND PUMP SKIDS TO MATCH EXISTING UNITS.
- E. CONTRACTOR SHALL WORK WITH THEIR VFD SUPPLIER AND SUBMIT A SEQUENCE OF OPERATION FOR THE DRIVES BASED ON CURRENT FLOW DATA FOR THE HOSPITAL AND SUBMIT FOR APPROVAL.




VARIABLE FREQUENCY DRIVES DETAIL
NO SCALE

SYMBOL LIST

- |— CHECK VALVE
- |— BALL VALVE
- |— BUTTERFLY VALVE
- |— GATE VALVE
- POINT OF CONNECTION (NEW TO EXISTING)
- PS DIRECTED SUPPLY



PIPING SCHEMATIC
NO SCALE



KEY PLAN
SCALE: NONE

ISSUE FOR BID Revisions	3/27/13 Date	VA WESTERN NEW YORK HEALTHCARE SYSTEM 3495 BAILEY AVENUE BUFFALO, NEW YORK 14215	CLINICAL ENGINEERING	DATE	ENGINEERING MANAGER	DATE	Drawing Title FLOOR PLANS AND NOTES	Project Title BOOSTER PUMP VFD'S	Date MARCH 27, 2013	Station No. 528	12-S13-M101	Office of Facilities	Department of Veterans Affairs
			INFECTION CONTROL	DATE	CARELINE MANAGER	DATE							
			SAFETY OFFICER	DATE	CHIEF OF STAFF	DATE							
			MEDICAL CENTER DIRECTOR	DATE	ASSOCIATE MEDICAL CENTER DIRECTOR	DATE							
Building Number 1		Checked VR	Drawn RLR	Location V.A.M.C. BUFFALO, NEW YORK									