



## SPRINKLER SYSTEM ZONING NOTES

EXISTING SPRINKLERS AND PIPING IN THIS AREA SHALL BE MODIFIED AND RELOCATED AS REQUIRED TO ACCOMMODATE NEW ENTRANCE INTO AMBULATORY SURGERY SUITE (LIGHT HAZARD).

ORDINARY HAZARD GROUP 2 - .2 GPM OVER MOST REMOTE 1500 SQ. FT., MAXIMUM SPRINKLER COVERAGE SHALL BE 130 SQ. FT. PER SPRINKLER. (STORAGE ROOMS, TRASH ROOMS, CLEAN AND SOILED LINEN ROOMS AND SIMILAR AREAS)



FINAL DRAWING SUBMISSION (100%)  
FULLY SPRINKLERED