

AMBIENT TEMP 95°F DB
100% WATER

1

CHILLER(S)

TAG	DESCRIPTION/ LOCATION	EWT °F	LWT °F	GPM	PD (FT)	TONS	NPLV / EER	ELECTRICAL DATA				M
								VOLTS	PHASE	MCA	MOCP	
(CH-1)E	EXISTING AIR COOLED CHILLER	54	44	240	25	90	-	208	3	-	-	MC
CH-2	AIR COOLED CHILLER 1ST FLOOR	54	44	89.2	6.1	37.2	14.5/10.1	208	3	224	250	1
-	-	-	-	-	-	-	-	-	-	-	-	

REQ'D ACCESS

1. FACTORY MOUNTED DISCONNECT
2. VIBRATION ISOLATORS (SPRING / NEOPRENE)
3. HOT GAS BY-PASS ALL CIRCUITS (RECIPROCATING COMPRESSOR(S) ONLY)
4. SINGLE POINT POWER CONNECTION
5. WATER FLOW SWITCH
6. SEE SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS

1 DEL Addendum #1
Add. Date: 06-10-13



DATE: 06-04-13
PROJECT NO.: 120053
DWN BY: SWH

REPLACE COND. UNITS B305

DAYTON VAMC
BUILDING 305

Dynamix
Engineering Ltd.
Facility Engineering Consultants

COPYRIGHT
DYNAMIX ENGINEERING LTD. ALL RIGHTS RESERVED

REVISES SHEET
M0

SK1-M0