



7. ALL EXISTING SURFACE MOUNTED BACKBOXES, CONDUIT, WIREWAY, JUNCTION BOXES, ETC., SHOWN REMOVED SHALL BE REMOVED IN THEIR ENTIRETY. ALL RECESSED BACKBOXES, JUNCTION BOXES SHOWN REMOVED SHALL BE ABANDONED IN PLACE AND COVERED WITH STAINLESS STEEL COVER PLATES. ALL RECESSED CONDUIT SHALL BE ABANDONED IN PLACE AND CAPPED OFF IN A SUITABLE MANNER PER LOCAL INSPECTORS REQUIREMENTS.
9. REMOVE ELECTRICAL CONNECTIONS TO ALL MECHANICAL EQUIPMENT BEING REMOVED BY DIVISION 15. COORDINATE EQUIPMENT REMOVAL LOCATIONS WITH MECHANICAL DRAWINGS.

1 DOOR ACTIVATOR PUSH PAD.
2 DOOR OPERATOR.

- 1 LOCATE INSIDE ENCLOSURE PER ELECTRIC WATER COOLER MANUFACTURERS REQUIREMENTS.
- 2 PROVIDE CONNECTION TO AUTOMATIC DOOR OPERATOR INCLUDING REMOTE KEYPAD, KEYED SWITCH, ACTUATORS, REQUEST TO EXIT DEVICE, POWER SUPPLY, ETC. SWITCHES AND DEVICE BOX FOR ACTUATORS ARE PROVIDED BY THE EQUIPMENT SUPPLIER. COORDINATE REQUIREMENTS WITH EQUIPMENT SUPPLIER AND EQUIPMENT LOCATIONS WITH OWNER.