



Install (5) Low Energy Automatic Power Door Operators Bldg 1 room 43 and 44. Each door shall receive 24V electric strike operated by the power door operator and wireless activating push buttons with push plates, COR will determine exact location of push plates. All power door operator finishes shall be dark bronze anodize aluminum. All installations shall meet Uniform Federal Accessibility Standards and ANSI A156.19 Key operated electric switch will be utilized to deactivate power door operator on all doors (except for restroom in room 43) to achieve effectively locking function. All wiring and conduit runs shall be concealed. All branch circuits shall be connected to Emergency Power.

ELECTRIC KEY SWITCH,
Double pole-single throw, compatible to a mortise cylinder that will accept an interchangeable Best 7 pin core.
Switch lock action: Maintained (off-on)
Horsepower rating: 1 HP @ 125-250 VAC or VDC. All wiring and conduit runs shall be concealed. All branch circuits shall be connected to Emergency Power.

NO.	DATE	REVISIONS
1	01/11/06	ISSUED FOR PERMIT
2	01/11/06	ISSUED FOR PERMIT
3	01/11/06	ISSUED FOR PERMIT
4	01/11/06	ISSUED FOR PERMIT
5	01/11/06	ISSUED FOR PERMIT
6	01/11/06	ISSUED FOR PERMIT
7	01/11/06	ISSUED FOR PERMIT
8	01/11/06	ISSUED FOR PERMIT
9	01/11/06	ISSUED FOR PERMIT
10	01/11/06	ISSUED FOR PERMIT
11	01/11/06	ISSUED FOR PERMIT
12	01/11/06	ISSUED FOR PERMIT
13	01/11/06	ISSUED FOR PERMIT
14	01/11/06	ISSUED FOR PERMIT
15	01/11/06	ISSUED FOR PERMIT
16	01/11/06	ISSUED FOR PERMIT
17	01/11/06	ISSUED FOR PERMIT
18	01/11/06	ISSUED FOR PERMIT
19	01/11/06	ISSUED FOR PERMIT

Building 1
Ground Floor Plan
1G
2006
V.A. MEDICAL CENTER
CANANDAIGUA, NY 14424