

CODED NOTES:


- 1 REMOVE EXISTING STEAM TRAPS COMPLETE.
- 2 INSTALL NEW STEAM TRAP/PUMP AND ASSOCIATED PIPING. CONNECT PIPING TO EXISTING CONDENSATE RISER. SEE DETAIL 3 ON SHEET 1-03 FOR PIPING SCHEMATIC.

ISSUED FOR REBID	06-23-13
FINAL CD-SUBMISSION	12-21-12
95% SUBMISSION	11-30-12
65% SUBMISSION	11-16-12
Revisions:	
Date	

CONSULTANTS:



**FREDRICK, FREDRICK & HELLER
ENGINEERS, INC.**
672 EAST ROYALTON ROAD
BROADVIEW HTS., OHIO 44147
TEL. (440) 546-0696
FAX: (440) 546-0698



ARCHITECT:

Drawing Title	Project Number
BASEMENT STREAM/CONDENSATE PIPING DETAILS	541-12-115
	Building Number
	1
Approved: Project Director	Drawing Number
	4-03

**Office of
Facilities
Management**

