



**6 TYPICAL CONSTANT VOLUME EXHAUST
TERMINAL UNIT DIAGRAM (TYPE E)**

NOT TO SCALE

TYPICAL CONSTANT VOLUME EXHAUST TERMINAL UNIT SEQUENCE OF OPERATION:

1. THE TERMINAL UNIT SHALL BE INDIVIDUALLY CONTROLLED BY ITS OWN DDC VAV CONTROLLER.
2. THE EXHAUST AIR TERMINAL UNIT SHALL MAINTAIN A CONSTANT EXHAUST AIR FLOW INDEPENDENT OF PRESSURE FLUCTUATIONS IN THE EXHAUST AIR INTAKE.
3. THE DDC BOX SHALL COMMUNICATE THE TERMINAL UNIT DAMPER POSITION AND AIR FLOW TO THE DDC SYSTEM.

REF: SHT. H9.5

ARCHITECTS
H A W A I I
L I M I T E D

Paula Toner, Supt. 300
1001 Broadway, Suite 100
New York, NY 10013
(212) 512-4438
(212) 512-3285

AMENDMENT NO. 1

TYPICAL CONSTANT VOLUME
EXHAUST TERMINAL UNIT DIAGRAM

AMBULATORY CARE AND RENOVATE E-WING
PHASE I, AMBULATORY CARE CLINIC

Drawn by MLO
Project No. 459-002A
Date APR 4, 1997
Drawing No.

H-516
Series