



NOTE1: RETURN DUCT TO AUDIOBOOTH SHALL BE FLEXIBLE DUCT CONNECTED TO 8" DUCT ON ROOF OF AUDIOBOOTH WITH HOSE CLAMPS. CONTRACTOR SHALL COORDINATE WITH AUDIOBOOTH MFR TO ENSURE ALL CONNECTIONS ARE PROPERLY ADDRESSED

1 MECHANICAL PLAN - RETURN & EXHAUST
MH102 SCALE: 1/4" = 1'-0"

FINAL SUBMISSION
APRIL 9, 2013

 786 MOBILE ST., FARMHOPE, AL 36532 251-990-5778 ARCH. & ENGR. SEAL 	NATURAL RESOURCES & ENVIRONMENTAL AFFAIRS		P.W. DWG. NO.		DEPARTMENT OF THE NAVY NAVAL SUPPORT ACTIVITY PANAMA CITY, FLORIDA	
	SAFETY DEPARTMENT		DRAWN BY R. LONDOÑO		CONSTRUCT NAVAL BRANCH HEALTH CLINIC PANAMA CITY	
	FIRE DEPARTMENT		CHECKED BY R. DeLOACH		MECHANICAL PLAN RETURN & EXHAUST	
	PUBLIC WORKS SUPERVISOR		SUPERVISOR B. COFFMAN		N/A V F A C DRAWING NO. N/A	
APPROVED		DATE		SIZE F		CODE IDENT. NO.
PUBLIC WORKS OFFICER				FROM PROJ. NO. 520-13-200		CONSTR. CONTR. NO.
				SCALE		MACC. T.O.# SHEET 5 OF 9

MH102