


Calculation Summary									
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	FtSpLx	PerspCtB
001 ELBCT_Workplane	Illuminance	Fc	27.07	36.0	17.0	1.59	2.12	2	2
002 LOUNGE_Workplane	Illuminance	Fc	38.70	51.8	24.8	1.56	2.09	2	2
003 LCPC-LPO_Workplane	Illuminance	Fc	44.56	58.7	30.6	1.46	1.92	2	2
004 OIC_Workplane	Illuminance	Fc	53.62	75.6	33.1	1.62	2.28	2	2
005 COPY_Workplane	Illuminance	Fc	32.98	40.9	25.9	1.27	1.58	2	2
005 STORAGE_Workplane	Illuminance	Fc	32.62	38.1	28.4	1.15	1.34	2	2
007 KIOSK-CHECK IN_Workplane	Illuminance	Fc	41.82	52.6	34.2	1.22	1.54	2	2
010 WOMENS_Workplane	Illuminance	Fc	20.93	26.5	15.1	1.39	1.75	2	2
011 ADULT SCREENING_Workplane	Illuminance	Fc	60.71	83.9	40.7	1.49	2.06	2	2
012 EXAM 1_Workplane	Illuminance	Fc	56.08	82.6	33.4	1.68	2.47	2	2
013 PROVIDER_Workplane	Illuminance	Fc	37.95	52.0	23.3	1.63	2.23	2	2
014 EXAM 2_Workplane	Illuminance	Fc	55.27	86.1	31.7	1.74	2.72	2	2
015 VISION TEST_Workplane	Illuminance	Fc	56.15	86.8	33.4	1.68	2.60	2	2
016 IMMUNIZATION_Workplane	Illuminance	Fc	59.15	106	19.6	3.02	5.40	2	2
017 OCC-HEALTH_Workplane	Illuminance	Fc	50.15	71.7	32.2	1.56	2.23	2	2
018 PREV MED NURSE_Workplane	Illuminance	Fc	50.25	71.8	32.8	1.53	2.19	2	2
019 TREATMENT_Workplane	Illuminance	Fc	52.29	78.8	29.4	1.78	2.68	2	2
020 EXAM SCREENING_Workplane	Illuminance	Fc	63.16	104	33.4	1.89	3.10	2	2
021 STORAGE_Workplane	Illuminance	Fc	30.11	52.2	15.4	1.96	3.39	2	2
022 MENS LOCKER_Workplane	Illuminance	Fc	16.52	27.2	8.1	2.04	3.36	2	2
023 WOMENS LOCKER_Workplane	Illuminance	Fc	16.59	27.3	8.2	2.02	3.33	2	2
024 STAFF MEN TLT_Workplane	Illuminance	Fc	17.26	24.2	10.3	1.68	2.35	2	2
025 STAFF WOMEN TLT_Workplane	Illuminance	Fc	17.87	24.8	12.3	1.45	2.02	2	2
026 RECORDS_Workplane	Illuminance	Fc	48.79	81.1	23.0	2.12	3.53	2	2
027 COMM_Workplane	Illuminance	Fc	53.41	70.3	37.4	1.43	1.88	2	2
029 CHAIR STOR-CORR_Workplane	Illuminance	Fc	22.46	32.4	11.2	2.01	2.89	2	2
030 SOUTLED_Workplane	Illuminance	Fc	27.51	50.0	15.0	1.83	3.33	2	2
031 CLEAN_Workplane	Illuminance	Fc	30.39	52.4	16.1	1.89	3.25	2	2
033 AUDIO_Workplane	Illuminance	Fc	55.31	87.6	28.6	1.93	3.06	2	2
034 JAN_Workplane	Illuminance	Fc	17.47	19.2	16.3	1.07	1.18	2	2
037 WAITING-CIRCULATION_Floor	Illuminance	Fc	24.71	36.2	5.2	4.75	6.96	2	2
FRONT DESK	Illuminance	Fc	36.41	46.0	25.7	1.42	1.79	2	2
MAIN CORRIDOR_Floor	Illuminance	Fc	22.44	32.0	4.4	5.10	7.27	2	2
EXTERIOR	Illuminance	Fc	3.71	7.9	0.1	37.10	79.00	4	4

FINAL SUBMISSION
APRIL 9, 2013



IF SHEET IS LESS THAN (30"x42") IT IS
A REDUCED PRINT; SCALE ACCORDINGLY

EL200

 766 MIDDLE ST., PANAMA, FL 32402 251-990-0778 ARCH. & ENGR. SEAL FLORIDA BES DESIGN/BUILD LLC No. 29795 STATE OF FLORIDA PROFESSIONAL ENGINEER	NATURAL RESOURCES & ENVIRONMENTAL AFFAIRS SATISFACTORY TO DATE	P.W. DWG. NO.	DEPARTMENT OF THE NAVY NAVAL FACILITIES ENGINEERING COMMAND PANAMA CITY, FLORIDA
	SAFETY DEPARTMENT SATISFACTORY TO DATE	DRAWN BY CWS	CONSTRUCT NAVAL BRANCH HEALTH CLINIC PANAMA CITY
	FIRE DEPARTMENT SATISFACTORY TO DATE	CHECKED BY KDE	LIGHTING CALCULATIONS
	PUBLIC WORKS SUPERVISOR SATISFACTORY TO DATE	SUPERVISOR WWB	DATE APPROVED
PUBLIC WORKS OFFICER		SCALE 3/16"=1'-0"	CONSTR. CONTR. NO. N/A