

KEY NOTES:

① GENERAL DEMOLITION OF EXISTING WALLS
② DEMOLITION OF EXISTING FLOORING, ABATE IF REQUIRED. (APPROXIMATELY 200 SQFT FOR FLOORING AND 200 LF FOR PIPING) RE-ROUTE PIPING AS REQUIRED. COORDINATE WITH COR.
③ DEMOLITION OF PIPE CHASE ABATE IF REQUIRED (APPROXIMATELY 200 LF) RE-ROUTE PIPING AS REQUIRED. COORDINATE WITH COR
④ DEMOLITION THAT WILL REQUIRE MODIFICATION WITH STRUCTURAL ENGINEER APPROVAL.
⑤ REMOVE AND DEMO EXISTING FRONT ENTRANCE AFTER WORK FOR ITEM-4 AND NEW GLASS STRUCTURE HAS BEEN COMPLETED AND APPROVED BY COR. SEE DRAWING A-101 AND S-102.
⑥ EXISTING DOOR TO BE REMOVED AND AREA TO BE FILL IN BY NEW WALL TO MATCH EXISTING SURROUNDING STRUCTURE.

EXISTING WALL TO BE DEMOLITION OR TO BE REFURBISH FOR NEW WALL APPLICATION. PLEASE SEE FINISHES AND DEMOLITION DRAWINGS.

ALL CONSTRUCTION BARRIERS ARE TO BE INSPECTED BY COR AND APPROVED BEFORE ANY CONSTRUCTION CAN TAKE PLACE. IF ADDITIONAL BARRIERS ARE REQUIRE OR ADDITIONAL PROTECTION THAN THE CONTRACTOR IS RESPONSIBLE TO COMPLY FOR THE SAFETY OF STAFF AND PATIENTS AT VAMC SALISBURY.

PLEASE NOTE MECHANICAL, ELECTRICAL, FIRE SUPPRESSION, AND OTHER DRAWINGS FOR LOCATION OF EXISTING UTILITIES AND STRUCTURAL COLUMNS. CONTRACTOR TO VERIFY EXISTING CONDITIONS WITH EXPLORATORY INVESTIGATION BEFORE DEMOLITION WORK CAN TAKE PLACE.

ACOUSTIC CEILING GRID AND TILES SHALL BE REMOVED. REPLACE WITH NEW AS PER SEE FINISHES SCHEDULE A-102. CONTRACTOR TO VERIFY EXISTING CONDITIONS ABOVE CEILING GRID FOR CHILL WATER, MEDICAL GAS, FIRE SUPPRESSION, AND OTHER UTILITY AND LIFE SAFETY ITEMS BEFORE ANY DEMOLITION WORKS CAN TAKE PLACE. ANY DAMAGED THAT OCCURS TO EXISTING UTILITIES WILL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPAIR EVEN IF AN ITEM IS SCHEDULE FOR REMOVAL ALL SYSTEM MUST TO BE MAINTAIN UNTIL COORDINATION HAS BE DONE FOR THEIR REMOVAL.

DETAIL FOR TYP. DUST BARRIERS FOR DOUBLE DOORS



PRIOR TO ANY WORK A DUST PARTITIONS SHALL BE CONSTRUCTED OF 2x4 STUDS AND ⅝"GYPSUM BOARD. PAINT ALL EXPOSED SIDE OF THE PARTITION WHITE. THE PARTITION SHALL BE SECURED TO AND SEALED TO ADJACENT SURFACES WITH POLYETHYLENE AND TAPE AS REQUIRED FOR A COMPLETE SEAL. PROVIDE EACH DUST PARTITION WITH A 3'-0" x 7'-0" DOOR THAT IS EQUIPPED WITH SELF CLOSING HINGES AND A HASP. THE DOOR SHALL BE SECURED WITH A VA PROVIDED PADLOCK. EACH DUST PARTITION SHALL BE EQUIPPED WITH A CONTRACTOR FURNISHED FIRE EXTINGUISHER. THE SIZE OF EACH DUST PARTITION SHALL VARY AS REQUIRED TO MEET THE NEEDS OF EACH PROJECT.
CONTRACTOR SHALL COORDINATE THE CONSTRUCTION OF ALL DUST PARTITIONS WITH THE COTR AND MUST BE APPROVED AS PER DETAIL ABOVE OR EQUIVALENT PROTECTION.
NEGATIVE AIR SHALL BE PROVIDE AT ALL TIMES IN WORK AREA TO PROTECT ANY DUST FROM ENTERING OUTSIDE THE CONSTRUCTION AREA. NO WORK CAN TAKE PLACE BEFORE INFECTION CONTROL HAS APPROVED DUST BARRIERS AND NEGATIVE AIR.
ALL EMPLOYEES SHALL SUBMIT COPY OF TB TEST BEFORE THEY CAN ENTER THE WORK SITE. AT ANY TIME IF IS FOUND THAT AN EMPLOYEE HAS ENTER THE CONSTRUCTION AND HAS NOT SUBMITTED THE TB TO COR ALL WORK SHALL BE STOPPED.

DETAIL FOR TYP. DUST BARRIERS FOR SINGLE DOORS



PRIOR TO ANY WORK A DUST PARTITIONS SHALL BE CONSTRUCTED OF 2x4 STUDS AND ⅝"GYPSUM BOARD. PAINT ALL EXPOSED SIDE OF THE PARTITION WHITE. THE PARTITION SHALL BE SECURED TO AND SEALED TO ADJACENT SURFACES WITH POLYETHYLENE AND TAPE AS REQUIRED FOR A COMPLETE SEAL. PROVIDE EACH DUST PARTITION WITH A 3'-0" x 7'-0" DOOR THAT IS EQUIPPED WITH SELF CLOSING HINGES AND A HASP. THE DOOR SHALL BE SECURED WITH A VA PROVIDED PADLOCK. EACH DUST PARTITION SHALL BE EQUIPPED WITH A CONTRACTOR FURNISHED FIRE EXTINGUISHER. THE SIZE OF EACH DUST PARTITION SHALL VARY AS REQUIRED TO MEET THE NEEDS OF EACH PROJECT.
CONTRACTOR SHALL COORDINATE THE CONSTRUCTION OF ALL DUST PARTITIONS WITH THE COTR AND MUST BE APPROVED AS PER DETAIL ABOVE OR EQUIVALENT PROTECTION.
NEGATIVE AIR SHALL BE PROVIDE AT ALL TIMES IN WORK AREA TO PROTECT ANY DUST FROM ENTERING OUTSIDE THE CONSTRUCTION AREA. NO WORK CAN TAKE PLACE BEFORE INFECTION CONTROL HAS APPROVED DUST BARRIERS AND NEGATIVE AIR.
ALL EMPLOYEES SHALL SUBMIT COPY OF TB TEST BEFORE THEY CAN ENTER THE WORK SITE. AT ANY TIME IF IS FOUND THAT AN EMPLOYEE HAS ENTER THE CONSTRUCTION AND HAS NOT SUBMITTED THE TB TO COR ALL WORK SHALL BE STOPPED.

REVISION: CHANGES IN LF #SQFT NOTES	01 JULY 2015
Revision	Date

RECOMMEND APPROVAL

REQUESTER	Date		
CHIEF OF SERVICE	Date	CHIEF OF STAFF	Date
ASSOC. DIR. PATIENT CARE SVC.	Date	ASSOC. DIR. for OPERATIONS	Date
APPROVAL BY: MEDICAL CENTER DIRECTOR			Date

Drawing Title: WALL DEMOLITION	Project Title: B-2 ENTRANCE RENOVATION		Date: 15 MAR 2013
			Project No. 659-13-115
Approved: Safety Manager/M&O Supervisor	Building Number: BUILDING #2	Checked	Drawn: BLF
Approved:Chief of Facilities Management Svr.	Location: W.G.(Bill) Hefner Medical Center 1601 Brenner Ave. Salisbury NC 28144		DRAWING NO. AD-102 DWG. 4 OF 28

Department of Veterans Affairs