

KEY NOTES:

CONTRACTOR TO REPLACE EXISTING FIRE SPRINKLERS LINES AND HEADS IN AREAS THAT ARE RENOVATED WITH HARD PIPE THAT MEETS VA FIRE PROTECTION DESIGN GUIDE. (FM & 46 APPROVED)

SPRINKLERS TO BE ADDED TO THE GLASS STRUCTURE AREA AND PAINTED TO TO MATCH THE GLASS STRUCTURE. DRAWING TO BE SUBMITTED AS PER VA FIRE SUPPRESSION DESIGN GUIDE FOR GOVERNMENT APPROVAL.

Revision	Date
REVISION: CLARIFICATION IN SCOPE	01 JULY 2013

RECOMMEND APPROVAL

REQUESTER	Date		
CHIEF OF SERVICE	Date	CHIEF OF STAFF	Date
ASSOC. DIR. PATIENT CARE SVC.	Date	ASSOC. DIR. for OPERATIONS	Date
APPROVAL BY: MEDICAL CENTER DIRECTOR			Date

Drawing Title: COFFEE SHOP LAYOUT

Project Title: B-2 ENTRANCE RENOVATION

Approved: Safety Manager/M&O Supervisor

Approved:Chief of Facilities Management Svr.

Building Number: BUILDING #2 | Checked | Drawn: BLF

Location: W.G.(Bill) Hefner Medical Center, 1601 Brenner Ave, Salisbury NC 28144

Date: 15 MAY 2013

Project No.: 659-13-115

DRAWING NO. FP-101

DWG. 19 OF 28

Department of Veterans Affairs