

4 / E2 BASEMENT PARTIAL PLAN–RM SL21
SCALE: 1/16" = 1'–0"



5 / E2 BASEMENT KEY PLAN
SCALE: NONE



3 / E2 BASEMENT PARTIAL PLAN–PA
SCALE: 1/8" = 1'–0"



2 / E2 ELECTRICAL LIGHTING PARTIAL PLAN
SCALE: 1/8" = 1'–0"



1 / E2 ELECTRICAL LIGHTING PARTIAL PLAN
SCALE: 1/8" = 1'–0"

GENERAL DRAWING NOTES:

A. PROVIDE RED COVERS AND RED DEVICES FOR SWITCHES ON EMERGENCY CIRCUITS. LABEL WITH PANEL AND CIRCUIT ID.

B. ALL PA CABLING SHALL BE RUN IN YELLOW CONDUIT.

C. NOTE: SYRACUSE TIME AND ALARM IS A LOCAL APPROVED VENDOR AVAILABLE FOR PA SYSTEM WORK. LOCAL CONTACT IS CHARLES SAUNDERS, SYRACUSE TIME & ALARM, 315–403–0893.

D. PROVIDE PANEL AND CIRCUIT ID ON ALL SWITCH COVERS.

E. SEE ARCHITECTURAL CEILING PLANS FOR LIGHT FIXTURE PRECISE LOCATIONS.

KEYED DRAWING NOTES:

(1) REMOVE PA CEILING SPEAKER FROM DEMOLISHED AREA AND REPLACE WITH NEW SPEAKER IN NEW AREA. VERIFY SPEAKER IS FUNCTIONING BEFORE REMOVAL.

(2) PROVIDE NEW PA CEILING SPEAKER AT LOCATION SHOWN AND CONNECT TO PA SYSTEM.

(3) PROVIDE NEW PA CEILING SPEAKER AT LOCATION SHOWN WITH WALL MOUNT VOLUME CONTROL AND CONNECT TO PA SYSTEM.

OCCUPANCY SENSOR LEGEND:

$_{OS}$ WALL SWITCH DUAL TECHNOLOGY VACANCY SENSOR, BASIS OF DESIGN: HUBBELL AUTOMATION LHMTSI, MANUAL–ON/AUTO OFF, 180° COVERAGE, 800W AT 120V, 1800W AT 277V.

(OS) CEILING MOUNT DUAL TECHNOLOGY SMALL MOTION CEILING SENSOR, BASIS OF DESIGN HUBBELL AUTOMATION OMNIDIABP1277, LINE VOLTAGE, 2400W AT 120V, 5000W AT 277V.

(OS)$_1$ CEILING MOUNT DUAL TECHNOLOGY SMALL MOTION CEILING SENSOR, BASIS OF DESIGN: HUBBELL AUTOMATION OMNIDIA, LOW VOLTAGE, PROVIDE COMPATIBLE 2–POLE POWER PACK.

NOTES:

MULTIPLE OCCUPANCY SENSORS IN THE SAME ROOM SHALL BE CONNECTED TO A COMMON POWER PACK PER MANUFACTURER'S INSTRUCTIONS. WHERE SWITCHES ARE SHOWN, CONNECT LOAD SIDE OF POWER PACKS PER MANUFACTURER'S INSTRUCTIONS. PROVIDE MULTIPOLE POWER PACK WHERE MORE THAN ONE LIGHTING CIRCUIT IS SHOWN FOR THE SAME OCCUPANCY SENSOR ZONE. SENSORS SHALL BE COMPATIBLE WITH DIMMERS WHEN DIMMERS ARE SHOWN.

INSTALL CUSTOM CUT MASKING OVER SENSOR WHEN REQUIRED TO PREVENT FALSE ACTIVATION FROM OUTSIDE SENSING IN SMALL OFFICES WITH OPEN DOORS.

KEY PLAN
NOT TO SCALE

Revisions:	Date
–	–
–	–
–	–
–	–
–	–
–	–
–	–
–	–
–	–

SUB-CONSULTANTS:

Engineering and Land Surveying, P.C.
1533 Crescent Road - Clifton Park, NY 12065

STATE OF NEW YORK — WILLIAM MARSHALL — 069440 — LICENSED PROFESSIONAL ENGINEER

UNAUTHORIZED ALTERATION OR ADDITION TO THIS DRAWING IS A VIOLATION OF SECTION 7209 SUBDIVISION 2 OF THE NEW YORK STATE EDUCATION LAW.

PREPARED BY:

Sigma Psi Consulting
Mechanical, Electrical, Plumbing Engineers, PLLC
4 Collamer Road, Malta, NY 12020 PH (518) 581-9428 FX (518) 580-9325

Drawing Title	ELECTRICAL LIGHTING PLANS, BASEMENT PARTIAL PLANS
Approved Project Director	
Project Title	SYRACUSE VAMC RENOVATE POLICE STATION
Location	SYRACUSE VA MEDICAL CENTER NY
Date	4/19/13
Checked	– PJM
Drawn	– PJM
Project Number	528A7-12-708
Building Number	1
Drawing Number	E2
	Dwg. 31 of 31

Office of Construction and Facilities Management
Department of Veterans Affairs

VA FORM 08-6231