DRAWING NOTES:

1. UTILIZE EXISTING BREAKER IN PANEL 3–97 FOR CONNECTION OF BI–FOLD DOOR CONTROL PANEL. UPDATE PANEL SCHEDULE TO REFLECT ADDITION OF DEVICE.

SYMBOLS LIST	
⊕	120 VOLT CONNECTION
Ⓙ	JUNCTION BOX

PANELBOARD SCHEDULE

NOTES:

SE RATED ☐	COMPUTER GRADE ☐	FEED-THRU LUGS ☐	SUB-FEED BREAKER ☐
HINGED TRIM ☐	200% NEUTRAL ☐	SUB FEED LUGS ☐	ISOLATED GND BUS ☐

NAME	LOCATION	SOURCE	RATING (AMPS) MCB	RATING (AMPS) MLO	PHASE/ WIRE	VOLTAGE	MOUNTING	KAIC	MODEL	NEMA TYPE
3-97	CORR. 300B-1	SWBD-B2			3Ø / 4W	208Y120V	FLUSH			1

CKT NO.	DESCRIPTION	BREAKER	KVA LOAD LTG	KVA LOAD RCPT	KVA LOAD MOTOR	KVA LOAD HTG	KVA LOAD HTG	KVA LOAD MOTOR	KVA LOAD RCPT	KVA LOAD LTG	BREAKER	DESCRIPTION	CKT NO.
1	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	18
2	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	19
3	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	20
4	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	21
5	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	22
6	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	23
7	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	24
8	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	25
9	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	26
(1) 10	**BI-FOLD DOOR**	20A/1P									20A/1P	ACTIVE LOAD	27
11	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	28
12	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	29
13	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	30
14	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	31
15	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	32
16	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	33
17	ACTIVE LOAD	20A/1P									20A/1P	ACTIVE LOAD	34
LEFT SIDE SUB-TOTAL			0.0	0	0	0	0	0	0	0			
RIGHT SIDE SUB-TOTAL			0	0	0	0							
CONNECTED SUB-TOTAL			0	0	0	0							
DEMAND FACTOR			1	10+.5	0.8	0.8							
SUB-TOTAL			0	0	0	0							
TOTAL KVA:			0										
TOTAL AMPS:			0.0										

* EXISTING PANEL DIRECTORY, NEW BREAKER(S) IN HEAVY LINE WEIGHT

ISSUE FOR BID	6/14/13
Revisions	Date

VA WESTERN NEW YORK
HEALTHCARE SYSTEM
3495 BAILEY AVENUE
BUFFALO, NEW YORK 14215

Drawing Title: ELECTRICAL SCHEDULE

Project Title: WOMEN'S WELLNESS ENTRY DOOR

Building Number: 1 | Checked: JFW | Drawn: JTR

Location: V.A.M.C. BUFFALO, NEW YORK

Date: JUNE 14, 2013

Station No. 528

13–s22 E101

Office of Facilities

Department of Veterans Affairs

6/14/2013 10:24:35 AM