

22"

36"

NO SMOKING

E85

FLAMMABLE

3

1

0

NOTES:

1. 3" RED TEXT ON WHITE BACKGROUND

2. PLACARD 11" X 11" WITH BLACK LETTERS

- COLOR BEHIND 3 IS RED

- COLOR BEHIND 1 IS BLUE

- COLOR BEHIND 0 IS YELLOW

- COLOR OF EMPTY SECTION IS WHITE

1

DFS 4.0

STORY BOARD

SCALE: NONE

(7902.1.3.1)

2.1

DFS 4.0

VEEDER ROOT

2.2

DFS 4.0

FUEL CONTROL PANEL

2.3

DFS 4.0

FUEL LOG

NOTES:

1. 3/4" BLACK LETTERING ON WHITE BACKGROUND

2. 1.0" TAPE

2.X

DFS 4.0

LETTERING STICKER

SCALE: NONE

3.1

DFS 4.0

DISPENSOR VAPOR RETURN

3.2

DFS 4.0

E85 FUEL SUPPLY

3.3

DFS 4.0

VAPOR RETURN

3.4

DFS 4.0

FUEL VENT

NOTES:

1. 1-1/4" BLACK LETTERING ON YELLOW BACKGROUND WITH FLOW DIRECTION ARROWS.

3.X

DFS 4.0

LETTERING STICKER

SCALE: NONE

(5201.6.3)

4.1

DFS 4.0

1.0"

.75"

.50"

IN CASE OF FIRE, SPILL OR FUEL RELEASE

1. Use emergency pump shut off!

2. Report the accident!

Fire department Telephone No. _____

Facility address: _____

PLACE TEXT AS SHOWN TEXT HEIGHT AS INDICATED ON WHITE BACKGROUND

4.2

DFS 4.0

22.0"

8.0"

FIRE EXTINGUISHER

PLACE 2.0" BLACK TEXT AS SHOWN. WHITE BACKGROUND

4.3

DFS 4.0

.50

.437

22.0"

8.0"

WARNING

It is unlawful and dangerous to dispense fuel into unapproved containers.

No filling of portable containers in or on a motor vehicle.

Place container or ground before filling.

Disconnect your static electricity before fueling by touching a metal surface away from the nozzle.

Do not reenter your vehicle while fuel is pumping.

For fire safety, do not remove nozzle -- back away immediately.

Do not allow individuals under licensed age to use the pump.

PLACE TEXT AS SHOWN TEXT HEIGHT AS INDICATED ON WHITE BACKGROUND

4.X

DFS 4.0

LETTERING STICKER

SCALE: NONE

5.1

DFS 4.0

NO SMOKING

5.2

DFS 4.0

ATTENTION: ALARM SOUNDS AT 85% FILLED

NOTES:

3" HIGH BLACK LETTERS BACKGROUND: WHITE, HEHGT AS INDICATED, EXTEND 2.0" BEYOND END OF TEXT

5.X

DFS 4.0

LETTER SIGN

SCALE: NONE

AS BUILT

09/17/08

FUEL OIL SYSTEMS

1558 "B" STREET HAYWARD CALIFORNIA

PH 510 727 6701 FAX 510 888 1755

WWW.FUELOILSYSTEMS.NET, EMAIL: INFO@FUELOILSYSTEMS.NET

E85 DISPENSING SYSTEM

SINAGE DETAILS

REVISION: 0

SPEC:

SHT 1 OF 2

SUBMITTAL:

JOB.: SAN FRANCISCO VA E85

REF DWG.:

SCALE: NONE

APPROVED: CA HASKINS

DATE: 9/12/07

DFS-4.1