RED CLINIC
SUITE
7000 sq. ft.

KITCHEN

1700 AUDITORIUM 2467.29
C1C03 CORRIDOR 815.16
STR EX 1-11 STAIRWELL 176.85
VERT PEN 1-16 VERT PEN 1-16 20.18
1647 Red Clinic Waiting Area 137.02
1649 Exam 91.39
1650 Exam 83.32
1651 Exam 83.35
1652 Exam 85.36
1653 Exam 85.09
C1C01A Fiber Closet 42.95
C1C08A Hallway 75.97
C1C07 Hallway 240.35
1666 TRASH 113.72
C1C13A FOOD SERVICE LOADING DOCK 1078.47
STR 1-20 STAIRWELL 87.35
1662 Expendible Supplies 157.15
1663 Refrigerator 43.67
1664 Chemical Storage 64.24
1665 Sanitation Room 241.83
1667 Ingredient Control Room 911.51
C1C13 Hallway 310.28
1682 TOILET, Male 125.85
ELEVATOR 1-13 ELEVATOR (Whse) 1-13 31.08
STR EX 1-13 STAIRWELL 114.94
ELEVATOR LAB 1-14 ELEVATOR LAB 1-14 60.08
1570 HALLWAY 89.69
1570A Toilet, Female 35.11
1570B Toilet, Male 39.55
1569 HAC 24.53
1582D Protestant Chaplain 83.99
1582E Catholic Chaplain 103.65
1582F Prog Manager Pastoral Care 169.52
1570C Prog Assistant Pastoral Care 201.42
1570D STORAGE 9.88
1643 FIRE APPARATUS 3.6
1644 Clean Utility 68.48
1646 Hac 40.75
1648 Exam Room 12 14.85
1632 Exam Room 11 120.06
1633 Exam Room 10 134.29
1639 Social Worker 76.91
1637 Social Worker 4.68
1635 Consultation 94.95
1641 Social Worker 82.22
1631 Exam Room 9 140.39
1629 Exam Room 8 139.61
1627 Exam Room 7 137.17
1625 Exam Room 6 133.10
1623 Exam Room 5 132.12
1617 Exam Room 4 122.33
1615 Exam Room 2 130.42
1613 Exam Room 1 120.42
1611 Toilet, Staff 45.67
1609 HAC 31.31
C1CN06 Hallway 459.07
C1C08 Hallway 493.34
1661AEC Electrical Closet 19.25
1668A FREEZER 538.99
1668 Tempering Refrigerator 411.30
1661B REFERIGERATOR 109.80
1669 REFRIGERATOR, ICR Issue 132.59
1661 Zone 1 for ADS 471.15
1661FA FIRE APPARATUS 3.73
1670 Retherm Cart Ref 296.14
1661C FREEZER 141.82
1671 Fresh Produce Ref 227.79
1674B Food Bank, Refrigerator 281.13
1672B VCS Freezer 282.75
STR 1-2 STAIRWELL 187.55
1658 Cold Food Ref 157.12
1672A VCS Refrigerator 227.48
1672 Dairy/Juice Refergerator 383.75
1674A Daily Issue Refrigerator 373.65
C1C12 Hallway 499.34
C1C14A Hallway 445.07
1677 Mer 394.14
1678 TOILET, Female 132.21
C0154 MORGUE ELEV AREA 100.91
1681 HAC 47.18
1681A FIRE APPARATUS 3.31
1559 Exam/Office 122.81
1560 TOILET, Female 104.83
1562 TOILET, Male 97.42
1563 Exam/Office 100.44
1565 Dietician 127.09
C1C05A Corridor 676.00
1531 Exam/Office 110.78
1530 Exam/Office 119.25
1507 Exam/Office 99.70
1503 Exam/Office 105.54
1502 Exam/Office 103.94
1566 Elev Alcove 102.80
1506 Intake 155.62
1502EC Electrical Closet 18.84
1568A FIBER 45.90
PEN 1-19 PEN 1-19 30.73
C1C03 Hallway 698.63
1505 Social Worker 105.89
1504 Intake 102.95
1501 Yellow Clinic, Reception 250.42
1512 Clinical Pharmacist 106.87
1510 Clinical Pharmacist 102.52
1500 Waiting Area 629.63
1324 Toilet, Female 108.95
1325 Toilet, Male 96.85
ELEV BANK 1-C-1 ELEVATOR 83.37
ELEV BANK 1-C-2 ELEVATOR 83.37
1448
C1CN05 Hallway 213.31
1640 Exam Room 16 113.57
1638 Exam Room 15 107.99
1636 Exam Room 14 108.07
1628 Toilet, Patient 45.33
1626 Toilet, Patient 45.30
1624 RN Office 232.43
1618 Primary Care Lab 183.19
1619 Soiled Utility 32.20
1620 Exam Room 17 106.12
1622 Pharmacist 84.62
C1CN03 Hallway 132.56
C1C01 CORRIDOR 992.34
C1CN04 Hallway 223.47
1616 Exam Room 3 111.32
1602 Reception 304.60
1612 RN Interview Room 80.00
1610 RN Interview Room 84.60
1601 Red Clinic Waiting Area 724.12
C1CN01 Hallway 187.27
1603 Intake/Exit 84.82
1604 Intake/Exit 81.93
1606 Intake/Exit 83.58
1607 Dietician 96.05
1608EC Electrical Closet 25.95
1453 Kettle Area 2112.64
FIBER CLOSET Fiber Closet 39.14
1657B Pert Pen 1-20 34.14
1657AEC Electrical Closet 55.61
1657 Bread & Dessert Area 619.86
1673 Salad Preparation 992.24
1674 Frozen Food ICR 664.10
C1C15 Hallway 198.58
1676 Office 439.29
1683 HVAC 278.54
1428 Toilet, Male 36.56
1427 Toilet, Female 40.50
C1426 Hallway 148.29
STR 1-28 STAIRWELL 184.06
1675 REFERIGERATOR 91.99
1456 Ovens 2163.20
1457 Food Production

SYMBOLS LIST

- 2 HOUR FIREWALL
- 1 HOUR FIREWALL
- 2 HOUR FIRE/SMOKEWALL
- 1 HOUR FIRE/SMOKEWALL
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA
- HE HORIZONTAL EXIT PASSAGEWAY
- EX EXIT
- EP EXIT PASSAGEWAY
- LC LINEN CHUTE
- SUITE DESIGNATIONS
- AREA OPEN TO CORRIDOR – WITH SMOKE DETECTION
- AREA OPEN TO CORRIDOR – NO SMOKE DETECTION REQUIRED

BUILDING 111 FIRST FLOOR

FULLY SPRINKLERED
HEALTHCARE OCCUPANCY

Revisions	Date
FP&C Proj#:	1751.16

Dept. of Veterans Affairs
Medical Center
5000 W. National Ave.
Milwaukee, WI 53295

Approved: Chief, Facilities Management Services
Approved: Medical Center Director
Approved:
Approved:

Project Title: STATEMENT OF CONDITIONS
Drawing Title: BUILDING 111 FIRST FLOOR-C WING(SOUTH)
Client Project No.
Contract No.
Designed By: BAA
Drawn By: SFF/JV
Checked By: BAA
Building No.: BUILDING 111
AutoCAD File Name: SOC02-111-01
Location: VA MEDICAL CENTER MILWAUKEE, WISCONSIN
Date: 07/02/12
Scale: 1/16"=1'-0"
Drawing No.: SOC-2
Dwg. XX Of 14

Department of Veterans Affairs