

1 / 15-E4 ROOF PLAN - ELECTRICAL - DEMOLITION

SCALE: 1/4" = 1'-0"

N

GENERAL NOTES:

1. REFER TO 15-E1 FOR ELECTRICAL LEGEND, ABBREVIATIONS AND GENERAL NOTES.
2. REFER TO MECHANICAL PLANS FOR EXACT MECHANICAL EQUIPMENT LOCATION & ELECTRICAL CONNECTION REQUIREMENTS.
3. UNLESS OTHERWISE NOTED, ALL DEVICES SHOWN IN THIS DRAWING SHALL BE REMOVED IN THEIR ENTIRETY INCLUSIVE OF ALL ASSOCIATED CONDUIT & WIRING BACK TO PANEL, SOURCE OR POINT OF ORIGIN.
4. ALL EQUIPMENT SHOWN ON THIS DEMOLITION PLAN IS EXISTING. ELECTRICAL EQUIPMENT SHOWN SOLID AND LIGHT SHALL REMAIN ALONG WITH ASSOCIATED WORK UNLESS OTHERWISE NOTED. ELECTRICAL EQUIPMENT SHOWN DASHED AND DARK SHALL BE REMOVED AND TURNED OVER TO THE OWNER. DISPOSE OF ALL ITEMS REFUSED BY THE OWNER.
5. ALL WIRING PASSING THROUGH AREA OF DEMOLITION WHICH IS NOT PART OF DEMOLITION SHALL REMAIN SUPPORTED FROM STRUCTURE ABOVE CEILING. CONTRACTOR SHALL RESUPPORT WIRING & LIGHTING IF NECESSARY AFTER DEMOLITION HAS FINISHED. MAINTAIN THE LIGHTING CIRCUITS AND FIRE ALARM SYSTEM SERVING AREA BEYOND SCOPE OF WORK.
6. PATCH AND SEAL ALL REMAINING OPENINGS THROUGH FLOORS AND WALLS RESULTING FROM DEMOLITION OR NEW WORK WITH MATERIALS AND FINISHES TO MATCH EXISTING CONSTRUCTION AND TO MAINTAIN FIRE RATING.
7. CONTRACTOR SHALL RING OUT EXISTING CIRCUITS TO DETERMINE WHICH BRANCH CIRCUITS ARE NO LONGER IN USE. CONTRACTOR SHALL REMOVE BRANCH CIRCUIT WIRING DETERMINED NO LONGER IN USE BACK TO SOURCE IN ITS ENTIRETY. REMOVE EXISTING ABANDONED WIRING.

DRAWING NOTES:

1. REMOVE EXISTING DEVICE. EXISTING BRANCH CIRCUIT SHALL BE REMOVED BACK TO SOURCE OR NEAREST POINT OF USE.
2. PROTECT EXISTING FEEDER CONDUIT AND WIRING FOR REUSE IN NEW WORK. TRACE ALL EXISTING BRANCH CIRCUITS. PROTECT EXISTING BRANCH CIRCUIT CONDUIT AND WIRING NOT BEING REMOVED DUE TO DEMOLITION.
3. EXISTING AIR COOLED CONDENSING UNIT AND ASSOCIATED ELECTRICAL EQUIPMENT TO REMAIN.
4. REMOVE EXISTING SWITCH AND ASSOCIATED WIRING. EXISTING OUTLET BOX AND CONDUIT SHALL REMAIN FOR REUSE AS INDICATED ON NEW WORK PLAN.
5. REMOVE EXISTING LIGHTING FIXTURE, WIRING, AND CONDUIT BACK TO NEAREST POINT OF USE.
6. EXISTING WIRE TROUGH TO BE REMOVED.
7. EXISTING MOTOROLA COMMUNICATIONS CABINET TO REMAIN.
8. REMOVE EXISTING DUCT SMOKE DETECTORS AND ASSOCIATED TEST SWITCH, REUSE IN NEW WORK TO THE EXTENT POSSIBLE.
9. REMOVE EXISTING FIRE ALARM CONTROL MODULE. REUSE IN NEW WORK TO EXTENT POSSIBLE.
10. REMOVE MOTOR STARTER FEEDING WATER HEATER. WATER HEATER SHALL BE REFED IN NEW WORK.
11. EXISTING LIGHTNING PROTECTION ON ROOF MUST BE MAINTAINED. REMOVE ALL AIR TERMINALS FROM EQUIPMENT BEING REMOVED. REUSE IN NEW WORK TO EXTENT POSSIBLE.

Additions:	Date:
Revisions:	

Consultants

BURDETTE KOEHLER MURPHY & ASSOCIATES, INC.
MECHANICAL / ELECTRICAL CONSULTING ENGINEERING
1423 CLARKVIEW ROAD, SUITE 500
BALTIMORE, MARYLAND 21209
410.323.0600 – FAX 410.377.2543

BUILDING COST CONSULTANTS
COST ESTIMATING
12917 – 30TH AVENUE
PLATTSMOUTH, NEBRASKA 68048
402.298.8260 – FAX 402.298.8290

Seal:

ARCHITECTURE PLANNING ENGINEERING
POLT DESIGN GROUP
1301 Enterprise Court, Suite 103-C 410.803.2141
Bel Air, Maryland 21014-1847 fax 410.838.1603
www.polt-design.com

Drawing Scale:	Drawing Title: ROOF PLAN – ELECTRICAL – DEMOLITION	Project Title: BUILDING 15 RENOVATION	Date: 12-19-2012
Drawing Start Date:	Approved: Associate Director for Operations:		Project No: xxx-10-xxx
Drawing Finish Date	Approved: Chief, Facilites Engineer:	Building No: 15 / Checked: RAM / Drawn: BMG	DRAWING NO: 15-E4
Drawing Approved:	Approved: Director, Medical Center:	Location: VAMHCS MEDICAL CENTER WILMINGTON, DELAWARE	Dwg. – Of xx

DEPARTMENT OF VETERANS AFFAIRS

BKM# 070360.060