



- DRAWING NOTES:**

- (13) PROVIDE CONNECTION TO HEAT TRACE. COORDINATE WORK WITH MECHANICAL CONTRACTOR.
- (14) REINSTALL EXISTING LIGHTNING PROTECTION AIR TERMINALS ON NEW MECHANICAL EQUIPMENT THAT WERE SALVAGED DURING DEMOLITION. PROVIDE ADDITIONAL LIGHTNING PROTECTION COMPONENTS ON NEW MECHANICAL EQUIPMENT AND CONNECT TO EXISTING SYSTEM AS REQUIRED. CONTRACTOR SHALL VERIFY THAT EXISTING LIGHTNING PROTECTION SYSTEM AND NEW COMPONENTS COMPLY WITH NFPA 780. IF SYSTEM DOES NOT COMPLY WITH NFPA 780, THEN CONTRACTOR SHALL PROVIDE THE NECESSARY COMPONENTS AND CONNECTION REQUIREMENTS RESULTING IN A FULLY MASTER LABELED SYSTEM.
- (15) PROVIDE 3P, 208V 5HP VARIABLE FREQUENCY DRIVE WITH INTEGRAL BYPASS AND 30A DISCONNECT. EXTEND 3 #10 + 1 #10 GRD. IN 3/4" C. TO UNIT AND CIRCUIT INDICATED.
- (16) CONNECT TO ATC PANEL. COORDINATE EXACT LOCATION WITH MECHANICAL CONTRACTOR.

Dwg. - Of xx