



1 SECOND FLOOR PLAN - ELECTRICAL - DEMOLITION
15-E3 SCALE: 1/4" = 1'-0" N

GENERAL NOTES:

- | | | | |
|----|---|----|---|
| 1. | REFER TO 15-E1 FOR ELECTRICAL LEGEND, ABBREVIATIONS AND GENERAL NOTES. | 5. | PATCH AND SEAL ALL REMAINING OPENINGS THROUGH FLOORS AND WALLS RESULTING FROM DEMOLITION OR NEW WORK WITH MATERIALS AND FINISHES TO MATCH EXISTING CONSTRUCTION AND TO MAINTAIN FIRE RATING. |
| 2. | UNLESS OTHERWISE NOTED, ALL DEVICES SHOWN IN THIS DRAWING SHALL BE REMOVED IN THEIR ENTIRETY INCLUSIVE OF ALL ASSOCIATED CONDUIT & WIRING BACK TO PANEL, SOURCE OR POINT OF ORIGIN. | 6. | ALL CEILING MOUNT FIRE ALARM AND TELECOMMUNICATIONS EQUIPMENT TO BE REMOVED CLEANED AND REINSTALLED IN SAME LOCATION DURING NEW WORK. ASSOCIATED WIRE AND CONDUIT TO BE EXTENDED AND PROTECTED AS REQUIRED. |
| 3. | ALL EQUIPMENT SHOWN ON THIS DEMOLITION PLAN IS EXISTING. ELECTRICAL EQUIPMENT SHOWN SOLID AND LIGHT SHALL REMAIN ALONG WITH ASSOCIATED WIRE UNLESS OTHERWISE NOTED. ELECTRICAL EQUIPMENT SHOWN DASHED AND DARK SHALL BE REMOVED AND TURNED OVER TO THE OWNER. DISPOSE OF ALL ITEMS REFUSED BY THE OWNER. | 7. | ALL ELECTRICAL WALL MOUNT EQUIPMENT IS EXISTING TO REMAIN UNLESS NOTED OTHERWISE. |
| 4. | ALL WIRING PASSING THROUGH AREA OF DEMOLITION WHICH IS NOT PART OF DEMOLITION SHALL REMAIN SUPPORTED FROM STRUCTURE ABOVE CEILING. CONTRACTOR SHALL RESUPPORT WIRING & LIGHTING IF NECESSARY AFTER DEMOLITION HAS FINISHED. MAINTAIN THE LIGHTING CIRCUITS AND FIRE ALARM SYSTEM SERVING AREA BEYOND SCOPE OF WORK. | | |

DRAWING NOTES:

- ① REMOVE EXISTING SWITCH AND ASSOCIATED WIRING. EXISTING OUTLET BOX AND CONDUIT SHALL REMAIN FOR REUSE AS INDICATED ON NEW WORK PLAN.
- ② ALL LIGHTING FIXTURES LOCATED IN THIS AREA SHALL REMAIN. TEMPORARILY SUPPORT EXISTING DEVICE TO REMAIN DURING DEMOLITION OF CEILING.
- ③ EXISTING CRAC UNIT TO REMAIN.
- ④ EXISTING CRAC UNIT TO BE RELOCATED. DISCONNECT POWER FROM THE CRAC UNIT. REMOVE CONDUIT AND WIRE AS NEEDED. PROTECT FOR REUSE IN NEW WORK. SEE DRAWING 15-E6 FOR NEW LOCATION OF CRAC UNIT.
- ⑤ EXISTING UPS TO REMAIN.
- ⑥ TEMPORARILY SUPPORT EXISTING DEVICE TO REMAIN DURING DEMOLITION OF CEILING.

[illegible]