STOVE HOOD BY G.C. THIS CONTRACTOR SHALL PROVIDE A UL300 WET CHEM SYSTEM BY KIDDIE OR EQUAL. PROVIDE FUSIBLE LINKS IN HOOD & NOZZLES AS REQUIRED & PANEL WITH CONTACTOR'S FOR RANGE SHUT DOWN & INTER CONNECTION TO FIRE ALARM & RECESSED REMOTE MANUAL PULL STATION

NEW SPRINKLER MAIN SERVING NEW ADDITION TO BE SIZED PER SPRINKLER CONTRACTOR'S HYDRAULIC CALCULATIONS.

TIE INTO EXIST. SPRINKLER MAIN IN THIS AREA AND EXTEND TO NEW CLC SUPPORT SPACES.

EXISTING FLOW SWITCH

EXISTING FLOOR CONTROL VALVE SERVING THIS AREA APPROX. EXIST. AREA 13720 SQ.FT. NEW ADDITION 5350 SQ.FT.

6" FIRE MAIN

EXISTING COMBINED INCOMING WATER SERVICE TO BUILDING

4" SPRINKLER RISER UP TO SECOND FLOOR

EXISTING WATER MAIN TO DOMESTIC WATER SYSTEM

EXISTING 4" FIRE MAIN

EXISTING SPRINKLER MAIN

EXISTING 4" MAIN TO EXISTING WEST WINGS

EXISTING SPRINKLER MAIN

EXISTING 4" FIRE MAIN TO EXISTING EAST WINGS

REMOVE EXISTING SPRINKLER HEAD IN THIS AREA AND INSTALL NEW RECESSED HEAD IN THIS AREA.

NOTES:

1. DISCONNECT AND REMOVE EXISTING SPRINKLER HEADS AND PIPING IN EXISTING AREAS BEING RENOVATED AND REROUTE PIPING TO NEW HEADS WERE SHOWN. FIELD VERIFY EXACT LOCATION AND ROUTING OF EXISTING SPRINKLER MAINS.
2. REMOVE EXISTING CORRIDOR SPRINKLER HEADS AND REINSTALL NEW HEADS TO ACCOMMODATE NEW CORRIDOR CEILING

CAFE 101 TO BE FIT-OUT BY VA

OCCUPATIONAL THERAPY 127 · ADL KITCHEN 129 · FEC · A/C ENTR.ROOM 130 · PT STORAGE ROOM 131 · EQUIPMENT HEATER 132 · PLUMBING 133 · VESTIBULE 199 · SUPPLIES · SUPPLIES · PT./OT OFFICE 136 · MULTI-PURPOSE ROOM 135 · CLEAN LINEN · PHYSICAL THERAPY 122 · CORRIDOR 100D · PT STORAGE ROOM 121 · EXAM ROOM 120 · HC TOILET 146 · HC TOILET 145 · CORRIDOR 100C · CARPENTRY SHOP · PHARMACY · ELEVATOR EQUIPMENT · HAC · RESPIRATORY OFFICE 118 · SPEECH THPY ROOM 117 · SPEECH THPY OFFICE 116 · HAC 208 · STORAGE 114 · MEDITATION ROOM 115 · EMS OFFICE · ELECTRICAL CLOSET · PSYCHIATRIST 114 · RESPIRATORY STORAGE 119 · DENTAL EXAM 112 · DENTAL EXAM 113 · CORRIDOR 100E · PUMP CLOSET 111 · AUDIO CONTROL RM 107 · AUDIOMETRIC ROOM 108 · PSYCHOLOGIST · CORRIDOR 100B · CAFE 101 · ELEVATOR EQUIPMENT · TELEPHONE CLOSET · HYGIENIST 109 · DENTAL OFFICE 110 · PROST FITTING 106 · WAITING 105 · PODIATRIST / ORTHOPEDIST / OPTOMETRIST 104 · CORRIDOR 100A · GENERAL STORAGE · RESIDENT STORAGE · HAC · TOILET · RECEPTION · OFFICE · TOILET · OFFICE · TOILET · OFFICE · OFFICE · CONFERENCE ROOM · PHYSICIAN 1.C.153 · HEAD NURSE 1.C.151 · 1 BR 1.C.149 · 2 BR 1.C.148 · 2 BR 1.C.147 · 2 BR 1.C.146 · 2 BR 1.C.112 · 2 BR 1.C.111 · 2 BR 1.C.110 · 1 BR 1.C.108 · 1 BR 1.C.107 · SPD 1.C.105 · CONG. BATH 1.C.101 · LAUNDRY 1.C.102 · CONG. TOILET 1.C.101A

1ST FLOOR PLAN – PLUMBING

1/8" = 1'-0"

PARTITION LEGEND

.....	SMOKE PARTITION - PREVENT THE PASSAGE OF SMOKE
- - - - -	SMOKE BARRIER - 1 HR RATING
— — —	2 HR RATED PARTITION
— · —	1 HR RATED PARTITION

SYMBOL LIST

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	O.S.&Y. VALVE/TAMPER SWITCH	ND	NEW DRY TYPE SIDEWALL SPRINKLER HEAD
F.S.	FLOW SWITCH	N	NEW QUICK RESPONSE UPRIGHT SPRINKLER HEAD
N	NEW SEMI– RECESSED QUICK RESPONSE PENDANT SPRINKLER HEAD		

SPRINKLER HEAD LOCATION DETAIL

NOT TO SCALE



NOTE: SPRINKLER HEADS TO BE FM APPROVED.



SPRINKLER HEAD DETAIL

N.T.S.



Sprinkler Head Detail at Audiology Booth



4/19/13

Revisions	Date

OVERALL FLOOR PLAN

Department of Veterans Affairs
New Jersey Health Care System
151 Knollcroft Road
Lyons, New Jersey 07939

BBLM Architects
Architecture Planning Interiors
924 Cherry Street Phila., PA 19107 (215) 625-2500
A Professional Corporation

Ritter & Plante Associates, LLC
4220 Main Street
Philadelphia, PA 19127
t: (215) 508-3900
f: (215) 508-3800

The Kachele Group
1218 Chestnut Street
Philadelphia, PA 19107
t: (215) 238-1994
f: (215) 238-6950

LKU Group, Inc. CONSULTING ENGINEERS
241 Molnar Drive
Elmwood Park, NJ 07407
t: (201) 791-1210
Matthew Huber, Professional Engineer NJ NO. 20843

Drawing Title: FIRE PROTECTION: FIRST FLOOR PLAN

Project Title: CLC SUPPORT SPACES VAMC - LYONS

Date: 2/05/13

Project No.: 1009

Approved: Chief, Facilities Engineering Serv.

Drawn: TJK

Building Number: 135

Contract Number: 561-CSI-136

Approved: Chief Executive Officer

Checked: JA

Location: LYONS, NJ

FP-1

Dwg. OF

VETERANS ADMINISTRATION