

SECOND FLOOR FRAMING PLAN
SCALE: 1/8" = 1'-0"


PLAN NOTES:

1. TOP OF NEW CONCRETE SLAB ELEVATION TO MATCH TOP OF EXISTING SLAB ELEV. +13'-4" ABOVE DATUM, UNLESS NOTED THUS \pm X'-X" ON PLAN FROM TOP OF SLAB ELEV.
2. TOP OF STEEL ELEVATION IS 61" BELOW TOP OF SLAB ELEVATION UNLESS NOTED THUS (X'-X") FROM TOP OF STEEL ELEVATION.
3. (F1) DENOTES 3/4" LIGHTWEIGHT CONC. TOPPING (f'c=4000 PSI)
ON 3"-20GA GALV. COMPOSITE METAL FLOOR DECK. TOTAL THICKNESS = 61".
REINFORCED WITH WWF W6x8-W2.1xW2.1 AND #4x8'-0" @ 12" O.C. OVER GIRDERS.
4. (P2) DENOTES SLOPING CONCRETE SLAB. MIN. 3/4" LIGHTWEIGHT CONC. TOPPING (f'c=4000 PSI)
ON 3"-20GA GALV. COMPOSITE METAL FLOOR DECK. SLOPE AT 1/4" / 1'-0" MIN.
SEE ARCH DRAWINGS.
5. STRUCTURAL STEEL FRAMING KEY:

6. L1 DENOTES DBL. W16x26 LINTEL.
7. BEAMS TO BE EQUALLY SPACED U.N.O.
8. SEE S602 FOR SECTIONS AND S603 FOR TYPICAL DETAILS.
9. SEE S001 FOR GENERAL NOTES.
10. DENOTES MOMENT CONNECTION.
11. CENTERLINES OF COLUMNS, BEAMS PIERS, WALLS, FOOTINGS, ETC.
ALIGN WITH THE ESTABLISHED GRID LINES, U.N.O.
12. BP1 DENOTES BEARING PLATE 12"x5"x3/8".
13. BP2 DENOTES BEARING PLATE 15"x7"x3/8".

FRAMING CONSTRUCTION NOTE:

- (CN-1) TEMPORARY SHORE EX. STEEL BEAM FOR 55 KIPS. COORDINATE LOCATION IN THE FIELD WITH EX. DUCTWORK AS VERY LITTLE CLEARANCE AND ACCESS EXISTS. VERIFY BEARING CAPACITY OF EX. SLAB ON GRADE FOR SUPPORT OF TEMP. SHORING. PROVIDE CRIBBING AS REQUIRED.
- (CN-2) SAWCUT AND DEMOLISH PORTION OF EX. CONC. WALL.
- (CN-3) CONNECT STEEL TO EXIST. CONCRETE WALL.
- (CN-4) CONNECT STEEL TO EXIST. STEEL BEAM. REMOVE EXISTING FIREPROOFING AS REQ'D.
- (CN-5) STEEL DESIGNED FOR MODERNFOLD ACQUISI-SEAL S32 SUSPENSION SYSTEM FOR OPERABLE PARTITIONS. SEE ARCHITECTURAL DRAWINGS FOR DETAILS AND FURTHER INFORMATION.
- (CN-6) STEEL DESIGNED FOR KAWNEER 1040 SLIDING MALL WALL PARTITION. SEE ARCHITECTURAL DRAWINGS FOR DETAILS AND FURTHER INFORMATION.
- (CN-7) APPLY CEMENTITIOUS GROUT FILL SLOPED AT 1/4" / 1'-0" TO MATCH SLAB ELEVATION.
- (CN-8) DOWEL NEW FLOOR SLAB TO EXISTING SECOND FLOOR SLAB. SEE SECTIONS FOR FURTHER INFORMATION.



Department of Veterans Affairs
New Jersey Health Care System
151 Knollcroft Road
Lyons, New Jersey 07939



BBLM
Architects

Architecture Planning Interiors
924 Cherry Street Phila., PA 19107 (215) 625-2500



Drawing Title
CLC SUPPORT SPACES
SECOND FLOOR FRAMING PLAN
Approved: Chief, Facilities Engineering Serv.
Drawn L.M.R. / V.B.
Checked D.W.
Approved: Chief Executive Officer

Project Title
CLC SUPPORT SPACES
VAMC - LYONS
Building Number 135
Contract Number 561-CSI-136
Location LYONS, NJ

Date 2/5/13
Project No. 1009
S-102
Dwg. OF

VETERANS
ADMINISTRATION