PARTITION LEGEND

- SMOKE PARTITION - PREVENT THE PASSAGE OF SMOKE
- SMOKE BARRIER - 1 HR RATING
- 2 HR RATED PARTITION
- 1 HR RATED PARTITION

NOTES:

1. DISCONNECT AND REMOVE EXISTING LIGHTING FIXTURE. THIS FIXTURE IS CONNECTED TO PANEL EL-2A VIA PHOTOCELL AND RELAY CONTROLS. EXTEND EXISTING WIRING TO NEW LIGHTING AS SHOWN.
2. DISCONNECT AND REMOVE EXISTING LIGHTING FIXTURE. THIS FIXTURE IS CONNECTED TO PANEL L-2A EXTEND EXISTING WIRING TO NEW LIGHTING AS SHOWN.
3. CONNECT TO EMERGENCY CIRCUITS SERVING EXISTING LIGHTS AND EXIT SIGNS. EXIT LIGHTS ARE CONNECTED TO SEPARATE CIRCUT
4. COORDINATE ALL WORK WITH PHASING DRAWINGS.

2ND FLOOR PLAN

1/8" = 1'-0"



KEY PLAN

4/19/13

OVERALL FLOOR PLAN

Department of Veterans Affairs
New Jersey Health Care System
151 Knollcroft Road
Lyons, New Jersey 07939

BBLM Architects
A Professional Corporation
Architecture Planning Interiors
924 Cherry Street Phila., PA 19107 (215) 625-2500

Ritter & Plante Associates, LLC
4220 Main Street
Philadelphia, PA 19127
t: (215) 508-3900
f: (215) 508-3800

The Kachele Group
1218 Chestnut Street
Philadelphia, PA 19107
t: (215) 238-1994
f: (215) 238-6950

LKU Group Inc.
CONSULTING ENGINEERS
241 Molnar Drive
Elmwood Park, NJ 07407
t: (201) 791-1210
Matthew Huber, Professional Engineer NJ NO. 20843

Revisions	Date

Drawing Title: ELECTRICAL: SECOND FLOOR - LIGHTING

Project Title: CLC SUPPORT SPACES VAMC - LYONS

Date: 2/05/13

Project No.: 1009

Approved: Chief, Facilities Engineering Serv.

Drawn: SMR

Building Number: 135

Contract Number: 561-CSI-136

Approved: Chief Executive Officer

Checked: JA

Location: LYONS, NJ

Dwg. E-7 OF

VETERANS ADMINISTRATION